



**The Member Secretary
Jharkhand State Pollution Control Board
T A Division Building,
HEC Campus, Dhurwa
Ranchi – 834004**

MD/ ENV/ 226 /125/2021
Date: 22nd September 2021

Sub: Environmental Statement of Tata Steel Hospital, Noamundi for 2020-21.

Dear Sir

Kindly find attach herewith the Environment Statement in the prescribed format (Form V) as per “Environmental (Protection) Amendment Rules, 1992” of our Tata Steel Hospital, Noamundi for your kind perusal..

Thanking you,

Yours faithfully
f: Tata Steel Limited


**Chief Medical Officer
Tata Steel Hospital, Noamundi
Tata Steel Hospital
Noamundi**

Encl: As above

**Copy to: The Regional Officer
Jharkhand State Pollution Control Board
MB/12 New Housing Colony
Adityapur, Jamshedpur - 831013, Jharkhand**

TATA STEEL LIMITED

Mines Division Noamundi 833 217 India
Tel 91 9234301340 Fax 91 6596 290737
Registered Office Bombay House 24 Homi Mody Street Fort Mumbai 400 001
Tel 91 22 66658282 Fax 91 22 66657724
Corporate Identity Number L27100MH1907PLC000260 Website www.tatasteel.com

ENVIRONMENT STATEMENT 2020-21



10KLD Effluent Treatment Plant (ETP) at Hospital

TATA Steel Hospital, Noamundi

TATA STEEL LIMITED

September 2021

FORM - V
(See Rule -14)

ENVIRONMENT STATEMENT FOR THE FINANCIAL YEAR ENDING THE 31st MARCH, 2021

TATA STEEL HOSPITAL, NOAMUNDI

PART-A

1	Name and address of the owner/ occupier of the industry, operation or process	:	Dr Dhirendra Kumar, Chief Medical Officer, Tata Steel Hospital Noamundi, Babu Line Campus, Noamundi, Dist.-West Singhbhum, Jharkhand-833217
	Agent	:	Dr Dhirendra Kumar
	Nominated Owner	:	Mr. Atul Bhatnagar, General Manager, OMQ division, Administrative Building, Noamundi Iron Mine, Tata Steel Limited PO.: Noamundi, Dist.-West Singhbhum Jharkhand - 833217 Mr T V Narendran, Managing Director & CEO, Tata Steel Ltd, PO: Jamshedpur, Dist.: East Singhbhum, Jharkhand-831001
2	Industry Category	:	Hospital (Health Care Facility)
3	Production Capacity	:	75 Bedded Hospital with all facility
4	Year of Establishment	:	1925
5	Date of last Environmental Statement submitted.	:	28.09.2020 vide letter no. MD/ENV/831/125/2020

Tata Steel hospital Noamundi is one of the health care facility of Noamundi iron Mine and shares all the resources of mine.

PART-B

Water and Raw Material Consumption

(i) Water Consumption:

Consumption Head:	2019-20 (in KL)	2020-21 (in KL)
Process	Nil	Nil
Spraying in mine pit , services	Nil	Nil
Domestic	Nil	Nil
Name of the product	Process water consumption per product output (m3/MT)	
	During the Previous financial Year (2019-20)	During the current financial Year (2020-21)
Hospital (Used in Housekeeping activity)	23566 KL	25882 KL

ii) Raw Material Consumption

The following items have been consumed/ utilized:

Name of Raw materials	Consumption of Raw Material	
	During Previous financial year (2019-20)	During current financial year (2020-21)
Oxygen gas	811 Kg (30 nos. of various capacity cylinders)	D- type – 59 nos.
		B- type – 72 nos.
		A- type - 08 nos.
Nitrous oxide	10 cylinders	8 cylinders
CO2		10 cylinders
It's a health care facility (Hospital) & thus various medicine are used for medical treatments		
Electric Power:		
Consumed	Nil	
Generated		

PART-C
POLLUTION DISCHARGED TO ENVIROMENT/ UNIT OF OUTPUT
(Parameters as specified in the consent issued)

Pollutants	Quantity of Pollutants discharged (mass / day)	Concentration of Pollutants discharges (mass / day)	Percentage of variation from prescribed standards with reasons
a) Water	At Tata Steel Hospital Noamundi all the liquid waste after pre-treatment connected to Effluent Treatment Plant (ETP) of 10 KLD. The treated water is consumed for plantation activities. All the water quality results of ETP are attached herewith in annexure-1.		
b) Air	At Tata Steel Hospital Noamundi, for disposal of bio-medical waste, an incinerator is installed. The air emission from same is regularly been monitored. The results of air quality monitoring is attached as annexure-2.		

PART-D
HAZARDOUS WASTES

As specified under the Hazardous & Other Waste (Management & Trans boundary Movement) Rules, 2016 and amendment thereof

Hazardous Wastes	Total Quantity	
	During the Previous Financial Year (2019-20)	During the Current Financial Year (2020-21)
I) From Process:	Nil	Nil
II) From Pollution Control Facility:		
▪ Bio-medical incinerator ash	17.7 Kg	88.63 Kg

PART-E
SOLID WASTES

Tata Steel Hospital, Noamundi is a Health Care Facility with ICU, Blood Bank, Pathological Lab, X-ray unit, Ultra sound facility etc. The solid waste generated in hospital such as refused food, peel of fruits etc. been generated and disposed of along with municipal solid waste.

Sources	TOTAL QUALITY	
	During the Previous Year (2019-20)	During the Current Year (2020-21)
a) From Process: b) From Pollution Control Facility c) i. Quantity recycled or reused within the unit ii. Quantity sold iii. Quantity disposed ▪ General Office Waste (garbage)	Treated water from ETP 5.87 tonne /yr	Treated water from ETP 5.44 tonne /yr

PART-F

THE CHARACTERISTICS (in terms of composition and quantum) OF HAZARDOUS AS WELL AS SOLID WASTES AND INDICATE DISPOSAL PRACTICE ADOPTED FOR BOTH THESE CATEGORIES OF WASTES

Tata Steel Hospital, Noamundi is a Health Care Facility with ICU, Blood Bank, Pathological Lab, X-ray unit, Ultra sound facility etc. Only bio-medical waste along with garbage (solid waste) is been generated, all the biomedical waste generated is disposed off as per Biomedical waste management Rule -2016.

Yellow Category	: 1776 kg	Red Category	: 1218 kg
White Category	: 2239 kg	Blue Category	: 847,5 kg
General Solid Waste	: 5440.5 Kg		

DISPOSAL PRACTICE:-

The segregation of Bio-medical waste is made from generation point and shall be disposed as per norms. Due to absence of common facility; a double chamber Incinerator has been installed at Hospital along with autoclave, shredder and other various facilities for disposal of Bio-medical waste.

The liquid chemical waste generated from pathology, blood bank etc. is pre-treated in neutralisation pit followed by treatment in 10 KLD Effluent Treatment Plant (ETP). The treated water is recycled & reused in horticulture activities.

PART-G

IMPACT OF POLLUTION ABATEMENT MEASURES TAKEN ON CONSERVATION OF NATURAL RESOURCES AND ON THE COST OF PRODUCTION

- For the adequate disposal of biomedical waste an Incinerator has been installed in unit.
- Plastic shredder, deep burial for incinerated ash disposal, autoclave is available in hospital.
- 10 KLD Effluent Treatment Plant is been established on 2nd August 2017.
- Pre-treatment such as neutralization of contamination of waste by using Hypochlorite dosing and autoclaving is practiced regularly before incineration of waste.

- The hospital has enhanced the facility such as new casualty, eye operation machines, various microscopes for surgery, auto analysers etc.
- The hospital is also proposed in Ayushman Bharat the National Health Protection Scheme of Govt. of India for treatment of economically weaker section of people.

PART-H

ADDITIONAL MEASURES/ INVESTMENT PROPOSAL FOR ENVIRONMENTAL PROTECTION INCLUDING ABATEMENT OF POLLUTION, PREVENTION OF POLLUTION

- The hospital spend additional environmental cost for operation & maintenance of bio-medical treatment facility apart from mines.

PART-I

ANY OTHER PARTICULARS FOR IMPROVING THE QUALITY OF THE ENVIRONMENT

- The hospitals is an integral part of mine and has adopted & certified for the Integrated Management System (ISO 9001: 2015, ISO 14001: 2015 & ISO 45001:2018 & SA 8001) and have been certified from year 2008.
- The hospital has its own facilities such as ICU, X-ray, Ultra Sound, Pathology, Dispensary, OT, Wards, Blood bank, Medicine store with pharmacist.
- The hospital celebrated & organizes various public events for awareness such as World TB Day, World Health Day, Nutrition & dietetics day, World Heart Day, No Tobacco day, AIDS Awareness Day, Brest Feeding Day etc. and organizes various Blood donation camps.


22/09/2021

**Chief Medical Officer,
Tata Steel Hospital, Noamundi**

Chief Medical Officer
**Tata Steel Hospital
Noamundi**

WATER QUALITY DATA 2020-21
TATA Steel Hospital, Noamundi
(Annual Average)

Parameters	EFFLUENT TREATMENT PLANT (ETP)		Standard
	10 KLD Inlet	10 KLD Outlet	
pH*	6.50	6.83	5.5-9.0
TSS (mg/l)	107.50	6.83	100
BOD 5 days (mg/l)	42.10	24.50	30
COD (mg/l)	135.79	8.23	250
Oil & Grease (mg/l)	BDL	BDL	10
Iron (mg/l)	0.32	0.22	3.0
Faecal Coliform	140.30	63.60	-

Note: BDL - Below detection limit

AIR QUALITY DATA 2020-21
Annual Average Air quality of Tata Steel Hospital, Noamundi of FY'21

Pollutants	Concentration of pollutants ($\mu\text{g}/\text{m}^3$)	Standards ($\mu\text{g}/\text{m}^3$)
Near Hospital		
1. PM ₁₀	56.87	100
2. PM _{2.5}	24.42	60
3. SO ₂	7.32	80
4. NO _x	17.02	80
5. CO	0.329	4*

*Unit of CO is mg/m³