



TSL/MoEF&CC/TS-26/2024-02/507 November 25, 2024

### The Deputy Director General of Forests (C) Ministry of Environment, Forest and Climate Change, Integrated Regional Office, A/3, Chandersekharpur, Bhubaneswar-751023

**Subject:** Half yearly EC compliance reports of 256 MW captive power plant of Tata Steel Ltd., Meramandali for the period April'24 to Sept'24.

**Reference:** EC vide letters no.J-13012/77/2011-IA-II (I), dated 12.02.2015

Dear Sir,

This has reference to the captioned subject and cited references. It is to inform that we are herewith submitting six monthly compliance reports for the conditions stipulated in the Environment Clearance of 256 MW captive power plant of Integrated Steel Plant of Tata Steel Ltd. Meramandali for the period from April 2024 to September 2024 along with monitoring report for your kind consideration.

The copy of above compliance report is also being sent in soft format through email (roez.bsr-mef@nic.in) for your kind perusal. Also copy of EC compliance is being uploaded on MoEFCC website on portal http:// environmentalclearance.nic.in.

Hope, the above are in line with the statutory requirements.

Thanking you,

Yours faithfully, For Tata Steel Limited

NOOP -

Anoop Srivastava Chief Environment -TSM

Copy to:

- The Zonal Officer, Central Pollution Control Board, Southern Conclave Block 502, 4 & 6<sup>th</sup> Floors, 1582 Rajdanga Main Road, Kolkata - 700107.
- II. The Member Secretary, SPCB, Parivesh Bhawan, A/118, Nilakahanta Nagar, Unit-VIII, Odisha, Bhubaneswar-751012.
- III. The Regional Officer, State Pollution Control Board, Odisha, Angul.

### TATA STEEL LIMITED

Narendrapur Kusupanga Meramandali Dhenkanal 759 121 Odisha India Tel 91 6762 352000 Registered Office Bombay House 24 Homi Mody Street Fort Mumbai 400 001 India Tel 91 22 66658282 Fax 91 22 66657724 Corporate Identity Number L27100MH1907PLC000260 Website www.tatasteel.com

(For the period from April' 2024 to September' 2024)

SL.	STIPULATED CONDITIONS	COMPLIANCE STATUS				
i	Vision document specifying prospective plan for the site shall be formulated and submitted to the RO of the Ministry within six months.	statements have been submitted to the				
ii	Harnessing solar power within the premises of the plant particularly at available roof tops shall be carried out and status of implementation including actual generation of solar power shall be submitted along with half yearly monitoring report.	<ul> <li>from DRI units through WHRBs.</li> <li>Additionally, coke oven and blast furnace gases are also used for generating green power through gas fired boilers utilizing</li> </ul>				
iii	Sulphur and ash contents in the imported coal to be used in the project shall not exceed 0.3% and 6% respectively at any given time. In case of variation of coal quality at any point of time, fresh reference shall be made to the Ministry for suitable amendments to environment clearance condition wherever necessary.	Not applicable.				
iv	A long term study of radioactivity and heavy metals contents in coal to be used shall be carried out through a reputed institute and results thereof analyzed every two years and reported along with monitoring reports. Thereafter mechanism for an in-built continuous monitoring for radioactivity and heavy metals in coal and fly ash (including bottom ash) shall be put in place.	<ul> <li>Not applicable.</li> <li>As presently gas-based power plant of capacity 165 MW has been commissioned. This plant does not consume coal hence, no ash is being generated.</li> <li>Hence, no need no monitor Radioactivity and heavy metals contents in coal and ash.</li> </ul>				
V	A stack of 220 meter height shall be provided with continuous online monitoring equipments for SO <sub>x</sub> , NO <sub>x</sub> , PM <sub>10</sub> and PM <sub>2.5</sub> . Exit velocity of flue gases shall not be less than 22 m / sec. Mercury emissions from stack shall also be monitored on periodic basis.	<ul> <li>Not applicable.</li> <li>As gas fired boiler has been commissioned instead of CFBC coal boiler. Chimney height 70 m and 40 m is attached to 60 TPH &amp; 125 TPH and 250 TPH respectively. Online monitoring system has been installed for Sox and NOx in the stacks. Online data is</li> </ul>				

Tata Steel Limited, Meramandali, Dhenkanal 759121

(For the p	eriod from April' 2024 to September' 2024)	
		transmitted to SPCB and CPCB servers through RT-DAS.
vi	High efficiency ESPs shall be installed to ensure that particulate emission does not exceed 50 mg / Nm <sup>3</sup> . Adequate dust extraction system such as cyclones/bag filters and water spraying system in dusty areas such as in coal handling and ash handling points, transfer areas and other vulnerable dusty areas shall be provided.	<ul> <li>Not applicable.</li> <li>As presently gas-based power plant of capacity 165 MW has been commissioned. This plant does not consume coal and particulate matter emission is very less. Hence, no requirement of ESPs.</li> </ul>
Vii	Adequate dust extraction system such as cyclones / bag filters and water spraying system in dusty areas such as in coal handling and ash handling points, transfer areas and other vulnerable dusty areas shall be provided.	<ul> <li>EC was granted to install coal base thermal power plant; however, gas base power plant has installed.</li> </ul>
viii	COC of at least 5.0 shall be adopted	COC in the range of 7 -8 is maintained.
ix	Monitoring of surface water quantity and quality shall also be regularly conducted and records maintained. The monitoring data shall be submitted to the Ministry regularly. Further, monitoring points shall be located between the plant and drainage in the direction of the flow of ground water and records maintained. Monitoring for heavy metals in ground water shall also be undertaken and results/findings submitted along with half yearly monitoring report.	<ul> <li>Monitoring of surface water and ground water is being carried out regularly. Monthly monitoring reports are being submitted to the SPCB, Odisha. Last monitoring report was submitted on May 10<sup>th</sup>, 2024.</li> <li>The summarized data is enclosed as Annexure - I.</li> </ul>
X	A well designed rainwater harvesting system shall be put in place within six months, which shall comprise of rain water collection from the built up and open area in the plant premises and detailed records kept of the quantity of water harvested every year and its use.	<ul> <li>Earthen pond and HDPE pond have been constructed to harvest rainwater. This water is reused in the process when required. During the period April'24 to Sept'24, 36774 m3 of rainwater has been utilized in process.</li> <li>Surface runoff water collected from DRI &amp; RMHS area are channelized through drains into a series of storage pond for harvesting.</li> </ul>
xi	No water bodies including natural drainage system in the area shall be disturbed due to activities associated	<ul> <li>No water body or natural drainage system is disturbed.</li> </ul>

Tata Steel Limited, Meramandali, Dhenkanal 759121

(For the p	eriod from April' 2024 to September' 2024)	
	with the setting up / operation of the	
	power plant.	
xii	Hydrogeology of the area shall be reviewed annually from an institute / organization of repute to assess impact of surface water and ground regime (especially around ash dyke). In case any deterioration is observed, specific mitigation measures shall be undertaken and report / data of water quality monitored regularly and maintained shall be submitted to the Regional Office of the Ministry.	<ul> <li>Not applicable.</li> <li>As presently gas-based power plant of capacity 165 MW has been commissioned. However, ground water level and quality are being monitored on quarterly basis and hydrogeology study is being carried out by IMMT, Bhubaneswar. The summary of the report is attached as Annexure- II.</li> </ul>
xiii	Waste water generated from the plant shall be treated before discharge to comply limits prescribed by the SPCB / CPCB.	<ul> <li>Wastewater generated from the plant is being treated in Effluent Treatment Plant</li> <li>Treated water is reused in slag granulation, greenery development and low-end application in Blast Furnace &amp; Sinter Plant etc.</li> <li>The water quality parameters are well within the limit as per the prescribed standard.</li> <li>Water analysis report is enclosed as Annexure-I.</li> </ul>
xiv	Additional soil for leveling of the proposed site shall be generated within the site (to the extent possible) so that natural drainage system of the area is protected and improved.	<ul> <li>No additional soil is required for leveling the site.</li> </ul>
xv	Prior approval of the Ministry shall be obtained for Mine Void and abandoned stone quarry filling of fly ash based on the outcome of the pilot study for which permission was accorded to the existing units by the Ministry on 05.09.2013 subject to Hon'ble NGT's Order.	<ul> <li>We request to withdraw this condition as this is not applicable. We have communicated vide letter No. TSBSL/MoEF&amp;CC/BS-01/2020-01/57 dtd.27.08.20.</li> </ul>
xvi	Fly ash shall be collected in dry form and storage facility (silos) shall be provided. Unutilized fly ash shall be disposed off in the ash pond in the form of slurry. Mercury and other heavy metals (As, Cr, Pb etc) will be monitored in the bottom ash as also in the effluents emanating	<ul> <li>Not applicable.</li> <li>As presently gas-based power plant of capacity 165 MW has been commissioned. This plant does not consume coal hence, no ash is being generated.</li> </ul>

(For the p	eriod from April' 2024 to September' 2024)	
	from the existing ash pond. No ash shall be disposed off in low lying areas.	
xvii	Fugitive emission of fly ash (dry or wet) shall be controlled such that no agricultural or non-agricultural land is affected. Damage to any land shall be mitigated and suitable compensation provided in consultation with the local panchayat.	
xviii	Ash pond shall be lined up with HDPE/LDPE lining or any other suitable material impermeable media such that no leachate takes place at any point of time. Adequate safety measures shall also be implemented to protect the ash dyke from getting breached.	
xix	Green belt consisting of three tire of plantation of native species around plant and at least 50 m width shall be raised. Wherever 50 m width is not feasible a 20 m width shall be raised and adequate justification shall be submitted to the Ministry. Tree density shall not be less than 2500 trees per ha with survival rate not less than 80%. Only native species shall be planted and the green belt development shall be expedited.	<ul> <li>Green belt development is under progress in and around the plant complex by planting indigenous species as per CPCB guidelines. Till Mar'22, 33.66% area (this includes Plant, R&amp;R and CSR plantation) has been covered under green belt. Rapid afforestation using MiyaWaki method in consultation with IIT, Kharagpur has been initiated.</li> <li>Plantation of saplings are done regularly based on the availability of vacant area. During the period April'24 to Sept'24 44052 nos. of plant have been planted. Proper maintenance of green coverage is being ensured throughout the year.</li> </ul>
XX	CSR schemes identified based on Public Hearing issues and need based assessment shall be implemented in consultation with the village panchayat and the District administration starting from the development of the project itself. As part of CSR, prior identification of local employable youth and eventual employment in the project after imparting relevant training shall be also undertaken. Company shall provide separate budget for community	<ul> <li>The peripheral development is being carried out based on socio economic survey and need based assessment. Based on this, company has provided the facilities of sanitation, drinking water, education, health care, road and communication facilities etc in surrounding villages.</li> <li>Various socio-economic development programs covering education, safe drinking water, sports and health care etc are undertaken in nearby villages.</li> <li>Details breakup of CSR initiatives are enclosed as Annexure-III</li> </ul>

Tata Steel Limited, Meramandali, Dhenkanal 759121

(For the p	eriod from April' 2024 to September' 2024)	
	development activities and income	
	generating program.	
xxi	As committed, a minimum amount of Rs. 40.00 crore shall be earmarked for CSR activities for next five years. For proper and periodic monitoring of CSR activities, a CSR committee or a social audit committee or a suitable credible external agency shall be appointed. CSR activities shall also be evaluated by an independent external agency. This evaluation shall be both concurrent and final	<ul> <li>CSR department has been established to monitor the CSR activities. The CSR activities are based on need based assessment.</li> </ul>
xxii	For proper and periodic monitoring of CSR activities, a CSR committee or a social audit committee or a suitable credible external agency shall be appointed. CSR activities shall also be evaluated by an independent external agency. This evaluation shall be both concurrent and final.	<ul> <li>As per the revised companies Act, 2013 and its amendment, CSR committee has been formed. Evaluation of each specific CSR intervention/activities is monitored &amp; evaluated by the CSR Committee.</li> <li>Evaluation of the Impact of Corporate Social Responsibility Projects has been carried out by XIMB, Bhubaneswar.</li> </ul>
xxiii	An Environmental Cell comprising of at least one expert in environment science/engineering, ecology, occupational health and social science, shall be created preferably at the project site itself and shall be headed by an officer of appropriate superiority and qualification. It shall be ensured that the Head of the Cell shall directly report to the Head of the Plant who would be accountable for implementation of environmental regulations and social impact improvement / mitigation measures.	<ul> <li>Environment Management Department has been established for implementation of stipulated environmental safeguards and control of pollution.</li> <li>The head of the Environment department and other officers are having Environmental Science/Engineering qualification and adequate experience.</li> </ul>
А	General Conditions:	
i	Space for FGD shall be provided for future installation as may be required.	<ul> <li>Not applicable.</li> <li>As presently gas-based power plant of capacity 165 MW has been commissioned. This plant does not consume coal hence, generation SO2 is minimum. Hence, FGD is not required.</li> </ul>
ii	The treated effluents conforming to the prescribed standards only shall be re-	Wastewater is treated in ETP . The treated effluent, conforming to the prescribed

Tata Steel Limited, Meramandali, Dhenkanal 759121

	eriod from April' 2024 to September' 2024) circulated and re-used within the plant. Arrangements shall be made that effluents and storm water do not get mixed	standards, are recycled and reused for slag granulation, dust suppression and green area development.			
iii	A sewage treatment plant shall be provided (as applicable) and the treated sewage shall be used for raising greenbelt / plantation.	<ul> <li>STP of 100 m3 per day has been installed near Blast Furnace-I.</li> </ul>			
iv	Adequate safety measures shall be provided in the plant area to check/minimize spontaneous fire in coal yard especially during summer season. Copy of these measures with full details along with location on plant layout shall be submitted to the Ministry as well as to the Regional Office of the Ministry.	<ul> <li>Not applicable</li> <li>As presently gas-based power plant of capacity 165 MW has been commissioned. This plant does not consume coal.</li> </ul>			
V	Storage facility for auxiliary liquid fuel such as LDO/HFO/LSHS shall be made in the plant area in consultation with the Department of Explosives, Nagpur. Sulphur content in the liquid fuel will not exceed 0.5%. Disaster Management Plan shall be prepared to meet any eventuality in case of an accident taking place due to storage of oil.	<ul> <li>Not applicable.</li> <li>LDO/HFO/LSHS is not using for startup activities. Startup activities are being carried out by LPG or COG.</li> </ul>			
vi	First aid and sanitation arrangements shall be made for the drivers and other contract workers during construction phase.	<ul> <li>Adequate First aid and sanitation arrangements were made during construction phase of the plant and similar facilities are being maintained during operational phase also for the workers and employees.</li> </ul>			
vii	Noise level emanating from turbines shall be so controlled such that the noise in the work zone shall be limited to 85 dB(A) from the source. For people working in the high noised areas, requisite PPEs like ear plugs/ear muffs etc shall be provided. Workers engaged in noisy areas such as turbine area, air compressors etc shall be periodically examined to maintain audiometric records and for treatment for any hearing loss including shifting to non- noisy/less noisy areas.	<ul> <li>Silencers have been provided at boilers to control noise during steam venting.</li> <li>Necessary PPEs are being provided to all the workers working in noisy areas and periodic examination is being conducted for the workers engaged in noisy areas.</li> <li>Noise monitoring is carried out regularly in the work zone areas and reports are enclosed as Annexure-IV.</li> </ul>			

Tata Steel Limited, Meramandali, Dhenkanal 759121

viii	eriod from April' 2024 to September' 2024) Regular monitoring of ambient air ground level concentration of SO <sub>2</sub> , NO <sub>x</sub> , PM <sub>2.5</sub> , PM <sub>10</sub> and Hg shall be carried out in the impact zone and records maintained. If at any stage levels are found to exceed the prescribe limits, necessary control measures shall be provided immediately. The locations of the monitoring stations and frequency of monitoring shall be decided in consultation with SPCB. Periodic reports shall be submitted to the regional office of the Ministry. The data shall also be put on the website of the Company.	<ul> <li>Five ambient air quality monitoring stations have been set up in nearby villages for measuring ground level concentrations of PM10, SO2 and NOx in consultation with SPCB. Odisha. EC compliance along with all report is being uploaded on the company's website at <u>http://www.tatasteel.com.</u></li> </ul>
ix	Utilization of 100 % fly ash generated shall be made from 4 <sup>th</sup> year of operation. Status of implementation shall be reported to the Regional Office of the Ministry from time to time.	<ul> <li>Not applicable</li> <li>As Presently gas-based power plant of capacity 165 MW has been commissioned. This plant does not consume coal hence, no ash is being generated.</li> </ul>
X	Provision shall be made for the housing of contractor workers (as applicable) within the site with all necessary infrastructure facilities such as fuel for cooking, mobile toilets, mobile STP, safe drinking water, medical health care, crèche etc.	<ul> <li>Adequate arrangements of housing for construction workers were made during construction phase of the plant.</li> </ul>
xi	The project proponent shall advertise in at least two local news papers widely circulated in the region around the project, one of which shall be in the vernacular language of the locality concerned within seven days from the date of this clearance letter, informing that the project has been accorded environment clearance and copies of the clearance letters are available with the SPCB/Committee and may also be seen at website of the Ministry of Environment and Forests at http://envfor.nic.in	<ul> <li>Advertisements were circulated in The Telegraph (English daily) dated 15.02.2015 and the Samaya (Oriya daily) dated 15.02.2015.</li> <li>A copy of the same was submitted to MoEF&amp;CC vide our letter no. BSL/MoEF/BS-02/2015-09 dated 21.02.2015.</li> </ul>
xii	A copy of the clearance letter shall be sent by the proponent to concerned Panchayat, Zila Parishad / Municipal Corporation, Urban Local Body and the	<ul> <li>Copy of the environment clearance was submitted to the concerned panchayat, Zila Parishad, District Industry Centre etc.</li> </ul>

Tata Steel Limited, Meramandali, Dhenkanal 759121

Ph 06762-352000 Email id :anoop.srivastava@tatasteel.com web@tatasteel.com

(For the r	variad from Aprill 2024 to Contamber 2024	
(For the p	period from April' 2024 to September' 2024)	
	local NGO, if any, from whom	
	suggestions/representations, if any,	
	were received while processing the	
	proposal. The clearance letter shall also	
	be put on the web site of the Company	
	by the Proponent.	
xiii	The proponent shall upload the status of compliance of the stipulated environment clearance conditions, including results of measured data on their website and shall update the same periodically. It shall simultaneously be sent to the Regional Office of the MoEF, the respective zonal office of CPCB and the SPCB. The criteria pollutant levels	<ul> <li>Status of compliance of the stipulated environment clearance conditions are being uploaded on website and are being sent to the Ministry, CPCB and SPCB. Results of online air quality monitoring are displayed electronically near the main gate.</li> <li>The last half yearly compliance report was submitted vide letter no.</li> </ul>
	namely SPM, RSPM ( $PM_{10}$ and $PM_{2.5}$ ) SO <sub>2</sub> , NO <sub>x</sub> (ambient as well as stack emission) shall be displayed at a convenient location near the main gate of the Company in the public domain.	TSL/MoEF&CC/TS-26/2024-01/451 dated 29.05.2024.
xiv	The environment statement for each financial year ending 31 <sup>st</sup> March in Firm- V as is mandated to be submitted by the project proponent to the concerned SPCB as prescribed under the Environment (Protection) Rules 1986, as amended subsequently, shall also be put on the website of the Company along with the status of compliance of environment clearance conditions and shall also be sent to the respective Regional Office of the Ministry by e-mail.	<ul> <li>The environment statement in Form-V for each financial year ending 31<sup>st</sup> March is submitted to the Regional Office of the Ministry, CPCB and SPCB.</li> <li>Last environment statement was submitted vide letter no. TSL/SPCB/TS-30/2024-03/494 dated 27.09.2024</li> </ul>
XV	The project proponent shall submit six monthly reports on the status of the implementation of the stipulated environmental safeguards to the Ministry of environment and Forests, its Regional Office, CPCB and SPCB. The project proponent shall upload the status of compliance of the environmental clearance conditions on their website and update the same periodically and simultaneously send	<ul> <li>Six monthly reports on status of the implementation of the stipulated environmental safeguards are being submitted.</li> <li>Status of compliance with the environmental clearance conditions is being uploaded on the Company's website at <a href="http://www.tatasteel.com">http://www.tatasteel.com</a>.</li> </ul>

Tata Steel Limited, Meramandali, Dhenkanal 759121

Ph 06762-352000 Email id :anoop.srivastava@tatasteel.com web@tatasteel.com

(Eor the p	eriod from April' 2024 to September' 2024)	
	the same by e-mail to the Regional office	
	of MoEF.	
xvi	Regional office of the MoEF will monitor the implementation of the stipulated conditions. A complete set of documents including Environment Impact Assessment report and Environment Management Plan along with the additional information submitted from time to time shall be forwarded to the Regional Office for their use during monitoring. Project proponent will upload the compliance status in their website and update the same from time to time at least six monthly basis. Criteria pollutants levels including NOx (from stack and ambient air) shall be displayed at the main gate of the power plant.	<ul> <li>All the required documents have been already submitted to the Regional Office and will be made available during inspection.</li> <li>Compliance status is uploaded on the website and updated in every six months.</li> </ul>
xvii	Separate funds shall be allocated for implementation of environmental protection measures along with item- wise break-up. These shall be included as part of the project cost. The funds earmarked for the environment protection measures shall not be diverted for other purposes and year- wise expenditure should be reported to the Ministry.	<ul> <li>Adequate funds are being provided by the management for pollution control and to meet recurring costs. Environmental requirements are given top priority for fund allocation and approval of capital projects.</li> <li>The funds earmarked for environment pollution control measures are not diverted for any other purpose.</li> <li>The company has invested adequate capital expenditure to improve mix of clean power &amp; also reduction of carbon emissions</li> </ul>
xviii	The project authorities shall inform the Regional Office as well as the Ministry regarding the date of financial closure and final approval of the project by the project authorities and the dates of land development work and commissioning of plant.	<ul> <li>Financial closure and financial approval will be communicated to the regional office and the Ministry of MoEF&amp;CC.</li> </ul>
xix	Full cooperation shall be extended to the Scientists/Officers from the Ministry / Regional Office / CPCB / SPCB who would be monitoring the compliance on environmental status.	<ul> <li>Full cooperation is extended to the Scientists/Officers from the Ministry / Regional Office / CPCB / SPCB who would be monitoring the compliance on environmental status.</li> </ul>

(For the pe	For the period from April' 2024 to September' 2024)					
Nan	ne change in EC from M/s. Tata Steel B	SL Limited to M/s. Tata Steel Limited				
SL	ADDITIONAL CONDITION	COMPLIANCE STATUS				
I	M/s Tata Steel BSL Ltd. (new incumbent) shall submit an application for amendment in EC for switching from 50% coal & 50% mix gases from Steel plant to 100% mix gases from steel plant for stipulation of adequate conditions on pollution control measures by the Ministry.	<ul> <li>Amendment EC has been obtained for switching from 50% coal &amp; 50% mix gases from Steel plant to 100% mix gases.</li> </ul>				
	The revised emission standards and specific water consumption as per the Ministry's Notification vide S.O.33.5 dated 17.12.2015 and subsequent amendments shall be complied with. The progress of implementation of new emission standards as per the extended timelines given by CPCB vide Order dated 16.04.2018 shall be submitted as part of compliance report.	<ul> <li>The revised emission standards and specific water consumption as per the Ministry's Notification vide S.O.33.5 dated 17.12.2015 and subsequent amendments is being complied with.</li> </ul>				
	Details of quantity of water consumption, power generation and Specific water consumption shall be submitted as part of compliance report.	<ul> <li>Water consumption, power generation and specific water consumption for the period April'24 to September'24 are given below.</li> <li>Power Generation: 3273796.8 MW Average Specific water consumption: 3.00 m3/MWh (BFPP-I: 3.43 m3/MWh &amp; BFPP-II: 2.62 m3/MWh)</li> </ul>				
IV	The status of case (CC case No.16/2014) filed before Hon'ble Sub Divisional Judicial Magistrate, Dhenkanal against Shri Neeraj Singhal, M/s Bhushan Steel Ltd. shall also be communicated to the Ministry.	Case is pending for Supply of Prosecution Report.				
	Amendment Environment clear Letter no.: J-13012/77/2011-					
SL	ADDITIONAL CONDITION	COMPLIANCE STATUS				
7	PP shall submit Compliance report of Ministry Regional office within 6 months.	<ul> <li>Complied</li> <li>Certificate of compliance has already been communicated vide letter No.TSL/MoEF &amp;CC/BS-26/2022-02/202 dtd. 13.05.22.</li> </ul>				

# LIST OF ENCLOSURES

SI. No.	Enclosure	Details				
1.	Annexure - I	Water Analysis Report				
2.	Annexure - II	Hydrogeology Study				
3.	Annexure - III	CSR Report				
4.	4. Annexure – IV Ambient & Work zone Noise Rep					

### Summary of Surface Water Quality Analysis

### (Period: From April 2024 to September 2024)

S. N	Parameter	Unit	Kishinda Nala		Lingara Nala		Brahamani River	
5. N			U/S	D/S	U/S	D/S	U/S	D/S
1	pH Value	-	6.92-8.58	7.32-8.20	6.78-8.50	7.36-8.4	6.87-8.29	7.02-8.13
2	Colour	Hazen	BDL(DL:2.0)	BDL(DL:2.0)	BDL(DL:2.0)	BDL(DL:2.0)	BDL(DL:2.0)	BDL(DL:2.0)
3	Temperature	Deg C	25-25.3	25-25.2	25-25.2	25-25.2	25-25.3	25-25.0
4	Total Suspended Solids	mg/l	3.8-15.6	2.6-20.0	3.8-19	8.6-18.2	10.8-90	3.2-120
5	Arsenic as As	mg/l	BDL(DL:0.005)	BDL(DL:0.005)	BDL(DL:0.005)	BDL(DL:0.005)	BDL(DL:0.005)	BDL(DL:0.005)
6	BOD, 3days at 27°C	mg/l	2.7-5.6	2.0-5.6	BDL(DL:2.0)	5.7-6.4	2.4-9.6	3.8-13
7	Boron as B	mg/l	BDL(DL:0.25)	BDL(DL:0.25)	BDL(DL:0.25)	BDL(DL:0.25)	BDL(DL:0.25)	BDL(DL:0.25)
8	Cadmium as Cd	mg/l	BDL(DL:0.001)	BDL(DL:0.001)	BDL(DL:0.001)	BDL(DL:0.001)	BDL(DL:0.001)	BDL(DL:0.001)
9	Calcium as Ca	mg/l	34-80.8	34-80.8	13-89.0	26-64.4	12-26.0	12.12-27.0
10	Chlorides as Cl	mg/l	35-158.35	35-148.45	14-152	20-126	11-29.69	12.0-108.0
11	COD	mg/l	9.6-28	16.0-23	10.0-20	19.0-28	8.4-34	13.0-40
12	Copper (as Cu)	mg/l	BDL(DL:0.02)	BDL(DL:0.02)	BDL(DL:0.02)	BDL(DL:0.02)	BDL(DL:0.02)	BDL(DL:0.02)
13	Cyanide as CN	mg/l	BDL(DL:0.01)	BDL(DL:0.01)	BDL(DL:0.01)	BDL(DL:0.01)	BDL(DL:0.01)	BDL(DL:0.01)

14	Fluoride as F-	mg/l	0.22-2.65	0.21-1.80	0.26-0.38	0.19-1.54	0.25-0.41	0.20-0.52
15	Hexa Chromium as Cr +6	mg/l	BDL(DL:0.01)	BDL(DL:0.01)	BDL(DL:0.01)	BDL(DL:0.01)	BDL(DL:0.01)	BDL(DL:0.01)
16	Iron as Fe	mg/l	0.96-4.9	0.17-4.9	0.18-2.0	0.59-1.0	0.17-2.1	2.1-2.2
17	Lead (as Pb)	mg/l	BDL(DL:0.005)	BDL(DL:0.005)	BDL(DL:0.005)	BDL(DL:0.005)	BDL(DL:0.005)	BDL(DL:0.005)
18	Manganese (as Mn)	mg/l	BDL(DL:0.02)	BDL(DL:0.02)	BDL(DL:0.02)	BDL(DL:0.02)	BDL(DL:0.02)	BDL(DL:0.02)
19	Mercury (as Hg)	mg/l	BDL(DL:0.0002)	BDL(DL:0.0002)	BDL(DL:0.0002)	BDL(DL:0.0002)	BDL(DL:0.0002)	BDL(DL:0.0002)
20	Nickel (as Ni)	mg/l	BDL(DL:0.01)	BDL(DL:0.01)	BDL(DL:0.01)	BDL(DL:0.01)	BDL(DL:0.01)	BDL(DL:0.01)
21	O&G	mg/l	BDL(DL:1.4)	BDL(DL:1.4)	BDL(DL:1.4)	BDL(DL:1.4)	BDL(DL:1.4)	BDL(DL:1.4)
22	Phenolic Comp	mg/l	BDL(DL:0.001)	BDL(DL:0.001)	BDL(DL:0.001)	BDL(DL:0.001)	BDL(DL:0.001)	BDL(DL:0.001)
23	Phosphate as P	mg/l	0.11-0.85	0.07-0.84	0.10-0.29	0.10-0.40	0.08-0.35	0.12-0.59
24	RFC	mg/l	BDL(DL:0.1)	BDL(DL:0.1)	BDL(DL:0.1)	BDL(DL:0.1)	BDL(DL:0.1)	BDL(DL:0.1)
25	Selenium (as Se)	mg/l	BDL(DL:0.005)	BDL(DL:0.005)	BDL(DL:0.005)	BDL(DL:0.005)	BDL(DL:0.005)	BDL(DL:0.005)
26	TKN	mg/l	BDL(DL:0.3)	BDL(DL:0.3)	BDL(DL:0.3)	BDL(DL:0.3)	BDL(DL:0.3)	BDL(DL:0.3)
27	Zinc (as Zn)	mg/l	BDL(DL:0.02)	BDL(DL:0.02)	BDL(DL:0.02)	BDL(DL:0.02)	BDL(DL:0.02)	BDL(DL:0.02)

Note: BDL: Below Detectable Limit; DL: Detectable Limit, U/S: Upstream D/S: Downstream

Source: Monitoring/ Analysis report of S.K. Mitra Private Limited and Environment Laboratory of TSM.

### **Summary of Treated Domestic Effluent Analysis**

(Period: From April 2024 to September 2024)

S.N.	Location		Parameters in Rang	e	
		рН	Suspended Solid in mg/I	BOD (3 days at 27°C) in mg/l	
1.	Colony STP	7.40-7.85	23-36	9.0-10.7	
2.	AEL STP	7.04-7.81	18-28	8.7-11.3	
3.	BF-1 STP	6.91-7.85	18-32	7.8-9.8	

### Summary of Effluent Treatment Plant Analysis

(Period: From April 2024 to September 2024)

				Paramete	rs in Range		
S.N	Location	рН	Suspended Solid in mg/l	Chemical Oxygen Demand in mg/l	BOD (3days at 27°C) in mg/l	Oil & Grease	Iron as Fe
1.	ETP-1 (Outlet)	7.18-8.15	13-26	19-45	3.5-7.0	<4.0	0.27-0.72
2.	ETP-2 (Outlet)	6.53-7.88	18-24	18-30	3.3-5.2	<4.0	0.10-0.60
3.	ETP-3 (Outlet)	6.76-8.02	25-41	29-37	3.7-5.2	<4.0	0.29-0.89
4.	CRM (ETP Outlet)	7.16-8.13	18-58	100-160	14.6-24.9	<4.0	0.79-2.80
5.	BF-1 (Thickener Outlet)	6.63-7.86	35-86	33-48	4.5-9.5	<4.0	-
6.	BF-2 (Thickener Outlet)	6.69-7.58	42-76	36-47	4.4-9.5	<4.0	-
7.	BOF (Thickener Outlet)	>10.0	63-78	36-51	4.5-8.0	<4.0	-

		Parameters in Range										
S.N.	Location	рН	Suspended Solid in mg/l	Chemical Oxygen Demand in mg/l	BOD (3days at 27°C) in mg/l	Oil & Grease	TCN	Phenol				
8.	Coke Oven-1 (BOD-1 Outlet)	6.80-7.64	28-80	120-210	16.5-28.5	<4.0	0.12-0.18	0.76-0.87				
9.	Coke Oven-2 (BOD-2 Outlet)	6.77-7.23	22-41	130-180	20.1-26.8	<4.0	0.11-0.14	0.71-0.81				

### Summary of ground water level monitoring report inside plant premises

S.N.	Location with description	Sample Code	Depth of Monitoring Bore Well (m)	Longitude	Latitude	Ground Water Level (m)
1	Colony near STP	GW-1	50.29	20°49.045'	85°15.734'	4.10
2	RMHS Near Wagon Tippler	GW-2	91.44	20°47.752'	85°15.993'	2.12
3	Near Blast Furnace-2	GW-3	49.38	20°47.25'	85°15.613'	5.20
4	Near Railway bridge	GW-4	47.55	20°48.920'	85°15.858'	2.50

### (Period: From April 2024 to September 2024)

### Ground Water Quality Analysis

S.N.	Parameter	Unit	GW-2	GW-3	GW-4	GW-6	Standard as per IS-10500-2012
1	рН	-	7.55	7.21	7.80	7.76	6.50-8.50
2	Colour	Hazen	Colourless	Colourless	Colourless	Colourless	15
3	Odour	-	Agreeable	Agreeable	Agreeable	Agreeable	-
4	T. Hardness (as CaCO3)	mg/l	278	310	244	282	300
5	Calcium as Ca	mg/l	67.33	74.54	58.52	68.14	75
6	Magnesium as Mg	mg/l	26.84	30.26	23.91	27.33	30
7	Iron as Fe	mg/l	0.13	0.20	0.16	0.15	0.3
8	Chloride as Cl	mg/l	94.30	114.15	71.96	81.89	250
9	Fluoride as F-	mg/l	0.64	0.49	0.68	0.72	1
10	Dissolved solids	mg/l	344	390	298	366	500
11	Nitrate as NO3	mg/l	4.80	6.20	4.20	7.80	45
12	Chromium as Cr+6	mg/l	0.016	0.020	0.024	0.012	0.050
13	Alkalinity as CaCO3	mg/l	78	108	66	86	200

### Summary of ground water level monitoring report inside plant premises

### Ground Water Level Period: March 2024

S.N	Location	Sample Code	Longitude	Latitude	Water Level from GL (m) BGL May'24
1	Kharagprasad	GW-01	20º 49.299'	85º 18.923'	4.2
2	Charadagadia	GW-02	20º 47.768'	85º 17.083'	7.5
3	Sibpur	GW-03	20º 46.941'	85º 14.394'	6.8
4	Kochilamada	GW-04	20º 47.541'	85º 16.802'	5.9
5	Galapada	GW-05	20º 48.142'	85º 18.600'	4.7
6	Motonga	GW-06	20º 48.143'	85º 18.599'	4.1
7	Narendrapur	GW-08	20º 49.483'	85º 15.530'	9.2
8	Khaliberena	GW-09	20º 46.946'	85º 14.396'	4.6
9	Ganthigadia	GW-10	20º 48.501'	85º 15.118'	2.2

### Ground Water Quality Analysis Report of surrounding villages

### March 2024

S.N.	Parameters	unit	GW-01	GW-02	GW-03	GW-04	GW-05	GW-06	GW-07	GW-08	GW-9
1	рН	-	6.76	7.11	7.59	7.16	7.05	7.29	7.52	7.57	7.54
2	Odour	-	Agreeable								
3	Colour	mg/l	BDL(DL:2.0)								
4	Turbidity	N.T. U	3.45	1.70	2.70	0.75	1.19	1.66	7.75	1.10	4.71
5	Total Dissolved Solids (as TDS)	mg/l	277	1268	493	503	186.0	7.29	565	484	591
6	Aluminium as Al	mg/l	BDL(DL:0.01)								
7	Anionic Surface- Active Agents as (MBAS)	mg/l	BDL(DL:0.05)								
8	Boron as B	mg/l	BDL(DL:0.25)								
9	Calcium as Ca	mg/l	40.08	35.27	80.16	52.91	32.06	89.78	16.03	83.37	83.37
10	Chloride as Cl	mg/l	29.0	240.0	57.0	50.0	15.00	118.0	45.0	40.0	47.0
11	Copper as Cu	mg/l	0.012	0.007	0.014	0.011	0.032	0.005	0.008	0.018	0.013
12	Fluoride as F	mg/l	0.12	0.98	0.46	1.10	0.19	1.00	0.94	0.55	1.10
13	Residual Free Chlorine	mg/l	BDL(DL:0.1)								
14	Iron as Fe	mg/l	0.228	0.125	0.157	0.238	0.989	0.153	0.172	0.339	0.301
15	Magnesium as Mg	mg/l	14.58	126.62	32.08	44.71	5.83	99.14	69.01	39.85	55.40
16	Manganese as Mn	mg/l	0.025	0.032	0.086	0.027	0.077	0.060	0.354	0.027	0.028
17	Mineral Oil	mg/l	BDL(DL:0.5)								
18	Nitrate as NO3	mg/l	12.30	182.0	3.76	49.60	3.12	12.10	10.63	3.58	17.20
19	Phenolic Compounds as C6H5OH	mg/l	BDL (DL:0.001)								
20	Selenium as Se	mg/l	BDL (DL:0.005)								
21	Sulphate as SO4	mg/l	30.67	125.41	63.39	57.25	13.61	129.96	62.25	47.26	82.02
22	Total Alkalinity as CaCO3	mg/l	140	484	304	392	96	320	376	364	413
23	Total Hardness	mg/l	160	608	332	316	104	632	324	372	436

	as CaCO3										
24	Zinc as Zn	mg/l	0.057	0.079	0.084	0.073	0.227	0.064	0.064	0.089	0.108
25	Cadmium as Cd	mg/l	BDL(DL:0.01)								
26	Cyanide as CN	mg/l	BDL(DL:0.01)								
27	Lead as Pb	mg/l	BDL (DL:0.005)								
28	Mercury as Hg	mg/l	BDL (DL:0.0002)								
29	Nickel (as Ni)	mg/l	BDL(DL:0.01)								
30	Total Arsenic (as As)	mg/l	BDL (DL:0.005)								
31	E. coli	/100ml	Not Detected	Not Detected	Not Detected	Detected	Not Detected	Not Detected	Not Detected	Not Detected	Not Detected

### August 2024

S.N.	Parameters	unit	GW-01	GW-02	GW-03	GW-04	GW-05	GW-06	GW-07	GW-08	GW-9	
1	рН	-	7.98	7.85	8.12	8.06	7.85	8.23	7.9	7.9	7.93	
2	Odour	-	Agreeable									
3	Colour	mg/l	BDL(DL:2.0)									
4	Turbidity	N.T. U	BDL(DL:1.0)									
5	Total Dissolved Solids (as TDS)	mg/l	528	814	1865	932	924	544	942	652	1012	
6	Aluminium as Al	mg/l	0.28	BDL(DL:0.01)								
7	Anionic Surface- Active Agents as (MBAS)	mg/l	BDL(DL:0.05)									
8	Boron as B	mg/l	BDL(DL:0.25)									
9	Calcium as Ca	mg/l	51	51	29	58	47	54	54	22.4	86	
10	Chloride as Cl	mg/l	67	116	297	68	116	59	118	14	164	
11	Copper as Cu	mg/l	BDL(DL:0.02)									
12	Fluoride as F	mg/l	BDL(DL:0.1)									
13	Residual Free Chlorine	mg/l	BDL(DL:0.1)									
14	Iron as Fe	mg/l	BDL(DL:0.05)									
15	Magnesium as Mg	mg/l	40.9	39.5	25.3	41.5	27.5	34.8	37.2	37.4	69.4	
16	Manganese as	mg/l	BDL(DL:0.02)									

	Mn										
17	Mineral Oil	mg/l	BDL(DL:0.5)								
18	Nitrate as NO3	mg/l	31.4	BDL(DL:0.2)	BDL(DL:0.2)	32.6	BDL(DL:0.2)	11.6	8.9	25.6	12.4
19	Phenolic Compounds as C6H5OH	mg/l	BDL (DL:0.001)								
20	Selenium as Se	mg/l	BDL (DL:0.005)								
21	Sulphate as SO4	mg/l	87	65	142	54	59	27	97	52	88
22	Total Alkalinity as CaCO3	mg/l	270	356	749	272	360	372	349	437	312
23	Total Hardness as CaCO3	mg/l	298	292	178	318	232	280	290	212	504
24	Zinc as Zn	mg/l	BDL(DL:0.02)								
25	Cadmium as Cd	mg/l	BDL(DL:0.01)								
26	Cyanide as CN	mg/l	BDL(DL:0.02)								
27	Lead as Pb	mg/l	BDL(DL:0.01)								
28	Mercury as Hg	mg/l	BDL (DL:0.0002)								
29	Nickel (as Ni)	mg/l	BDL(DL:0.01)								
30	Total Arsenic (as As)	mg/l	BDL (DL:0.005)								
31	E. coli	/100ml	Detected	Detected	Detected	Detected	Detected	Not Detected	Not Detected	Detected	Detected

----- End of Report -----



(A Govt. of India Autonomous Body) Environmental Chemical Laboratory Bhubaneswar, Odisha TEST REPORT



# Issued to :TATA STEEL LIMITED, MERAMANDALIDate : 23.09.2024Test report No - 08/2024-007Source of Sample : CharadagadiaSample receiving Date : 09.08.2024

Type of Sample : well water

Sample Analysis Date : 09.08.2024

SI	Characteristics	Test Method	Requirements as p	er IS 10500:2012(Latest	Test Result
No		(P)of IS:3025	v	ersion)	
			Acceptable limit	Permissible Limit	-
1.	Turbidity, NTU	Part 10	1	5	0.78
2.	pH@Temp° C	Part 11	6.5-8.5	No relaxation	6.96@25.0
3.	Total Dissolved Solids mg/L	Part 16	500	2000	1241.0
4.	Total Hardness (as CaCO <sub>3</sub> ),mg/L	Part 21	200	600	604.0
5.	Calcium as Ca, mg/L	Part 40	75	200	36.07
6.	Magnesium as Mg, mg/L	Part 46	30	100	124.9
7.	Alkalinity as CaCO <sub>3</sub> , mg/L	Part 23	200	600	456.0
8.	Chloride as CI, mg/L	Part 32	250	1000	180.0
9.	Sulfate as SO <sub>4</sub> , mg/L	Part 24	200	400	138.13
10.	Fluoride as F, mg/L	Part 60	1.0	1.5	0.72
11.	Iron as Fe, mg/L	Part 53	0.3	No relaxation	0.168
12.	Copper as Cu, mg/L	Part 42	0.05	1.5	0.031
13.	Manganese as Mn, mg/L	APHA(PART 3111B)	0.1	0.3	0.009
14.	Zinc as Zn, mg/L	Part 49	5.0	15.0	0.107
15.	Lead as Pb, mg/L	Part 47	0.01	No relaxation	< 0.001
16.	Cadmium as Cd, mg/L	Part 41	0.003	No relaxation	< 0.001
17.	Chromium as Cr, mg/L	Part 52	0.05	No relaxation	< 0.001
18.	Nickel as Ni, mg/l	Part 54	0.02	No relaxation	<0.001

Authorized Signatory

#### Dr. Arakshita Majhi

Senior Principal Scientist Phone : 0674-2379236, E mail - arakshita@immt.res.in

NOTES :

- 1. The sample is drawn by EC Laboratory & result relates to the sample tested.
- 2. This certificate shall not be reproduced wholly or in part without prior written consent of the laboratory.
- 3. This certificate shall not be used in any advertising media or as evidence in the court of Law without prior written consent of laboratory.
- Latest version of test methods used as per latest specification.
- 5. It is recommended that the acceptable limit is to be implemented. Values in excess of those mentioned in "acceptable limit" render the water not suitable, but still may be tolerated in the absence of an alternative source but up to the limits indicate under "permissible limit" in the absence of alternative sources, above which the source will have to be rejected.

Non NABL Test report – P.T.O

'End of Test Report'

1of 2

Laboratory: Acharya Vihar, Bhubaneswar, Odisha-751013. Tel: 0674-2379236, Mobile: 9760387460.

E-mail: dir@immt.res.in.



#### (A Govt. of India Autonomous Body) **Environmental Chemical Laboratory** Bhubaneswar, Odisha **TEST REPORT**

Issued to : TATA STEEL LIMITED, MERAMANDALI	Date : 23	.09.2024
Test report No - 08/2024-007		<u> </u>
Source of Sample : Charadagadia	Sample receiving Date :	09.08.2024

Тур	e of Sample : well water	Sample Analy	Sample Analysis Date : 09.08.2024			
19.	*Color, Hazen units	Part 4	5	15	<5	
20.	*Odour	Part 5	Agreeable	Agreeable	Agreeable	
21.	*Conductivity, µs/cm	Part 14	-	-	1804	
22.	*Total Suspended Solid, mg/l	Part 17	-	-	7.0	
23.	*Nitrite as NO <sub>2</sub> ,mg/L	Part 34	-	-	0.618	
24.	*Nitrate as NO <sub>3</sub> , mg/L	Part 34	45	No relaxation	162.0	
25.	Sodium, mg/l	Part 45	-	-	167.95	
26.	Potassium, mg/l	Part 45		-	5.55	
27.	Residual Free Chlorine, mg/l	Part 26	0.2	1.0	<0.1	
28.	Arsenic as As, mg/l	Part 37	0.01	No relaxation	<0.001	
29.	Total Coliform by MPN	IS 1622 RA 2019	Shall not be detectable in 100ml sample	No relaxation	>542	
30.	Fecal Coliform by MPN	IS 1622 RA 2019	Shall not be detectable in 100ml sample	No relaxation	>542	

Authorized Signatory

Sanci Frucil -Car Panke 2

Dr. Arakshita Majhi Senior Principal Scientist

Phone: 0674-2379236,

E mail - arakshita@immt.res.in

#### **NOTES:**

1. The sample is drawn by EC Laboratory & result relates to the sample tested.

.11

2. This certificate shall not be reproduced wholly or in part without prior written consent of the laboratory.

1 22

- 3. This certificate shall not be used in any advertising media or as evidence in the court of Law without prior written consent of laboratory.
- 4. Latest version of test methods used as per latest specification.
- 5. It is recommended that the acceptable limit is to be implemented. Values in excess of those mentioned in "acceptable limit" render the water not suitable, but still may be tolerated in the absence of an alternative source but up to the limits indicate under "permissible limit" in the absence of alternative sources, above which the source will have to be rejected.
- 6. Testing parameters which are not set limitation has marked as "-".

'End of Test Report'

2of 2 Laboratory: Acharya Vihar, Bhubaneswar, Odisha-751013. Tel: 0674-2379236, Mobile: 9760387460. E-mail: dir@immt.res.in.



(A Govt. of India Autonomous Body) Environmental Chemical Laboratory Bhubaneswar, Odisha TEST REPORT

#### Issued to : TATA STEEL LIMITED, MERAMANDALI

Date: 23.09.2024

#### Test report No - 08/2024-012

Sou	Irce of Sample : ETAPA	Sample recei	ving Date : 09	.08.2024	
Тур	e of Sample : Well water	Sample Anal	Sample Analysis Date : 09.08.2024		
19.	*Color, Hazen units	Part 4	5	15	10
20,	*Odour	Part 5	Agreeable	Agreeable.	Agreeable
21.	*Conductivity, µs/cm	Part 14		-	1123
22.	*Total Suspended Solid, mg/l	Part 17	-	-	12.0
23.	*Nitrite as NO <sub>2</sub> ,mg/L	Part 34	-	-	0.091
24.	*Nitrate as NO <sub>3</sub> , mg/L	Part 34	45	No relaxation	4.62
25.	Sodium, mg/l	Part 45	-	-	141.75
26.	Potassium, mg/l	Part 45	-	-	11.35
27.	Residual Free Chlorine, mg/l	Part 26	0.2	1.0	<0.1
28.	Arsenic as As, mg/l	Part 37	0.01	No relaxation	<0.001
29.	Total Coliform by MPN	IS 1622 RA 2019	Shall not be detectable in 100ml sample	No relaxation	212
30.	Fecal Coliform by MPN	IS 1622 RA 2019	Shall not be detectable in 100ml sample	No relaxation	9

Authorized Signatory

Dr. Arakshita Majhi

Senior Principal Scientist

Phone: 0674-2379236,

E mail - arakshita@immt.res.in

#### NOTES :

- 1. The sample is drawn by EC Laboratory & result relates to the sample tested.
- 2. This certificate shall not be reproduced wholly or in part without prior written consent of the laboratory.
- This certificate shall not be used in any advertising media or as evidence in the court of Law without prior written consent of laboratory.
- 4. Latest version of test methods used as per latest specification.
- 5. It is recommended that the acceptable limit is to be implemented. Values in excess of those mentioned in "acceptable limit" render the water not suitable, but still may be tolerated in the absence of an alternative source but up to the limits indicate under "permissible limit" in the absence of alternative sources, above which the source will have to be rejected.
- 6. Testing parameters which are not set limitation has marked as "-".

'End of Test Report'

**2of 2** Laboratory: Acharya Vihar, Bhubaneswar, Odisha-751013. Tel: 0674-2379236, Mobile: 9760387460. E-mail: dir@immt.res.in.



(A Govt. of India Autonomous Body) Environmental Chemical Laboratory Bhubaneswar, Odisha TEST REPORT



Date: 23.09.2024

### Issued to : TATA STEEL LIMITED, MERAMANDALI

### Test report No - 08/2024-012

Source of Sample : ETAPA	Sample receiving Date: 09.08.202		
Type of Sample : Well water	Sample Analysis Date :	09.08.2024	

SI No	Characteristics	Test Method (P)of IS:3025	Requirements as per IS 10500:2012(Latest Version)		Test Result
			Acceptable limit	Permissible Limit	
1.	Turbidity, NTU	Part 10	1	5	14.82
2.	pH@Temp° C	Part 11	6.5-8.5	No relaxation	7.13@25.0
3.	Total Dissolved Solids mg/L	Part 16	500	2000	655.0
4.	Total Hardness (as CaCO <sub>3</sub> ),mg/L	Part 21	200	600	284.0
5.	Calcium as Ca, mg/L	Part 40	75	200	8.01
6.	Magnesium as Mg, mg/L	Part 46	30	100	64.15
7.	Alkalinity as CaCO <sub>3</sub> , mg/L	Part 23	200	600	416.0
8.	Chloride as Cl, mg/L	Part 32	250	1000	92.0
9.	Sulfate as SO <sub>4</sub> , mg/L	Part 24	200	400	1.42
10.	Fluoride as F, mg/L	Part 60	1.0	1.5	1.02
11.	Iron as Fe, mg/L	Part 53	0.3	No relaxation	0.285
12.	Copper as Cu, mg/L	Part 42	0.05	1.5	0.029
13.	Manganese as Mn, mg/L	APHA(PART 3111B)	0.1	0.3	0.479
14.	Zinc as Zn, mg/L	Part 49	5.0	15.0	0.224
15.	Lead as Pb, mg/L	Part 47	0.01	No relaxation	< 0.001
16.	Cadmium as Cd, mg/L	Part 41	0.003	No relaxation	< 0.001
17.	Chromium as Cr, mg/L	Part 52	0.05	No relaxation	< 0.001
18.	Nickel as Ni, mg/l	Part 54	0.02	No relaxation	<0.001

Authorized Signatory



#### Dr. Arakshita Majhi Senior Principal Scientist

Phone : 0674-2379236,

E mail - arakshita@immt.res.in

NOTES :

- 1. The sample is drawn by EC Laboratory & result relates to the sample tested.
- 2. This certificate shall not be reproduced wholly or in part without prior written consent of the laboratory.
- 3. This certificate shall not be used in any advertising media or as evidence in the court of Law without prior written consent of laboratory.
- 4. Latest version of test methods used as per latest specification.
- 5. It is recommended that the acceptable limit is to be implemented. Values in excess of those mentioned in "acceptable limit" render the water not suitable, but still may be tolerated in the absence of an alternative source but up to the limits indicate under "permissible limit" in the absence of alternative sources, above which the source will have to be rejected.

Non NABL Test report – P.T.O

'End of Test Report'

1of 2

Laboratory: Acharya Vihar, Bhubaneswar, Odisha-751013. Tel: 0674-2379236, Mobile: 9760387460. E-mail: dir@immt.res.in.



(A Govt. of India Autonomous Body) **Environmental Chemical Laboratory** Bhubaneswar, Odisha TEST REPORT



#### issued to : TATA STEEL LIMITED, MERAMANDALI

Date: 23.09.2024

#### Test report No - 08/2024-011

Source of Sample : GALPADA	Sample receiving Date :	09.08.2024
Type of Sample : Well water	Sample Analysis Date :	09.08.2024

SI No	Characteristics	Test Method (P)of IS:3025	Requirements as per IS 10500:2012(Latest Version)		Test Result
			Acceptable limit	Permissible Limit	-
1.	Turbidity, NTU	, Part 10	1	5	0.59
2.	pH@Temp° C	Part 11	6.5-8.5	No relaxation	6.88@25.0
3.	Total Dissolved Solids mg/L	Part 16	500	2000	252.0
4.	Total Hardness (as CaCO <sub>3</sub> ),mg/L	Part 21	200	600	166.0
5.	Calcium as Ca, mg/L	Part 40	75	200	54.51
6.	Magnesium as Mg, mg/L	Part 46	30	100	7.29
7.	Alkalinity as CaCO <sub>3</sub> , mg/L	Part 23	200	600	158.0
8.	Chloride as Cl, mg/L	Part 32	250	1000	22.0
9.	Sulfate as SO <sub>4</sub> , mg/L	Part 24	200	400	21.26
10.	Fluoride as F, mg/L	Part 60	1.0	1.5	0.22
11.	Iron as Fe, mg/L	Part 53	0.3	No relaxation	0.29
12.	Copper as Cu, mg/L	Part 42	0.05	1.5	0.025
13.	Manganese as Mn, mg/L	APHA(PART 3111B)	0.1	0.3	0.048
14.	Zinc as Zn, mg/L	Part 49	5.0	15.0	0.096
15.	Lead as Pb, mg/L	Part 47	0.01	No relaxation	< 0.001
16.	Cadmium as Cd, mg/L	Part 41	0.003	No relaxation	<0.001
17.	Chromium as Cr, mg/L	Part 52	0.05	No relaxation	< 0.001
18.	Nickel as Ni, mg/l	Part 54	0.02	No relaxation	< 0.001

Authorized Signatory

23.09

### Dr. Arakshita Majhi

Senior Principal Scientist

Phone: 0674-2379236,

E mail - arakshita@immt.res.in

NOTES :

- The sample is drawn by EC Laboratory & result relates to the sample tested. 1.
- This certificate shall not be reproduced wholly or in part without prior written consent of the laboratory. 2

niol

n Jbr

Burn

L. d' Yor

3. This certificate shall not be used in any advertising media or as evidence in the court of Law without prior written consent of laboratory.

1 mai-101010

- 4. Latest version of test methods used as per latest specification.
- 5. It is recommended that the acceptable limit is to be implemented. Values in excess of those mentioned in "acceptable limit" render the water not suitable, but still may be tolerated in the absence of an alternative source but up to the limits indicate under "permissible limit" in the absence of alternative sources, above which the source will have to be rejected.

Non NABL Test report – P.T.O

1of 2

'End of Test Report'

Laboratory: Acharya Vihar, Bhubaneswar, Odisha-751013. Tel: 0674-2379236, Mobile: 9760387460. E-mail: dir@immt.res.in.



(A Govt. of India Autonomous Body) Environmental Chemical Laboratory Bhubaneswar, Odisha TEST REPORT

Issued to : TATA STEEL LIMITED, MERAMANDALI	Date : 23.09.2024
Test report No - 08/2024-011	
Source of Sample : GALPADA	Sample receiving Date : 09.08.2024

19.	*Color, Hazen units	Part 4	5	15	<5
20.	*Odour	Part 5	Agreeable	Agreeable	Agreeable
21.	*Conductivity, µs/cm	Part 14	-	-	389
22.	*Total Suspended Solid, mg/l	Part 17	-	-	3.0
23.	*Nitrite as NO <sub>2</sub> ,mg/L	Part 34	-	-	0.031
24.	*Nitrate as NO <sub>3</sub> , mg/L	Part 34	45	No relaxation	2.65
25.	Sodium, mg/l	Part 45		-	15.09
26.	Potassium, mg/l	Part 45	-	-	0.70
27.	Residual Free Chlorine, mg/l	Part 26	0.2	1.0	<0.1
28.	Arsenic as As, mg/l	Part 37	0.01	No relaxation	<0.001
29.	Total Coliform by MPN	IS 1622 RA 2019	Shall not be detectable in 100ml sample	No relaxation	>542
30.	Fecal Coliform by MPN	IS 1622 RA 2019	Shall not be detectable in 100ml sample	No relaxation	5

Authorized Signatory

Dr. Arakshita Majhi

Senior Principal Scientist Phone : 0674-2379236, ( E mail - <u>arakshita@immt.res.in</u>

#### **NOTES:**

1. The sample is drawn by EC Laboratory & result relates to the sample tested.

fiv.

11: 21-

- 2. This certificate shall not be reproduced wholly or in part without prior written consent of the laboratory.
- 3. This certificate shall not be used in any advertising media or as evidence in the court of Law without prior written consent of laboratory.
- 4. Latest version of test methods used as per latest specification.
- 5. It is recommended that the acceptable limit is to be implemented. Values in excess of those mentioned in "acceptable limit" render the water not suitable, but still may be tolerated in the absence of an alternative source but up to the limits indicate under "permissible limit" in the absence of alternative sources, above which the source will have to be rejected.
- 6. Testing parameters which are not set limitation has marked as "-".

'End of Test Report'

**2of 2** Laboratory: Acharya Vihar, Bhubaneswar, Odisha-751013. Tel: 0674-2379236, Mobile: 9760387460. E-mail: dir@immt.res.in.



(A Govt. of India Autonomous Body) Environmental Chemical Laboratory Bhubaneswar, Odisha TEST REPORT



#### Issued to : TATA STEEL LIMITED, MERAMANDALI Date: 23.09.2024 Test report No - 08/2024-003 Source of Sample : Ganthigadia Sample receiving Date : 09.08.2024 Type of Sample : Well water Sample Analysis Date : 09.08.2024

SI No	Characteristics	Test Method (P)of IS:3025	Requirements as per IS 10500:2012(Latest Version)		Test Result
NU		(F)0115:5025	Acceptable limit	Permissible Limit	-
1.	Turbidity, NTU	Part 10	1	5	2.43
2.	pH@Temp° C	Part 11	6.5-8.5	No relaxation	7.60@25.0
3.	Total Dissolved Solids mg/L	Part 16	500	2000	473.0
4.	Total Hardness (as CaCO <sub>3</sub> ),mg/L	Part 21	200	600	324.0
5.	Calcium as Ca, mg/L	Part 40	75	200	36.87
6.	Magnesium as Mg, mg/L	Part 46	30	100	56.38
7.	Alkalinity as CaCO <sub>3</sub> , mg/L	Part 23	200	600	240.0
8.	Chloride as Cl, mg/L	Part 32	250	1000	40.0
9.	Sulfate as SO <sub>4</sub> , mg/L	Part 24	200	400	115.7
10.	Fluoride as F, mg/L	Part 60	1.0	1.5	0.95
11.	Iron as Fe, mg/L	Part 53	0.3	No relaxation	0.090
12.	Copper as Cu, mg/L	Part 42	0.05	1.5	0.029
13.	Manganese as Mn, mg/L	APHA(PART 3111B)	0.1	0.3	0.018
14.	Zinc as Zn, mg/L	Part 49	5.0	15.0	0.117
15.	Lead as Pb, mg/L	Part 47	0.01	No relaxation	<0.001
16.	Cadmium as Cd, mg/L	Part 41	0.003	No relaxation	<0.001
17.	Chromium as Cr, mg/L	Part 52	0.05	No relaxation	<0.001
18.	Nickel as Ni, mg/l	Part 54	0.02	No relaxation	<0.001

Authorized Signatory

Dr. Arakshita Majhi

Senior Principal Scientiste

Phone: 0674-2379236.

E mail - arakshita@immt.res.in

#### NOTES :

- The sample is drawn by EC Laboratory & result relates to the sample tested. 1.
- This certificate shall not be reproduced wholly or in part without prior written consent of the laboratory. 2.
- 3. This certificate shall not be used in any advertising media or as evidence in the court of Law without prior written consent of laboratory.
- 4. Latest version of test methods used as per latest specification.
- 5. It is recommended that the acceptable limit is to be implemented. Values in excess of those mentioned in "acceptable limit" render the water not suitable, but still may be tolerated in the absence of an alternative source but up to the limits indicate under "permissible limit" in the absence of alternative sources, above which the source will have to be rejected.

Non NABL Test report – P.T.O

'End of Test Report'

1of 2 Laboratory: Acharya Vihar, Bhubaneswar, Odisha-751013. Tel: 0674-2379236, Mobile: 9760387460. E-mail: dir@immt.res.in.



#### (A Govt. of India Autonomous Body) Environmental Chemical Laboratory Bhubaneswar, Odisha TEST REPORT

lss	ued to : TATA STEEL LIMIT	ED, MERAMANDA	Li	Date : 23.09.	2024		
Tes	st report No - 08/2024-003						
So	urce of Sample : Ganthigadia	3	Sample rece	iving Date : 09	9.08.2024		
Ту	pe of Sample : Well water		Sample Anal	ysis Date : 0	9.08.2024		
19.	*Color, Hazen units	Part 4	5	15	<5		
20.	*Odour	Part 5	Agreeable	Agreeable	Agreeable		
21.	*Conductivity, µs/cm	Part 14	-	-	773		
2.	*Total Suspended Solid, mg/l	Part 17	-	-	8.0		
3.	*Nitrite as NO <sub>2</sub> ,mg/L	Part 34	-	-	0.247		
4.	*Nitrate as NO <sub>3</sub> , mg/L	Part 34	45	No relaxation	40.5		
5.	Sodium, mg/l	Part 45	-	-	29.15		
6.	Potassium, mg/l	Part 45		-	18.66		
7.	Residual Free Chlorine, mg/l	Part 26	0.2	1.0	<0.1		
8.	Arsenic as As, mg/l	Part 37	0.01	No relaxation	<0.001		
9.	Total Coliform by MPN	IS 1622 RA 2019	Shall not be detectable in 100ml sample	No relaxation	>542		
0.	Fecal Coliform by MPN	IS 1622 RA 2019	Shall not be detectable in 100ml sample	No relaxation	21		

Authorized Signatory

Dr. Arakshita Majhi

Senior Principal Scientist:

Phone : 0674-2379236,

E mail - arakshita@immt.res.in

NOTES :

- 1. The sample is drawn by EC Laboratory & result relates to the sample tested.
- 2. This certificate shall not be reproduced wholly or in part without prior written consent of the laboratory.
- 3. This certificate shall not be used in any advertising media or as evidence in the court of Law without prior written consent of laboratory.
- 4. Latest version of test methods used as per latest specification.
- 5. It is recommended that the acceptable limit is to be implemented. Values in excess of those mentioned in "acceptable limit" render the water not suitable, but still may be tolerated in the absence of an alternative source but up to the limits indicate under "permissible limit" in the absence of alternative sources, above which the source will have to be rejected.
- 6. Testing parameters which are not set limitation has marked as "-".

'End of Test Report'



#### (A Govt. of India Autonomous Body) **Environmental Chemical Laboratory** Bhubaneswar, Odisha TEST REPORT

	ued to : TATA STEEL LIMIT st report No – 08/2024-004	Date : 23.09.2	2024		
Soi	Irce of Sample : Khaliberena		Sample recei	ving Date : 09	.08.2024
Type of Sample : Well water Sample				ysis Date : 09	.08.2024
19.	*Color, Hazen units	Part 4	5	15	<5
20.	*Odour	Part 5	Agreeable	Agreeable	Agreeable
21.	*Conductivity, µs/cm	Part 14	-	-	481
22.	*Total Suspended Solid, mg/l	Part 17		-	5.0
23.	*Nitrite as NO2,mg/L	Part 34	-	-	0.037
24.	*Nitrate as NO <sub>3</sub> , mg/L	Part 34	45	No relaxation	5.65
25.	Sodium, mg/l	Part 45	-	-	15.12
26.	Potassium, mg/l	Part 45	-	-	3.43
27.	Residual Free Chlorine, mg/l	Part 26	0.2	1.0	<0.1
28.	Arsenic as As, mg/l	Part 37	0.01	No relaxation	<0.001
29.	Total Coliform by MPN	IS 1622 RA 2019	Shall not be detectable in 100ml sample	No relaxation	>542
30.	Fecal Coliform by MPN	IS 1622 RA 2019	Shall not be detectable in 100ml sample	No relaxation	348

Authorized Signatory

Dr. Arakshitu winifel Senior Principal Scientist Environmental Chemical Lab) (ISC 7025:2017, Mar. Li Environmental & Sustainability Jack. Environmental & Sustainability Jack. Senior Principal Scientist Phone : 0674-2379236 E mail

E mail - arakshita@immt.res.in

NOTES:

- 1. The sample is drawn by EC Laboratory & result relates to the sample tested.
- 2. This certificate shall not be reproduced wholly or in part without prior written consent of the laboratory.
- 3 This certificate shall not be used in any advertising media or as evidence in the court of Law without prior written consent of laboratory.
- 4. Latest version of test methods used as per latest specification.
- 5. It is recommended that the acceptable limit is to be implemented. Values in excess of those mentioned in "acceptable limit" render the water not suitable, but still may be tolerated in the absence of an alternative source but up to the limits indicate under "permissible limit" in the absence of alternative sources, above which the source will have to be rejected.
- 6. Testing parameters which are not set limitation has marked as "-".

'End of Test Report'



(A Govt. of India Autonomous Body) **Environmental Chemical Laboratory** Bhubaneswar, Odisha TEST REPORT



#### Issued to : TATA STEEL LIMITED, MERAMANDALI

#### Date: 23.09.2024

#### Test report No - 08/2024-004

Source of Sample : Khaliberena	Sample receiving Date :	09.08.2024	
Type of Sample : Well water	Sample Analysis Date :	09.08.2024	

SI No	Characteristics	Test Method (P)of IS:3025	Requirements as p V	Test Result	
			Acceptable limit	Permissible Limit	-
1.	Turbidity, NTU	Part 10	1	5	1.17
2.	pH@Temp° C	Part 11	6.5-8.5	No relaxation	7.22@25.0
3.	Total Dissolved Solids mg/L	Part 16	500	2000	267.0
4.	Total Hardness (as CaCO <sub>3</sub> ),mg/L	Part 21	200	600	176.0
5.	Calcium as Ca, mg/L	Part 40	75	200	14.43
6.	Magnesium as Mg, mg/L	Part 46	30	100	34.02
7.	Alkalinity as CaCO <sub>3</sub> , mg/L	Part 23	200	600	200.0
8.	Chloride as Cl, mg/L	Part 32	250	1000	18.0
9.	Sulfate as SO <sub>4</sub> , mg/L	Part 24	200	400	35.98
10.	Fluoride as F, mg/L	Part 60	1.0	1.5	0.59
11.	Iron as Fe, mg/L	Part 53	0.3	No relaxation	0.053
12.	Copper as Cu, mg/L	Part 42	0.05	1.5	0.049
13.	Manganese as Mn, mg/L	APHA(PART 3111B)	0.1	0.3	0.013
14.	Zinc as Zn, mg/L	Part 49	5.0	15.0	0.128
15.	Lead as Pb, mg/L	Part 47	0.01	No relaxation	<0.001
16.	Cadmium as Cd, mg/L	Part 41	0.003	No relaxation	<0.001
17.	Chromium as Cr, mg/L	Part 52	0.05	No relaxation	<0.001
18.	Nickel as Ni, mg/l	Part 54	0.02	No relaxation	<0.001

**Authorized Signatory** 

#### Dr. Arakshita Maihi

Senior Principal Scientist

Phone: 0674-2379236.

E mail - arakshita@immt.res.in

#### NOTES :

- 1. The sample is drawn by EC Laboratory & result relates to the sample tested.
- 2. This certificate shall not be reproduced wholly or in part without prior written consent of the laboratory.
- This certificate shall not be used in any advertising media or as evidence in the court of Law without prior written 3. consent of laboratory.
- 4. Latest version of test methods used as per latest specification.
- 5. It is recommended that the acceptable limit is to be implemented. Values in excess of those mentioned in "acceptable limit" render the water not suitable, but still may be tolerated in the absence of an alternative source but up to the limits indicate under "permissible limit" in the absence of alternative sources, above which the source will have to be rejected.

Non NABL Test report - P.T.O

'End of Test Report'

Laboratory: Acharya Vihar, Bhubaneswar, Odisha-751013. Tel: 0674-2379236, Mobile: 9760387460. E-mail: dir@immt.res.in.



(A Govt. of India Autonomous Body) Environmental Chemical Laboratory Bhubaneswar, Odisha TEST REPORT



### Issued to : TATA STEEL LIMITED, MERAMANDALI

#### Date : 23.09.2024

#### Test report No - 08/2024-009

Source of Sample : KHARAGPRASAD	Sample receiving Date :	09.08.2024	
Type of Sample : Well water	Sample Analysis Date :	09.08.2024	

SI No	Characteristics	Test Method (P)of IS:3025	Requirements as p V	Test Result	
			Acceptable limit	Permissible Limit	
1.	Turbidity, NTU	Part 10	1	5	0.56
2.	pH@Temp° C	Part 11	6.5-8.5	No relaxation	6.46@25.0
3.	Total Dissolved Solids mg/L	Part 16	500	2000	258.0
4.	Total Hardness (as CaCO <sub>3</sub> ),mg/L	Part 21	200	600	168.0
5.	Calcium as Ca, mg/L	Part 40	75	200	46.49
6.	Magnesium as Mg, mg/L	Part 46	30	100	12.64
7.	Alkalinity as CaCO <sub>3</sub> , mg/L	Part 23	200	600	140.0
8.	Chloride as Cl, mg/L	Part 32	250	1000	30.0
9.	Sulfate as SO <sub>4</sub> , mg/L	Part 24	200	400	29.19
10.	Fluoride as F, mg/L	Part 60	1.0	1.5	0.21
11.	Iron as Fe, mg/L	Part 53	0.3	No relaxation	0.065
12.	Copper as Cu, mg/L	Part 42	0.05	1.5	0.031
13.	Manganese as Mn, mg/L	APHA(PART 3111B)	0.1	0.3	0.019
14.	Zinc as Zn, mg/L	Part 49	5.0	15.0	0.199
15.	Lead as Pb, mg/L	Part 47	0.01	No relaxation	< 0.001
16.	Cadmium as Cd, mg/L	Part 41	0.003	No relaxation	< 0.001
17.	Chromium as Cr, mg/L	Part 52	0.05	No relaxation	<0.001
18.	Nickel as Ni, mg/l	Part 54	0.02	No relaxation	<0.001

Authorized Signatory

10

Dr. Arakshita Maihi

Senior Principal Scientist

Phone : 0674-2379236,

E mail - arakshita@immt.res.in

NOTES :

- 1. The sample is drawn by EC Laboratory & result relates to the sample tested.
- 2. This certificate shall not be reproduced wholly or in part without prior written consent of the laboratory.
- 3. This certificate shall not be used in any advertising media or as evidence in the court of Law without prior written consent of laboratory.
- 4. Latest version of test methods used as per latest specification.
- 5. It is recommended that the acceptable limit is to be implemented. Values in excess of those mentioned in "acceptable limit" render the water not suitable, but still may be tolerated in the absence of an alternative source but up to the limits indicate under "permissible limit" in the absence of alternative sources, above which the source will have to be rejected.

Non NABL Test report – P.T.O

'End of Test Report'

1of 2

Laboratory: Acharya Vihar, Bhubaneswar, Odisha-751013. Tel: 0674-2379236, Mobile: 9760387460. E-mail: dir@immt.res.in.



#### (A Govt. of India Autonomous Body) **Environmental Chemical Laboratory** Bhubaneswar, Odisha TEST REPORT

	ued to : TATA STEEL LIMIT st report No – 08/2024-009	ED, MERAMANDA		Date : 23.09.	2024
Soi	urce of Sample : KHARAGPR	ASAD	Sample rece	iving Date : 09	.08.2024
Тур	pe of Sample : Well water		Sample Ana	ysis Date : 09	9.08.2024
19.	*Color, Hazen units	Part 4	5	15	<5
20.	*Odour	Part 5	Agreeable	Agreeable	Agreeable
21.	*Conductivity, µs/cm	Part 14	-		432
22.	*Total Suspended Solid, mg/l	Part 17	-	-	3.0
23.	*Nitrite as NO <sub>2</sub> ,mg/L	Part 34	-	-	0.217
24.	*Nitrate as NO <sub>3</sub> , mg/L	Part 34	45	No relaxation	20.9
25.	Sodium, mg/l	Part 45	-	-	14.59
26.	Potassium, mg/1	Part 45	-	-	14.57
27.	Residual Free Chlorine, mg/l	Part 26	0.2	1.0	<0.1
28.	Arsenic as As, mg/l	Part 37	0.01	No relaxation	<0.001
29.	Total Coliform by MPN	IS 1622 RA 2019	Shall not be detectable in 100ml sample	No relaxation	>542
30.	Fecal Coliform by MPN	IS 1622 RA 2019	Shall not be detectable in 100ml sample	No relaxation	17

Authorized Signatory

้าทั่

A ANDRE CHEMICS THE REAL Dr. Arakshita Majhi

Senior Principal Scientist

Phone: 0674-2379236,

E mail - arakshita@immt.res.in

### NOTES :

1. The sample is drawn by EC Laboratory & result relates to the sample tested.

Segior Principal

. d'. e

- 2. This certificate shall not be reproduced wholly or in part without prior written consent of the laboratory.
- 3. This certificate shall not be used in any advertising media or as evidence in the court of Law without prior written consent of laboratory.
- 4. Latest version of test methods used as per latest specification.
- 5. It is recommended that the acceptable limit is to be implemented. Values in excess of those mentioned in "acceptable limit" render the water not suitable, but still may be tolerated in the absence of an alternative source but up to the limits indicate under "permissible limit" in the absence of alternative sources, above which the source will have to be rejected.
- 6. Testing parameters which are not set limitation has marked as "-".

'End of Test Report'



(A Govt. of India Autonomous Body) Environmental Chemical Laboratory Bhubaneswar,Odisha (An NABL Accredited Laboratory)



TEST REPORT

Issued to: Tata Steel Limited, Meramandali

Test Report No.08/2024-001

Sample Condition: In Plastic Jar

Sample quantity: 2 Litre

Sampling Method: APHA1060B

Source of Sample :Kisinda UP & Down stream

 $\gamma A_{\rm P}$ 

Letter Reference :

Date : 23.09.2024

Sample Collected on: 09.08.2024 Sample Analysed on: 09.08.2024

SI No	Characteristics	Test Method	Kisinda UP-	Kisinda down	Standard as per Class
		As Per APHA	stream	stream	C-IS 2296/CPCB/SPCB
1	pH Value	APHA 4500H+ B	7.66	7.69	6.0-9.0
2	Colour	APHA 2120 B, C	<5	<5	300 (max)
3	Electrical Conductivity, µs/cm	APHA 2510 B	447	481	
4	Total Dissolved Solids, mg/l	APHA 2540 C	232	263	1500 (max)
5	Dissolved Oxygen, mg/l	APHA 2540 C	6.2	5.8	4 (min)
6	BOD (3) days at 27°C	APHA 5210 B	5.2	1.6	3 (max)
7	Chloride, mg/l	APHA 4500Cl- B	26.0	26.0	600 (max)
8	Fluoride as F, mg/l	APHA 4500F- C	3.1	2.6	1.5 (max)
9	Sulphates (SO <sub>4</sub> ), mg/l	APHA 4500 SO42- E	23.1	40.2	400 (max)
10	Nitrate as NO <sub>3</sub> , mg/l	APH4500 NO3- E	5.55	3.92	50 (max)
11	Hexa Chromium as Cr <sup>+6</sup> , mg/l	APHA 3500Cr B	0.016	0.024	0.05
12	Cyanide as CN , mg/l	APHA 4500 CN- C,D	<0.03	<0.03	0.05 (max)
13	Copper as Cu, mg/l	APHA 3111 B,C	0.019	0.026	1.5 (max)
14	Iron as Fe, mg/l	APHA 3500Fe, B	0.128	0.149	0.5 (max)
15	Cadmium as Cd , mg/l	АРНА 3111 В,С	<0.003	<0.003	0.01 (max)
16	Selenium as Se, mg/l	APHA 3114 B	<0.001	<0.001	0.05 (max)

1of 2

Laboratory: Acharya Vihar, Bhubaneswar, Odisha-751013. Tel: 0674-2379236, Mobile: 9760387460.

E-Mail: <u>dir@immt.res.in</u>.

NABL Accredited Lab/ISO/IEC 17025:2005.



(A Govt. of India Autonomous Body) Environmental Chemical Laboratory Bhubaneswar,Odisha (An NABL Accredited Laboratory)



### TEST REPORT

17	Arsenic as As, mg/l	APHA 3114 B	< 0.001	< 0.001	0.2 (max)
18	Lead as Pb(max), mg/l	APHA 3111 B,C	<0.001	<0.001	0.1 (max)
19	Zinc as Zn(max), mg/l	APHA 3111 B,C	0.129	0.053	15 (max)
20	Sodium Absorption Ratio	By Calculation	4.95	6.45	
21	Total Coliform	APHA 9221 B	345	>542	5000
22	Fecal Coliform	APHA 9221 B	109	278	300
23	Manganese as Mn, mg/l		0.039	0.045	0.1
24	Sodium as Na, mg/l		23.67	31.24	
25	Potassium as K, mg/l		3.66	3.69	
26	Nickel as Ni, mg/l		< 0.001	<0.001	0.02
27	Chemical Oxygen Demand, mg/l		24.0	28.0	
28	Free Ammonia, mg/l		<0.01	<0.01	0.5
29	Boron as B, mg/l		<0.01	<0.01	0.5

Authorized Signatory

My on

Dr Arakshita Majhi Senior Principal Scientist Phone - 0674-2379236 E mail I.D- arakshita@immt.res.in



(A Govt. of India Autonomous Body) **Environmental Chemical Laboratory** Bhubaneswar, Odisha TEST REPORT



#### TATA STEEL LIMITED, MERAMANDALI Issued to :

Date: 23.09.2024

#### Test report No - 08/2024-008

Source of Sample : KOCHILAMARA	Sample receiving Date :	09.08.2024	
Type of Sample : Well water	Sample Analysis Date :	09.08.2024	

SI No	Characteristics	Test Method (P)of IS:3025	Requirements as p V	Test Result	
			Acceptable limit	Permissible Limit	
1.	Turbidity, NTU	Part 10	1	5	0.43
2.	pH@Temp° C	Part 11	6.5-8.5	No relaxation	7.21@25.0
3.	Total Dissolved Solids mg/L	Part 16	500	2000	643.0
4.	Total Hardness (as CaCO <sub>3</sub> ),mg/L	Part 21	200	600	420.0
5.	Calcium as Ca, mg/L	Part 40	75	200	76.15
6.	Magnesium as Mg, mg/L	Part 46	30	100	55.89
7.	Alkalinity as CaCO <sub>3</sub> , mg/L	Part 23	200	600	362.0
8.	Chloride as Cl, mg/L	Part 32	250	1000	58.0
9.	Sulfate as SO <sub>4</sub> , mg/L	Part 24	200	400	102.15
10.	Fluoride as F, mg/L	Part 60	1.0	1.5	0.81
11.	Iron as Fe, mg/L	Part 53	0.3	· No relaxation	0.169
12.	Copper as Cu, mg/L	Part 42	0.05	1.5	0.028
13.	Manganese as Mn, mg/L	APHA(PART 3111B)	0.1	0.3	0.034
14.	Zinc as Zn, mg/L	Part 49	5.0	15.0	0.078
15.	Lead as Pb, mg/L	Part 47	0.01	No relaxation	< 0.001
16.	Cadmium as Cd, mg/L	Part 41	0.003	No relaxation	< 0.001
17.	Chromium as Cr, mg/L	Part 52	0.05	No relaxation	0.206
18.	Nickel as Ni, mg/l	Part 54	0.02	No relaxation	<0.001

**Authorized Signatory** 

1961 r<sup>isc</sup>hit.

Senior Principal Scientist

E mail - arakshita@immt.res.in

NOTES :

- The sample is drawn by EC Laboratory & result relates to the sample tested. 1.
- 2. This certificate shall not be reproduced wholly or in part without prior written consent of the laboratory.
- 3. This certificate shall not be used in any advertising media or as evidence in the court of Law without prior written consent of laboratory.
- 4. Latest version of test methods used as per latest specification.
- 5. It is recommended that the acceptable limit is to be implemented. Values in excess of those mentioned in "acceptable limit" render the water not suitable, but still may be tolerated in the absence of an alternative source but up to the limits indicate under "permissible limit" in the absence of alternative sources, above which the source will have to be rejected.

Non NABL Test report – P.T.O

'End of Test Report'

10f 2

Laboratory: Acharya Vihar, Bhubaneswar, Odisha-751013. Tel: 0674-2379236, Mobile: 9760387460. E-mail: dir@immt.res.in.



#### (A Govt. of India Autonomous Body) **Environmental Chemical Laboratory** Bhubaneswar, Odisha **TEST REPORT**

Issued	to : TATA STEEL LIMITED, MERAMANDALI	Date : 23.09.2024
Test re	eport No – 08/2024-008	

#### Source of Sample : KOCHILAMARA

Type of Sample : Well water

Sample Analysis Date : 09.08.2024

09.08.2024

Sample receiving Date :

19.	*Color, Hazen units	Part 4	5	15	<5
20.	*Odour	Part 5	Agreeable	Agreeable	Agreeable
21.	*Conductivity, µs/cm	Part 14		-	1052
22.	*Total Suspended Solid, mg/l	Part 17	-	-	2.0
23.	*Nitrite as NO <sub>2</sub> ,mg/L	Part 34	-	-	0.341
24.	*Nitrate as NO <sub>3</sub> , mg/L	Part 34	45	No relaxation	68.0
25.	Sodium, mg/l	Part 45		-	78.67
26.	Potassium, mg/l	Part 45	-	-	2.14
27.	Residual Free Chlorine, mg/l	Part 26	0.2	1.0	<0.1
28.	Arsenic as As, mg/l	Part 37	0.01	No relaxation	< 0.001
29.	Total Coliform by MPN	IS 1622 RA 2019	Shall not be detectable in 100ml sample	No relaxation	>542
30.	Fecal Coliform by MPN	IS 1622 RA 2019	Shall not be detectable in 100ml sample	No relaxation	7

Authorized Signatory

Arakshita Majhi Cenior Principal Scientist Senior Principal Scientist Senior Principal Scientist Senior Principal Scientist Phone : 0674-2379236, E mail - arakshit

#### **NOTES:**

- 1. The sample is drawn by EC Laboratory & result relates to the sample tested.
- This certificate shall not be reproduced wholly or in part without prior written consent of the laboratory. 2.

Mai

- 3. This certificate shall not be used in any advertising media or as evidence in the court of Law without prior written consent of laboratory.
- 4. Latest version of test methods used as per latest specification.
- 5. It is recommended that the acceptable limit is to be implemented. Values in excess of those mentioned in "acceptable limit" render the water not suitable, but still may be tolerated in the absence of an alternative source but up to the limits indicate under "permissible limit" in the absence of alternative sources, above which the source will have to be rejected.
- 6. Testing parameters which are not set limitation has marked as "-".

'End of Test Report'



(A Govt. of India Autonomous Body) **Environmental Chemical Laboratory** Bhubaneswar,Odisha (An NABL Accredited Laboratory)



TEST REPORT

Issued to: Tata Steel Limited, Meramandali

Test Report No.08/2024-002

Sample Condition: In Plastic Jar

Sample quantity: 2 Litre

Sampling Method: APHA1060B

Source of Sample :Lingra UP & Down stream

Letter Reference :

Date : 23.09.2024

Sample Collected on: 09.08.2024 Sample Analysed on: 09.08.2024

SI No	Characteristics	Test Method As Per APHA	Lingra UP- stream	Lingra down stream	Standard as per Class C-IS 2296/CPCB/SPCB
1	pH Value	APHA 4500H+ B	7.45	7.43	6.0-9.0
2	Colour	APHA 2120 B, C	<5	<5	300 (max)
3	Electrical Conductivity, µs/cm	APHA 2510 B	270	272	
4	Total Dissolved Solids, mg/l	АРНА 2540 С	145.0	151.0	1500 (max)
5	Dissolved Oxygen, mg/l	APHA 2540 C	5.4	5.8	4 (min)
6	BOD (3) days at 27°C	APHA 5210 B	1.6	2.0	3 (max)
7	Chloride, mg/l	APHA 4500Cl- B	16.0	14.0	600 (max)
8	Fluoride as F, mg/l	APHA 4500F- C	0.41	0.41	1.5 (max)
9	Sulphates (SO <sub>4</sub> ) , mg/l	АРНА 4500 SO42- Е	5.11	21.44	400 (max)
10	Nitrate as NO <sub>3</sub> , mg/l	APH4500 NO3- E	2.72	2.48	50 (max)
11	Hexa Chromium as Cr <sup>+6</sup> , mg/l	APHA 3500Cr B	0.012	0.014	0.05
12	Cyanide as CN , mg/l	APHA 4500 CN- C,D	<0.03	<0.03	0.05 (max)
13	Copper as Cu, mg/1	APHA 3111 B,C	0.020	0.019	1.5 (max)
4	Iron as Fe, mg/l	APHA 3500Fe, B	0.369	0.702	0.5 (max)
5	Cadmium as Cd , mg/l	АРНА 3111 В,С	<0.001	<0.001	0.01 (max)



Laboratory: Acharya Vihar, Bhubaneswar, Odisha-751013. Tel: 0674-2379236, Mobile: 9760387460. E-Mail: dir@immt.res.in. NABL Accredited Lab/ISO/IEC 17025:2005.

10f 2



(A Govt. of India Autonomous Body) Environmental Chemical Laboratory Bhubaneswar,Odisha

(An NABL Accredited Laboratory)



#### TEST REPORT

16	Selenium as Se, mg/l	APHA 3114 B	<0.001	<0.001	0.05 (max)
17	Arsenic as As, mg/l	APHA 3114 B	< 0.001	<0.001	0.2 (max)
18	Lead as Pb(max), mg/l	APHA 3111 B,C	<0.001	<0.001	0.1 (max)
19	Zinc as Zn(max), mg/l	APHA 3111 B,C	0.063	0.081	15 (max)
20	Sodium Absorption Ratio	By Calculation	3.88	3.56	
21	Total Coliform (CFU/ml)	APHA 9221 B	542	>542	5000
22	Fecal Coliform (CFU/ml)	APHA 9221 B	348	120	300
23	Manganese as Mn, mg/l		0.083	0.064	0.1
24	Sodium as Na, mg/l		15.12	14.69	
25	Potassium as K, mg/l		3.43	3.37	
26	Nickel as Ni, mg/l		<0.001	<0.001	0.02
27	Chemical Oxygen Demand, mg/l		12.0	16.0	
28	Free Ammonia, mg/l		<0.01	<0.01	0.5
29	Boron as B, mg/l		< 0.01	<0.01	0.5

Authorized Signatory

Dr Arakshita Majhi Senior Principal Scientist Phone - 0674-2379236 E mail I.D- arakshita@immt.res.in

> 2of 2 Laboratory: Acharya Vihar, Bhubaneswar, Odisha-751013. Tel: 0674-2379236, Mobile: 9760387460. E-Mail: <u>dir@immt.res.in</u>. NABL Accredited Lab/ISO/IEC 17025:2005.



#### (A Govt. of India Autonomous Body) **Environmental Chemical Laboratory** Bhubaneswar, Odisha **TEST REPORT**

#### Issued to : TATA STEEL LIMITED, MERAMANDALI

Date: 23.09.2024

#### Test report No - 08/2024-010

Source of Sample : MOTANGA	Sample receiving Date :	09.08.2024
Type of Sample : Well water	Sample Analysis Date :	09.08.2024

Sample Analysis Date : 09.08.2024

19.	*Color, Hazen units	Part 4	5	15	<5
20.	*Odour	Part 5	Agreeable	Agreeable	Agreeable
21.	*Conductivity, µs/cm	Part 14	-	5-	1094
22.	*Total Suspended Solid, mg/l	Part 17	-		5.0
23.	*Nitrite as NO <sub>2</sub> ,mg/L	Part 34	-	-	0.102
24.	*Nitrate as NO <sub>3</sub> , mg/L	Part 34	45	No relaxation	25.6
25.	Sodium, mg/l	Part 45	-	-	77.71
26.	Potassium, mg/l	Part 45	-		2.99
27.	Residual Free Chlorine, mg/l	Part 26	0.2	1.0	<0.1
28.	Arsenic as As, mg/l	Part 37	0.01	No relaxation	<0.001
29.	Total Coliform by MPN	IS 1622 RA 2019	Shall not be detectable in 100ml sample	No relaxation	221
30.	Fecal Coliform by MPN	IS 1622 RA 2019	Shall not be detectable in 100ml sample	No relaxation	79

Authorized Signatory

menta é Sur à Imenta é Sur à la Mair 2 Dr. Arakshita Majhi al-12 Senior Principal Scientist Phone: 0674-2379236,

Sings

E mail - arakshita@immt.res.in

NOTES :

1. The sample is drawn by EC Laboratory & result relates to the sample tested.

ola indiali

- This certificate shall not be reproduced wholly or in part without prior written consent of the laboratory. 2.
- This certificate shall not be used in any advertising media or as evidence in the court of Law without prior written consent of 3. laboratory.
- 4. Latest version of test methods used as per latest specification.
- 5. It is recommended that the acceptable limit is to be implemented. Values in excess of those mentioned in "acceptable limit" render the water not suitable, but still may be tolerated in the absence of an alternative source but up to the limits indicate under "permissible limit" in the absence of alternative sources, above which the source will have to be rejected.
- 6. Testing parameters which are not set limitation has marked as "-".

'End of Test Report'

20f 2 Laboratory: Acharya Vihar, Bhubaneswar, Odisha-751013. Tel: 0674-2379236, Mobile: 9760387460. E-mail: dir@immt.res.in.



(A Govt. of India Autonomous Body) Environmental Chemical Laboratory Bhubaneswar, Odisha TEST REPORT



#### Issued to : TATA STEEL LIMITED, MERAMANDALI

#### Date : 23.09.2024

#### Test report No - 08/2024-010

Source of Sample : MOTANGA	Sample receiving Date :	09.08.2024
Type of Sample : Well water	Sample Analysis Date :	09 08 2024

Sample Analysis Date : 09.08.2024

SI No	Characteristics	Test Method (P)of IS:3025	Requirements as per IS 10500:2012(Latest Version)		Test Result
			Acceptable limit	Permissible Limit	-
1.	Turbidity, NTU	Part 10	1	5	0.73
2.	pH@Temp° C	Part 11	6.5-8.5	No relaxation	6.97@25.0
3.	Total Dissolved Solids mg/L	Part 16	500	2000	697.0
4.	Total Hardness (as CaCO <sub>3</sub> ),mg/L	Part 21	200	600	418.0
5.	Calcium as Ca, mg/L	Part 40	75	200	84.17
6.	Magnesium as Mg, mg/L	Part 46	30	100	50.54
7.	Alkalinity as CaCO <sub>3</sub> , mg/L	Part 23	200	600	326.0
8.	Chloride as Cl, mg/L	Part 32	250	1000	70.0
9.	Sulfate as SO <sub>4</sub> , mg/L	Part 24	200	400	139.13
10.	Fluoride as F, mg/L	Part 60	1.0	1.5	0.80
11.	Iron as Fe, mg/L	Part 53	0.3	No relaxation	0.068
12.	Copper as Cu, mg/L	Part 42	0.05	1.5	0.026
13.	Manganese as Mn, mg/L	APHA(PART 3111B)	0.1	0.3	0.014
14.	Zinc as Zn, mg/L	Part 49	5.0	15.0	0.197
15.	Lead as Pb, mg/L	Part 47	0.01	No relaxation	< 0.001
16.	Cadmium as Cd, mg/L	Part 41	0.003	No relaxation	<0.001
17.	Chromium as Cr, mg/L	Part 52	0.05	No relaxation	<0.001
18.	Nickel as Ni, mg/l	Part 54	0.02	No relaxation	<0.001

Authorized Signatory

**Dr. Arakshita Majhi** Senior Principal Scientist Phone : 0674-2379236,

E mail - arakshita@immt.res.in

#### NOTES :

- 1. The sample is drawn by EC Laboratory & result relates to the sample tested.
- 2. This certificate shall not be reproduced wholly or in part without prior written consent of the laboratory.
- 3. This certificate shall not be used in any advertising media or as evidence in the court of Law without prior written consent of laboratory.
- 4. Latest version of test methods used as per latest specification.
- 5. It is recommended that the acceptable limit is to be implemented. Values in excess of those mentioned in "acceptable limit" render the water not suitable, but still may be tolerated in the absence of an alternative source but up to the limits indicate under "permissible limit" in the absence of alternative sources, above which the source will have to be rejected.

Non NABL Test report - P.T.O

'End of Test Report'

1of 2

Laboratory: Acharya Vihar, Bhubaneswar, Odisha-751013. Tel: 0674-2379236, Mobile: 9760387460. E-mail: dir@immt.res.in.



(A Govt. of India Autonomous Body) **Environmental Chemical Laboratory** Bhubaneswar, Odisha TEST REPORT and the second state and second states and the second second second second second second second second second s A MARSHARE REPORTED TO A CONTRACT OF A CO



#### Issued to : TATA STEEL LIMITED, MERAMANDALI Date : 23.09.2024

#### Test report No - 08/2024-013

Type of Sample : Well water

#### Source of Sample : NARENDRAPUR

Sample receiving Date : 09.08.2024

Sample Analysis Date : 09.08.2024

SI No	Characteristics	Test Method (P)of IS:3025	Requirements as per IS 10500:2012(Latest Version)		Test Result
			Acceptable limit	Permissible Limit	
1.	Turbidity, NTU	Part 10	1	5	4.08
2.	pH@Temp° C	Part 11	6.5-8.5	No relaxation	7.22@25.0
3.	Total Dissolved Solids mg/L	Part 16	500	2000	535.0
4.	Total Hardness (as CaCO <sub>3</sub> ),mg/L	Part 21	200	600	318.0
5.	Calcium as Ca, mg/L	Part 40	75	200	11.22
6.	Magnesium as Mg, mg/L	Part 46	30	100	70.47
7.	Alkalinity as CaCO <sub>3</sub> , mg/L	Part 23	200	600	264.0
8.	Chloride as Cl, mg/L	Part 32	250	1000	48.0
9.	Sulfate as SO <sub>4</sub> , mg/L	Part 24	200	400	79.51
10.	Fluoride as F, mg/L	Part 60	1.0	1.5	0.68
11.	Iron as Fe, mg/L	Part 53	0.3	No relaxation	0.027
12.	Copper as Cu, mg/L	Part 42	0.05	1.5	0.027
13.	Manganese as Mn, mg/L	APHA(PART 3111B)	0.1	0.3	0.008
14.	Zinc as Zn, mg/L	Part 49	5.0	15.0	0.086
15.	Lead as Pb, mg/L	Part 47	0.01	No relaxation	<0.001
16.	Cadmium as Cd, mg/L	Part 41	0.003	No relaxation	< 0.001
17.	Chromium as Cr, mg/L	Part 52	0.05	No relaxation	< 0.001
18.	Nickel as Ni, mg/l	Part 54	0.02	No relaxation	<0.001

Authorized Signatory

vior bunc bar - e.,

Sustainabili

Senior Principal Scientist, Studies Materials (NIL) Phone : 0674-2379236

E mail - arakshita@immt.res.in

#### NOTES :

- 1. The sample is drawn by EC Laboratory & result relates to the sample tested.
- 2. This certificate shall not be reproduced wholly or in part without prior written consent of the laboratory.
- 3. This certificate shall not be used in any advertising media or as evidence in the court of Law without prior written consent of laboratory.
- 4. Latest version of test methods used as per latest specification.
- 5. It is recommended that the acceptable limit is to be implemented. Values in excess of those mentioned in "acceptable limit" render the water not suitable, but still may be tolerated in the absence of an alternative source but up to the limits indicate under "permissible limit" in the absence of alternative sources, above which the source will have to be rejected.

Non NABL Test report – P.T.O

'End of Test Report'

1of 2

Laboratory: Acharya Vihar, Bhubaneswar, Odisha-751013. Tel: 0674-2379236, Mobile: 9760387460. E-mail: dir@immt.res.in.



#### (A Govt. of India Autonomous Body) **Environmental Chemical Laboratory** Bhubaneswar, Odisha TEST REPORT

Iss	ued to : TATA STEEL LIMIT	ED, MERAMANDA	u	Date : 23.09.2	2024		
Tes	st report No - 08/2024-013						
Sou	arce of Sample : NARENDRA	PUR	Sample rec	eiving Date : 09	.08.2024		
Тур	e of Sample : Well water		Sample An	alysis Date : 09	.08.2024		
19.	*Color, Hazen units	Part 4	5	15	<5		
20.	*Odour	Part 5	Agreeable	Agreeable	Agreeable		
21.	*Conductivity, µs/cm	Part 14	-	-	842		
22.	*Total Suspended Solid, mg/l	Part 17	-	-	10.0		
23.	*Nitrite as NO <sub>2</sub> ,mg/L	Part 34	-	-	0.267		
24.	*Nitrate as NO <sub>3</sub> , mg/L	Part 34	45	No relaxation	51.9		
25.	Sodium, mg/l	Part 45	-		55.50		
26.	Potassium, mg/l	Part 45	-	-	6.39		
27.	Residual Free Chlorine, mg/l	Part 26	0.2	1.0	<0.1		
	Arsenic as As, mg/l	Part 37	0.01	No relaxation	<0.001		
.9.	Total Coliform by MPN	IS 1622 RA 2019	Shall not be detectable in 100ml sample	e No relaxation	348		
30.	Fecal Coliform by MPN	IS 1622 RA 2019	Shall not be detectable	e No relaxation	11		

Authorized Signatory

Dr. Arakshita Majhi

Senior Principal Scientist

Phone: 0674-2379236,

E mail - arakshita@immt.res.in

#### **NOTES:**

- The sample is drawn by EC Laboratory & result relates to the sample tested. 1.
- This certificate shall not be reproduced wholly or in part without prior written consent of the laboratory. 2.
- This certificate shall not be used in any advertising media or as evidence in the court of Law without prior written consent of З, laboratory.

in 100ml sample

- 4. Latest version of test methods used as per latest specification.
- 5. It is recommended that the acceptable limit is to be implemented. Values in excess of those mentioned in "acceptable limit" render the water not suitable, but still may be tolerated in the absence of an alternative source but up to the limits indicate under "permissible limit" in the absence of alternative sources, above which the source will have to be rejected.
- 6. Testing parameters which are not set limitation has marked as "-".

'End of Test Report'



(A Govt. of India Autonomous Body) Environmental Chemical Laboratory Bhubaneswar, Odisha

TEST REPORT



#### Issued to : TATA STEEL LIMITED, MERAMANDALI

#### Date : 23.09.2024

#### Test report No - 08/2024-005

Source of Sample : SARAPA	Sample receiving Date :	09.08.2024
Type of Sample : Well water	Sample Analysis Date :	09.08.2024

SI No	Characteristics	Test Method (P)of IS:3025	Requirements as per IS 10500:2012(Latest Version)		Test Result
			Acceptable limit	Permissible Limit	-
1.	Turbidity, NTU	Part 10	1	5	0.49
2.	pH@Temp°C	Part 11	6.5-8.5	No relaxation	7.48@25.0
3.	Total Dissolved Solids mg/L	Part 16	500	2000	505.0
4.	Total Hardness (as CaCO <sub>3</sub> ),mg/L	Part 21	200	600	390.0
5.	Calcium as Ca, mg/L	Part 40	75	200	79.36
6.	Magnesium as Mg, mg/L	Part 46	30	100	46.66
7.	Alkalinity as CaCO <sub>3</sub> , mg/L	Part 23	200	600	304.0
8.	Chloride as Cl, mg/L	Part 32	250	1000	42.0
9.	Sulfate as SO <sub>4</sub> , mg/L	Part 24	200	400	
10.	Fluoride as F, mg/L	Part 60	1.0	1.5	92.59
11.	Iron as Fe, mg/L	Part 53	0.3	No relaxation	0.35
12.	Copper as Cu, mg/L	Part 42	0.05	1.5	
13.	Manganese as Mn, mg/L	APHA(PART 3111B)	0.1	0.3	0.024
14.	Zinc as Zn, mg/L	Part 49	5.0	15.0	0.018
15.	Lead as Pb, mg/L	Part 47	0.01	No relaxation	0.098
16.	Cadmium as Cd, mg/L	Part 41	0.003	No relaxation	<0.001
17.	Chromium as Cr, mg/L	Part 52	0.05		<0.001
18.	Nickel as Ni, mg/l			No relaxation	0.153
		Part 54	0.02	No relaxation	< 0.001

Authorized Signatory

N.

Dr. Arakshita Maihi

Senior Principal Scientist

Phone : 0674-2379236.

E mail - arakshita@immt.res.in

NOTES :

- 1. The sample is drawn by EC Laboratory & result relates to the sample tested.
- 2. This certificate shall not be reproduced wholly or in part without prior written consent of the laboratory.
- 3. This certificate shall not be used in any advertising media or as evidence in the court of Law without prior written consent of laboratory.
- 4. Latest version of test methods used as per latest specification.
- 5. It is recommended that the acceptable limit is to be implemented. Values in excess of those mentioned in "acceptable limit" render the water not suitable, but still may be tolerated in the absence of an alternative source but up to the limits indicate under "permissible limit" in the absence of alternative sources, above which the source will have to be rejected.

Non NABL Test report – P.T.O

'End of Test Report'

1of 2

Laboratory: Acharya Vihar, Bhubaneswar, Odisha-751013. Tel: 0674-2379236, Mobile: 9760387460. E-mail: dir@immt.res.in.



#### (A Govt. of India Autonomous Body) Environmental Chemical Laboratory Bhubaneswar, Odisha TEST REPORT

Issued to :	TATA STEEL LIMITED, MERAMANDALI	

Date: 23.09.2024

#### Test report No - 08/2024-005

50	urce of Sample : SARAPA		Sample rece	Sample receiving Date : 09.08.202					
Туј	Type of Sample : Well water			Sample Analysis Date : 09.08.2024					
1 <b>9</b> .	*Color, Hazen units	Part 4	5	15	<5				
20.	*Odour	Part 5	Agreeable	Agreeable	Agreeable				
21.	*Conductivity, µs/cm	Part 14		-	790				
22.	*Total Suspended Solid, mg/l	Part 17		-	6.0				
23.	*Nitrite as NO <sub>2</sub> ,mg/L	Part 34	-	-	0.079				
24.	*Nitrate as NO <sub>3</sub> , mg/L	Part 34	45	No relaxation	4.39				
25.	Sodium, mg/l	Part 45	-	-	20.54				
26.	Potassium, mg/l	Part 45	-	-	1.63				
27.	Residual Free Chlorine, mg/l	Part 26	0.2	1.0	<0.1				
28.	Arsenic as As, mg/l	Part 37	0.01	No relaxation	<0.001				
29.	Total Coliform by MPN	IS 1622 RA 2019	Shall not be detectable in 100ml sample	No relaxation	542				
30.	Fecal Coliform by MPN	IS 1622 RA 2019	Shall not be detectable in 100ml sample	No relaxation	<2				

Authorized Signatory

Dr. Arakshita Majhi

Senior Principal Scientist

Phone : 0674-2379236,

E mail - arakshita@immt.res.in

#### NOTES :

- 1. The sample is drawn by EC Laboratory & result relates to the sample tested.
- 2. This certificate shall not be reproduced wholly or in part without prior written consent of the laboratory.
- 3. This certificate shall not be used in any advertising media or as evidence in the court of Law without prior written consent of laboratory.
- 4. Latest version of test methods used as per latest specification.

inec tc isin

- 5. It is recommended that the acceptable limit is to be implemented. Values in excess of those mentioned in "acceptable limit" render the water not suitable, but still may be tolerated in the absence of an alternative source but up to the limits indicate under "permissible limit" in the absence of alternative sources, above which the source will have to be rejected.
- 6. Testing parameters which are not set limitation has marked as "-".

'End of Test Report'



(A Govt. of India Autonomous Body) Environmental Chemical Laboratory Bhubaneswar, Odisha TEST REPORT



#### Issued to : TATA STEEL LIMITED, MERAMANDALI

and the second state

#### Date : 23.09.2024

#### Test report No - 08/2024-006

Source of Sample : SIBAPUR	Sample receiving Date :	09.08.2024
Type of Sample : Well water	Sample Analysis Date :	09.08.2024

SI No	Characteristics	Test Method (P)of IS:3025	Requirements as p V	Test Result	
			Acceptable limit	Permissible Limit	
1.	. Turbidity, NTU Part 10		1	5	2.03
2.	pH@Temp° C	Part 11	6.5-8.5	No relaxation	7.42@25.0
3.	Total Dissolved Solids mg/L	Part 16	500	2000	240.0
4.	Total Hardness (as CaCO <sub>3</sub> ),mg/L	Part 21	200	600	154.0
5.	Calcium as Ca, mg/L	Part 40	75	200	52.10
6.	Magnesium as Mg, mg/L	Part 46	30	100	5.83
7.	Alkalinity as CaCO <sub>3</sub> , mg/L	Part 23	200	600	126.0
8.	Chloride as Cl, mg/L	Part 32	250	1000	24.0
9.	Sulfate as SO <sub>4</sub> , mg/L	Part 24	200	400	33.46
10.	Fluoride as F, mg/L	Part 60	1.0	1.5	0.64
11.	Iron as Fe, mg/L	Part 53	0.3	No relaxation	0.113
12.	Copper as Cu, mg/L	Part 42	0.05	1.5	0.039
13.	Manganese as Min, mg/L	APHA(PART 3111B)	0.1	0.3	0.019
14.	Zinc as Zn, mg/L	Part 49	5.0	15.0	0.277
15.	Lead as Pb, mg/L	Part 47	0.01	No relaxation	< 0.001
16.	Cadmium as Cd, mg/L	Part 41	0.003	No relaxation	<0.001
17.	Chromium as Cr, mg/L	Part 52	0.05	No relaxation	< 0.001
18.	Nickel as Ni, mg/l	Part 54	0.02	No relaxation	<0.001

Authorized Signatory



Dr. Arakshita Majhi

Senior Principal Scientist

Phone: 0674-2379236,

E mail - arakshita@immt.res.in

#### NOTES :

- 1. The sample is drawn by EC Laboratory & result relates to the sample tested.
- 2. This certificate shall not be reproduced wholly or in part without prior written consent of the laboratory.
- 3. This certificate shall not be used in any advertising media or as evidence in the court of Law without prior written consent of laboratory.
- Latest version of test methods used as per latest specification.
- 5. It is recommended that the acceptable limit is to be implemented. Values in excess of those mentioned in "acceptable limit" render the water not suitable, but still may be tolerated in the absence of an alternative source but up to the limits indicate under "permissible limit" in the absence of alternative sources, above which the source will have to be rejected.

Non NABL Test report – P.T.O

'End of Test Report'

1of 2

Laboratory: Acharya Vihar, Bhubaneswar, Odisha-751013. Tel: 0674-2379236, Mobile: 9760387460. E-mail: dir@immt.res.in.



#### (A Govt. of India Autonomous Body) Environmental Chemical Laboratory Bhubaneswar, Odisha TEST REPORT

#### Issued to : TATA STEEL LIMITED, MERAMANDALI

Date : 23.09.2024

#### Test report No - 08/2024-006

Sou	Irce of Sample : SIBAPUR	Sample recei	Sample receiving Date: 09.08.2024					
Тур	Type of Sample : Well water			Sample Analysis Date: 09.08.2024				
19.	*Color, Hazen units	Part 4	5	15	<5			
20.	*Odour	Part 5	Agreeable	Agreeable	Agreeable			
21.	*Conductivity, µs/cm	Part 14	-	-	415			
22.	*Total Suspended Solid, mg/l	Part 17	-	-	8.0			
23.	*Nitrite as NO <sub>2</sub> ,mg/L	Part 34	-	-	0.148			
24.	*Nitrate as NO <sub>3</sub> , mg/L	Part 34	45	No relaxation	25.30			
25.	Sodium, mg/l	Part 45	-	-	16.38			
26.	Potassium, mg/l	Part 45	-	-	13.85			
27.	Residual Free Chlorine, mg/l	Part 26	0.2	1.0	<0.1			
28.	Arsenic as As, mg/l	Part 37	0.01	No relaxation	<0.001			
29.	Total Coliform by MPN	IS 1622 RA 2019	Shall not be detectable in 100ml sample	No relaxation	>542			
30.	Fecal Coliform by MPN	IS 1622 RA 2019	Shall not be detectable in 100ml sample	No relaxation	32			

Authorized Signatory



Dr. Arakshita Majhi Senior Principal Scientist

Phone: 0674-2379236,

E mail - arakshita@immt.res.in

#### NOTES :

- 1. The sample is drawn by EC Laboratory & result relates to the sample tested.
- 2. This certificate shall not be reproduced wholly or in part without prior written consent of the laboratory.
- 3. This certificate shall not be used in any advertising media or as evidence in the court of Law without prior written consent of laboratory.
- 4. Latest version of test methods used as per latest specification.
- 5. It is recommended that the acceptable limit is to be implemented. Values in excess of those mentioned in "acceptable limit" render the water not suitable, but still may be tolerated in the absence of an alternative source but up to the limits indicate under "permissible limit" in the absence of alternative sources, above which the source will have to be rejected.
- 6. Testing parameters which are not set limitation has marked as "-".

'End of Test Report'

**2of 2** Laboratory: Acharya Vihar, Bhubaneswar, Odisha-751013. Tel: 0674-2379236, Mobile: 9760387460. E-mail: dir@immt.res.in.

## CSR Expenditure and Activities

## (Around Tata Steel Ltd, Meramandali & TSM-CPP(AEL))

#### Period: From April'24 to October'24

PROGRAM HEAD	Expenditure in Lakh	MAJOR INTERVENTIONS/REMARKS
HEALTH	62.07	Public Health Unit; Rishta; Project Drishti
Agriculture	57.18	Agricultural activity
Environment	2.91	Plantation at Nuahata, Odapada
Skill Development	6.89	Disability program
DRINKING WATER	61.72	Installation of tubewells; supply of drinking water (Kusupanga, Krunti, Narendrapur, Talbahal)
EDUCATION	307.98	School infrastructure; Education project: Green school project
SPORTS	4.86	Marathon
Miscellaneous	189.25	Volunteerism, Safety, Common expenses
TOTAL	692.86	

#### Ref.No.EMD/LAB/2024/0002

			April	May	June	July	August	September
S. N	Name of the unit	Location						
<b>0</b> . N	Name of the drift				I	Leq		
		Near Motor I D fan 1	82.9	82.8	82.4	83.2	82.1	83.6
		Near Motor I D fan-2	84.8	86.3	85.1	85.1	85.3	85.7
		Near Motor I D fan-3	85.2	85.2	84.9	84.8	85	85.2
		Near Cooling tower area	80.3	80.9	80.8	80.5	80.5	79.8
		Near Fire Pump House						
1	BF-2 Cast House	Building area	90.5	90.1	90.9	90.7	92.1	90.9
		PCI-1	82.2	83	80.8	82.2	83.5	84.1
		PCI-2	86.1	SD	83	84.8	82	83
		CA Fan-1,2,3	90.1	87.9	87.8	87.9	86.9	87.4
		Control room	59.8	60.1	60.5	60	58.1	60
		Near B F-2 Furnace area	81.1	80.8	79.8	80.5	81.4	79.9
2	BF-2 Stock House	Near ID fan 1	84.2 84.6	84.8 85	84.9	84.4 85.1	83.7 84.9	84.1 85.2
Z	BF-2 Stock House	Near ID fan 2	59.3	58.9	84.7 59.3	59.2	59.4	
		Control room office						61.8
		Near De dusting-2 ID fan	84.4	85.1	84.4	84.1	81.8	82.7
		Near Blower room area	92.1	91.6	87.5	89.7	93.2	93.6
		Near Cooling tower area	81.6	82.9	81.1	82	80.3	79.4
		Near De dusting-3 ID fan	82.5	82.1	83.2	82.8	81.6	82.8
		Near De dusting-4 ID fan	84.8	84	SD	SD	SD	SD
	Lime Plant	Near Pump House area	86.1	86.8	86.4	85.6	85.4	85.9
•		Screening House 01	SD	84.3	85.3	85.7	80.3	SD
3		Screening House 02	SD	88.3	87.7	87.8	SD	85.3
		Screening House 03	85	84.9	92.7	90	SD	86.9
		Screening House 04	SD	86.9	90.2	89.5	SD	87.6
		Screening House 05	84.2	SD	SD	SD	SD	87.8
		,						
		Delivery Building Near Outside Office area	83.5 82.7	83.1 79.3	82.9 77.7	83.2 76.8	82.2 77.9	81.8 76.7
		Gas Boosting Station	91.5	93.8	88.2	89.1	86.8	87.1
		Inside office building	58.8	93.0 61.4	60	60.4	62.1	62.5
		Near ID Fan -1	58.8 SD	82.9	SD	50.4 SD	SD	SD
		Near ID Fan -2	82.5	84.9	SD	81.1	84.6	83
4	BF PP-1 Boiler-01	Near FD fan	89.3	90.8	SD	89.7	90	87.2
		Near Boiler-1 Area	81.1	83.4	SD	83	84.8	83.3
		Near ID Fan -1	SD	85.2	86	SD	85.5	SD
_		Near ID Fan-2	SD	87.4	86.4	SD	87.4	SD
5	BF PP-1 Boiler-02	Near FD fan	SD	93.5	93.8	SD	95.7	SD
		Near Boiler-2 Area	SD	85.8	85.3	SD	84.7	SD
		Near ID Fan -1	84.5	SD	85.5	86.2	SD	85.6
		Near ID Fan -2	86.8	SD	87.5	87.8	SD	86.7
		Near FD fan	95	SD	94.2	96.4	SD	96.7
6	BF PP-1 Boiler-03	Near Blower (9 m)	89.1	91.4	90.4	91.3	90.9	90.8
-		TG Floor (8.5 m)	87.5	88.5	89.3	87.5	87.2	86.8
		Near Boiler-3 Area	84.9	SD	84.1	85.3	SD	84.1
		Near Control room office	67.2	60.9	61.2	63.4	63.5	63.8
		Near ID fan -1	80.1	80.5	80.2	80.5	79.6	80.8
		Near ID fan -2	80.5	81.3	80.3	80.7	79	81.1
	Cap finad hallon CO	Near FD fan 1	82	82.4	81.6	82	82.6	82.7
7	Gas fired boiler 60	Near FD fan 2	82.3	82.1	81.8	81.8	80.1	81.8
	TPH Area	60 TPH Blower feed water						
		pump	83.9	84	83.8	83.9	83.9	83.7
	1	Near Boiler area	81.4	82.7	81.4	81.6	80.2	80

			April	May	June	July	August	September
S. N	Name of the unit	Location						
•					T	Leq		
		Near ID fan -1	82.1	82.5	81.5	83	84	SD
		Near ID fan -2	84.8	84.3	84.8	84.8	83.9	SD
	Gas fired boiler 125	Near FD fan -1	87.6	87.9	88.4	87.3	88.9	SD
8	TPH Area	Near FD fan -2	88.1	88.1	88.8	88.4	87	SD
		Near Boiler area	82.8	81.6	81.4	82	83.6	SD
		125 TPH Blower feed Water	00 F	05.4	00 5	05.4	077	00
		pump Near ID fan -1 area	86.5 80	85.1 SD	86.5 SD	85.1 82.5	87.7 80.8	SD 81.2
		Near ID fan -2 area	80.5	SD	SD	82.5 82.7	81.7	
		Near FD fan -1 area	82.5	SD	SD	82.3	82.9	81.6 83.7
	Gas fired boiler 250	Near FD fan -2 area	83.6	SD	SD	84.5	83.1	82.3
9	TPH Area	Near Boiler area	81.7	SD	SD	84.7	82.2	80.9
	ΠΠΑισα	250 TPH Blower feed water	86.5	SD	SD	86.2	87.9	85.1
		pump	00.0	00	00	00.2	07.5	00.1
		Office and Control Room	60.1	58.4	60	59.3	62.1	59.6
		KILN NO-1	00.1	00.1		00.0	02.1	00.0
		Near Cooling tower area	SD	78.5	80.1	79.8	80.2	77.6
		Near De-dusting 01 ID Fan	SD	85.8	85.3	85.1	85.7	85.3
		Near 1& 2 control room						
		office	60.4	61.2	58.5	62.1	59.3	63.1
		Near Cooler area	SD	80.6	80.4	80.3	80.1	78.2
		Near Lobe Compressor						
		room	00	07.0	05.0	05.0	05.4	05.0
			SD	87.3	85.8	85.3	85.1	85.9
		KILN NO-2	SD	01.0	00	00.0	00	SD
		Near Cooling tower area Near Cooler area	SD	81.2 79.5	SD SD	80.2 79.1	SD SD	SD SD
			30	79.5	30	79.1	30	30
		Near Lobe Compressor						
		room	SD	84.5	SD	84.9	SD	SD
		KILN NO-3						
		Near Cooling tower area	79.7	SD	SD	SD	81.4	80
		Near De-dusting 02 ID Fan	85.8	SD	SD	SD	86	86.8
		Near 3& 4control room office	61.7	61.8	60	60.9	58.1	60.4
4.0		Near Cooler area	79.6	SD	SD	SD	80.5	81
10	DRI	Near Lobe Compressor						
		room	06.4	00	00	20	05	84.0
		KILN NO-4	86.4	SD	SD	SD	85	84.9
		Near Cooling tower area	80.4	SD	SD	SD	80	78.9
		Near Cooler area	80.9	SD	SD	SD	80.7	79.5
			00.9	50	50	30	00.7	19.5
		Near Lobe Compressor						
		room	84.2	SD	SD	SD	84.9	83.4
		KILN NO-5						
		Near Cooling tower area	79.6	81.9	SD	80	81.5	79.6
		Near De-dusting 03 ID Fan	85.6	87.8	SD	85.4	85.8	86.3
		Near 5& 6 control room	<b>FO</b> (		<b>5</b> 0 ·		<b>FO -</b>	
		office	59.1	62.1	59.4	60.2	58.9	60.6
		Near Cooler area	79.9	79.5	SD	80.1	81.5	80.1
		Near Lobe Compressor						
		room	84.4	86.1	SD	85.3	85.1	85.8
		KILN NO-6						
		Near Cooling tower area	79.8	SD	SD	SD	80.1	81.1
		Near Cooler area	80.2	SD	SD	SD	80.4	80.4

1		Near Lobe Compressor	1					
			07.0	00	0.0	0.0	05.0	0.4
			87.8	SD	SD	SD	85.9	84
		KILN NO-7	70.0	00	00	00	00	70.0
		Near Cooling tower area	79.6	SD	SD	SD	SD	79.8
		Near De-dusting 04 ID Fan	85.9	86.7	SD	85.6	85.9	86.3
		Near 7& 8 control room	50.0	50.7	E0 4	61.2	EQ 1	F0 4
		office	58.2	59.7 SD	58.4	61.3 SD	58.1 SD	59.4
		Near Cooler area	80.1	30	SD	30	30	80
		Near Lobe Compressor						
		room	85.3	SD	SD	SD	SD	85.2
		KILN NO-8						
		Near Cooling tower area	SD	79.9	SD	80.4	81.5	79.3
		Near Cooler area	SD	81.4	SD	81	80.4	79.8
		Near Lobe Compressor						
		room	SD	82.2	SD	86.2	86.1	84.5
		KILN NO-9	30	02.2	50	00.2	00.1	04.0
		Near Cooling tower area	78.5	80.3	79.4	80.3	SD	SD
		Near 9&10 control room	, 0.0	50.5	,	00.0	55	00
		office	57.9	60.6	60	59.3	59.7	59.7
		Near Cooler area	80.6	81.1	80	80.2	SD SD	SD SD
		Near Lobe Compressor	00.0	0111	00	00.2	00	00
							<b>a</b> -	0-
		room	84.1	84.2	84.9	85.2	SD	SD
		KILN NO-10						
		Near Cooling tower area	78.2	80.8	81.3	79.3	81.3	80.6
		Near De-dusting 05 ID Fan	85.8	85.7	86.2	86.1	85.8	85.9
		Near Cooler area	79	79.4	81.1	80.8	79.3	80.5
		Near Lobe Compressor						
		room	83.5	81.9	84.9	85.4	85.8	84.3
		Boiler-01						
		ID Fan	SD	81.6	83.4	82.3	82.4	82
		Near Boiler area	SD	83.7	84.5	84.8	84.8	84.4
		Boiler-02						
		ID Fan	82.9	SD	SD	81.5	SD	SD
		Near Boiler area	84.8	SD	SD	83.8	SD	SD
		Boiler-03						
		ID Fan	81.8	83.3	SD	82.4	80.3	82.3
		Near Boiler area	83.5	83.6	SD	83.5	81.3	83.7
		Boiler-04						
		ID Fan	82.1	82.1	SD	83.9	81.1	81.6
		Near Boiler area	83.2	83.8	SD	84.3	83.1	82.5
		Boiler-5						
		ID Fan	85.5	85.1	SD	85.4	84.7	85.4
11	110 MW Power	Near Boiler area	82.3	83.4	SD	82.3	83.2	82.1
••	Plant	Boiler-6						
		ID Fan	85.9	SD	SD	85.8	SD	85.8
		Near Boiler area	81.5	SD	SD	84.5	SD	83.5
		Boiler-7						
		ID Fan	SD	SD	SD	SD	85.6	84.9
		Near Boiler area	SD	SD	SD	SD	82.8	83
		Boiler-8						
		ID Fan	SD	84.8	SD	84.8	85	84.6
		Near Boiler area	SD	81.6	SD	84.3	81.7	81.7
		Boiler-9						
			026	84.8	84.8	84.9	SD	SD
		ID Fan	83.6					
		Near Boiler area	81.4	82.5	82.5	82.8	SD	SD
		Near Boiler area Boiler-10	81.4	82.5	82.5	82.8	SD	
		Near Boiler area						SD 86.3 82.5

	1	AFBC Boiler Area	SD	SD	SD	SD	SD	SD
		Near 33 TG MW	SD	SD	85.3	85.4	SD	SD
		Near 77 TG MW	87.1	87.1	SD	86.5	86.3	85.5
		Near Bag House Motor I D	07.1	07.1	00	00.0	00.0	00.0
		fan-1	85.2	85.4	85.6	85.4	SD	85.3
		Near Bag House Motor I D	00.2	00.1	00.0	00.1	00	00.0
		fan-2	85.6	SD	85.8	85.5	85.4	85.7
		Near Bag House Motor I D	00.0	00	00.0	00.0	00.1	00.1
		fan-3	SD	85.9	86.1	85.1	85.1	86
		Near Bag House Motor I D						
12	BF-1 Cast House	fan-4	86.1	85.8	SD	84.9	84.9	85.2
		Near secondary Cooling						
		tower area	80.8	80.6	82.1	81.2	81	81.4
		Near Main Pump House						
		Building area	86.9	86.2	87.5	88.4	88.8	87.9
		Near PCI building	SD	89.3	87.3	SD	SD	85.8
		Near B F-1 Furnace	81.9	80.2	80.7	79.3	80	80.2
		Near Bag House Motor I D						
		fan-1	SD	SD	SD	SD	SD	SD
13	BF-1 Stock House	Near Bag House Motor I D						
13	DI -I SLOCK HOUSE	fan-2	85.4	85.8	86.2	85	85.3	85.8
		BF-1 Office	60.4	59.8	60	59.3	59.2	58.4
		Near Fines building Area	80.2	81.1	82	82	80.5	82.3
		Near CRM Mill Complex						
		Area	81	79.2	81.1		80.8	83.9
		Near Fire water pump house			05.0			
		area	85.2	86.1	85.3		85.4	85
		Near T.L.L	86.2	85.6	SD		84.9	87.8
		Near A.R.P building	SD	86.1	85		84.6	85.2
		Near Air Receiver Tank area	96	95.8	92.1		94.1	89.7
		Near ETP area	83.3	84.8	84.8		82.3	80.2
		Near GP-1 Zinc Pot	SD	87.7	84.9		SD	SD
14	CRM	Near GP-2 Zinc Pot	87.5	88.9	85.5		84.9	SD
14	CRIVI	Near GP-3 Zinc Pot	SD	85.4	85.1		86.1	88
		Colour Coating Line	84.3	84.8	83.8		85	82.8
		Mill-1	86.8	86.3	85		86.7	86.4
		Mill-2	86.2	85.8	87.1		87.7	SD
		Mill-3	85.6	85.3	85.2		SD	85.5
		CRM Plant Office	60.4	60.1	59		58.5	58.4
		ECL	SD	SD	84.4		88.1	87.2
		CRCA	85.6	85.2	83.9		84.7	SD
		SPM	85.3	85.7	88.6		87.9	88.1
		RGM	81	82.3	82.6		SD	82.4
		Near Main ID fan 1	82.1	82.9	-		91	84.8
		Near Cooler fan area 1	85.6	83.7			85.1	82.6
		Near Cooler fan area-2	85.8	84			84.6	84.6
	1	Near Cooler fan area-3	85	83.9	1		82.9	84
		· · · · · · · · · · · · · · · · · · ·					85.3	85
		Near Cooler fan area-4	84.8	85.1				
		Near Cooler fan area-4 Near 85m2 ESP ID Fan	84.8 87.1	85.1 86			86.3	85.9
		Near 85m2 ESP ID Fan	87.1	86			86.3	85.9
		Near 85m2 ESP ID Fan Near 110m2 ESP ID fan						
		Near 85m2 ESP ID Fan	87.1	86			86.3 86.9	85.9
15	Sinter Plant-1	Near 85m2 ESP ID Fan Near 110m2 ESP ID fan Near Pump House Building area	87.1 89	86 86.5			86.3	85.9 86.3
15	Sinter Plant-1	Near 85m2 ESP ID Fan Near 110m2 ESP ID fan Near Pump House Building	87.1 89 80	86 86.5 80.6			86.3 86.9 81.1	85.9 86.3 82
15	Sinter Plant-1	Near 85m2 ESP ID Fan Near 110m2 ESP ID fan Near Pump House Building area Near bag filter ID fan	87.1 89 80 88.8	86 86.5 80.6 88.1			86.3 86.9 81.1 87.1	85.9 86.3 82 86.9
15	Sinter Plant-1	Near 85m2 ESP ID Fan Near 110m2 ESP ID fan Near Pump House Building area Near bag filter ID fan Product Screen	87.1 89 80 88.8	86 86.5 80.6 88.1			86.3 86.9 81.1 87.1	85.9 86.3 82 86.9
15	Sinter Plant-1	Near 85m2 ESP ID Fan Near 110m2 ESP ID fan Near Pump House Building area Near bag filter ID fan Product Screen Flux and Coke Crushing	87.1 89 80 88.8 87.4	86 86.5 80.6 88.1 85.8			86.3 86.9 81.1 87.1 85.9	85.9 86.3 82 86.9 86.5
15	Sinter Plant-1	Near 85m2 ESP ID Fan Near 110m2 ESP ID fan Near Pump House Building area Near bag filter ID fan Product Screen Flux and Coke Crushing House	87.1 89 80 88.8 87.4 82.8	86 86.5 80.6 88.1 85.8 81.4			86.3 86.9 81.1 87.1 85.9 80.3	85.9 86.3 82 86.9 86.5 81.4
15	Sinter Plant-1	Near 85m2 ESP ID Fan         Near 110m2 ESP ID fan         Near Pump House Building area         Near bag filter ID fan         Product Screen         Flux and Coke Crushing House         Sinter Machine 15 mtr	87.1 89 80 88.8 87.4 82.8 84.5	86 86.5 80.6 88.1 85.8 81.4 84.3			86.3 86.9 81.1 87.1 85.9 80.3 85.8	85.9 86.3 82 86.9 86.5 81.4 85.1
15	Sinter Plant-1	Near 85m2 ESP ID Fan         Near 110m2 ESP ID fan         Near Pump House Building area         Near bag filter ID fan         Product Screen         Flux and Coke Crushing House         Sinter Machine 15 mtr         9 m office room	87.1 89 80 88.8 87.4 82.8 84.5 58.4	86 86.5 80.6 88.1 85.8 81.4 84.3 58.8			86.3 86.9 81.1 87.1 85.9 80.3 85.8 57.5	85.9 86.3 82 86.9 86.5 81.4 85.1 60

		Electrical office	67.4	61.5	I	1	61.7	59.8
		Proportioning Building	80.2	81.9			80.7	80.7
		Mixing House	81.1	82			81.3	81.6
		Sinter machine 19 mtr	85.4	85.1			81.9	85.3
		Near Stone Cutter Building						
		area	84.8	84.8	84.2	84.8	84.8	83.5
		Near M.H.S I.D fan	84.5	84.3	84.6	84.6	84.6	84.9
		Near Coal Pushing &						
16	Coke Oven-1	Charging I D Fan Area	SD	SD	SD	81.4	SD	SD
		Near Battery-1 area	80	80	81.4	80.5	SD	81.5
		Near Battery-2 area	81.2	80.2	80.9	81.1	81	80.3
		Control room office	60.1	60.2	59.5	60.3	59.6	59.5
		Laboratory	58.8	58	58.4	59	59.1	58
		Near Main ESP ID	83.9	82.9	81.7	83.9	84.8	84.5
		Near PD ESP ID fan	81.5	82.1	80.2	82	81.5	83.1
		Near Cooler fan -1	86.1	87.1	86.5	86.7	86.2	86.3
17	Sinter Plant-02	Near Cooler fan -2	85.9	86.1	85.7	86.3	85.8	76.7
.,		Near Cooler fan -3	86.2	87.6	86.3	87	86	76.3
		Control Room Area	60.2	61.2	60.4	58.9	58.3	58.2
		ESP Area	79.9	80.2	80.5	81.2	80.4	81.3
		Near M. N. D Area	80	79.9	81.1	80.3	80.1	81.5
		Near Main ESP ID fan	84.6	84.8	83.7	84	84.5	84.8
		Near PD ESP ID fan	81.7	81.9	80.8	81.3	81.6	82.8
		Near Cooler fan -1	86	88.5	87.9	86.1	86.9	85.9
		Near Cooler fan -2	85.4	87.6	87.1	87.3	87	85.7
	Sinter Plant-03	Near Cooler fan -3	88.8	88.6	87.6	87.2	87.9	85.2
		SP2,3RCPHTPM circle	91	90.7	90.2	91.4	90.9	90.1
18		ESP Area	80.8	81.8	80	80.5	80.3	82.1
		Pumphouse Area	82.1	83.2	82.9	81.1	81.1	82.9
		Near M. N. D Area	81.6	82.3	80.7	81.4	80	81.4
		Control Room Area	58.8	59.3	59.7	59.5	59.7	59.4
		Infront of Entrance of DG						
		250 KVA SP2&SP3 (Door						
		Close Condition)	84.1	84.4	83.9	82.8	83.6	83.9
		Near Secondary ID fan-1	91	SD		91.9	91.4	91.5
		Near Secondary ID fan-2	91.3	91.7		91.8	91.9	SD
		Near Secondary ID fan area-3	SD	91.4		90	SD	92
		Near Secondary ID fan area-4	90.3	91.3		89.5	91.5	92.1
		Near Cooling Tower area	83.4	81.2		84.8	82.6	84.6
19	BOF Shop	Near Primary/ Secondary ID fan					Ι Τ	
		area-1/2	81.8	82.3		82	82	81.2
		BOF Briquetting plant	SD	78.5		81.5	80.8	81.4
		Bag House T44B ID fan	84.2	82.7		84.5	SD	SD
		BOF office area	61.4	66.3		62.3	62.3	62.4
		Near Wage bridge area	76.3	77.8		79.3	78.5	80.6
		Near Motor ID fan area-1 area		91.1		91.6	90.7	92.8
		Near Motor ID fan area-2 area	1	88.9	t	89.3	90.1	91.6
		Near Motor ID fan area-4 area	1	88.4		90.4	SD	90.3
	SMS-2-FES-1&2	Near Motor ID fan area-6 area		88.3		89.8	89.2	90.1
	31VI3-2-FE3-1&2		l			84.5	84.2	84.9
	31013-2-FE3-1&2			84 1			UT.4	04.0
20	3IVI3-2-FE3-1&2	Booster House (ID Fan)		84.1 79.4			60.8	58.8
20	31013-2-FE3-1&2	Booster House (ID Fan) Near Control room Area	83.6	79.4	847	58.4	60.8 85.1	58.8 84.4
20	31013-2-FE3-102	Booster House (ID Fan) Near Control room Area Near COG Fan Area	83.6		84.7		60.8 85.1	58.8 84.4
20	31013-2-FE3-1@2	Booster House (ID Fan) Near Control room Area Near COG Fan Area Near RHF Office area		79.4 85.1		58.4 85.2	85.1	84.4
		Booster House (ID Fan) Near Control room Area Near COG Fan Area Near RHF Office area (Pulpit)	80.7	79.4 85.1 80.6	81.9	58.4 85.2 81.7	85.1 83	84.4 81.7
20	HSM	Booster House (ID Fan) Near Control room Area Near COG Fan Area Near RHF Office area (Pulpit) Near RM-2 area	80.7 87.9	79.4 85.1 80.6 87.2	81.9 86.3	58.4 85.2 81.7 85.8	85.1 83 85.2	84.4 81.7 86.2
		Booster House (ID Fan) Near Control room Area Near COG Fan Area Near RHF Office area (Pulpit) Near RM-2 area Near Roll Shop area	80.7 87.9 78.7	79.4 85.1 80.6 87.2 77.5	81.9 86.3 78.2	58.4 85.2 81.7 85.8 79.3	85.1 83 85.2 78.4	84.4 81.7 86.2 79.9
		Booster House (ID Fan) Near Control room Area Near COG Fan Area Near RHF Office area (Pulpit) Near RM-2 area	80.7 87.9	79.4 85.1 80.6 87.2	81.9 86.3	58.4 85.2 81.7 85.8	85.1 83 85.2	84.4 81.7 86.2

I	I	Neer Combustion of the	[	1		1		
		Near Combustion air blower	86.9	87.1	86.1	86.7	86.6	85.9
		Near Combustion air blower-	00.9	57.1	00.1	00.7	00.0	85.9 SD
		2	87.2	86.8	85.8	85.5	85.8	
		DC pulpit office area	62.4	61.3	62.1	61.5	62.2	62
		Near RM-1 area	85.4	85.9	85.2	85.9	85.2	85.8
		FM area	86.7	86.3	86.7	86.2	85.9	85.7
		Laminar area	89.7	88.9	88.2	87.8	87.3	87.8
		Near DC sampling Station	84.5	84.9	84.4	84.1	83.7	82.9
		Near Re-heating Furness area	81.7	81.2	82.3	80.9	81.4	81.7
		Near Exhauster house area	87.2	87.5	87.8	86.8	86.9	86.3
		Near Chemical Dosing E.T.P	01.2	07.0	07.0	00.0	00.0	00.0
		room area	80	80.2	80.4	80.6	79.3	80.4
		Near Pusher car Emission						
		control system ID Fan	81.7	81.6	80.1	83.7	82	82.1
		Near Guide car emission I D						
		Fan	82.8	82.8	81.4	83.5	81.6	80
22	Coke Oven-2	Near Water pumphouse area Near Battery cellar	86.7	86.9	88.9	87.3	87.5	86.8
		ventilation blower	SD	SD	SD	SD	SD	SD
		Near Battery coke oven gas	00	50	00	00	00	00
		de-graphitizing blower	SD	SD	SD	SD	SD	SD
		Pushing emission control						
		system ID fan	81.2	81.7	81.9	82.1	82.7	81.5
		Control Room Office	60	58	58.4	59.7	61.7	58.4
		Near I.D. fan-1	82.4	SD	87	86.3	86.1	SD
		Near I.D. fan-2	83.9	SD	88.3	87.5	85.3	SD
23	BFPP-2 Boiler-2	Near P.A. fan	90.8	SD	90.6	90.1	90.3	SD
		Near S.A. fan Near Boiler -2 area	90.9 84.8	SD SD	90 84.3	90.5 83.7	88.4 83.7	SD SD
		Near cooling tower-area	84.2	84.6	84.8	84.1	83.3	84.6
		Near I.D. fan-1	SD	85.1	87.5	SD	SD	83.5
		Near I.D. fan-2	SD	84.9	86.3	SD	SD	84.1
		Near P.A. fan	SD	90	89.8	SD	SD	89.7
24	BFPP-2 Boiler-3	Near S.A. fan	SD	88.6	87.9	SD	SD	88.8
		Near TG floor	90.4	89.8	89	89.9	89	87.8
		Near Blower	91.8	89.3	89.4	90.2	91.3	88.6
		Control room	58.3	60.2	62.2	60.7	62.4	58.4
		Near Boiler -3 area	SD	83.8	83.8	SD	SD	85
		Near Nitrogen compressor House-1	106.3	104.5	SD	105.7	107.4	105.9
		Near Nitrogen compressor	100.3	104.5	50	103.7	107.4	103.8
		House-2	105.8	SD	95.6	105.2	107.2	106
		Near Nitrogen compressor			00.0			
		House-3	104.9	106.3	SD	SD	108.3	106.3
		Near Air compressor House						
		area-1	108	109.6	97.3	98.2	96.7	98.9
		Near Control room office out	aa -		<b>.</b>		6 <b>-</b> -	<u> </u>
25	Oxygen Plant-02	side area	92.5	94.8	81.1	98.6	95.1	96.1
		Control Room Office Near A/ C Package room	60.4	61.5	61.2	61.8	61.1	61.9
		area	83.7	83.2	76.8	78.1	82.2	82.3
		Near Argon cold box area	81.8	81.6	81.9	79.7	80.1	82
		Near cooling tower	80.5	79.3	70.4	75.3	81.4	81.9
		Near 340 TPD new						
		compressor House exit	81.4	89.5	89.8	88.9	89.9	87.5
		Near 340 TPD new	85.9	89.2			_	
		compressor House Entrance			90.8	89.6	90.2	91.8

	1	Neer 1120 TDD eir		1	1			
		Near 1120 TPD air compressor house	87.3	86.8	100	97.6	98.3	98.9
		Pump House area	85.8	86	83.6	84.8	86.1	86.5
		Near Turbine-1 area	85.1	84.9	84.5	84.7	84.5	83.7
		Near BB Plant Bunker ID fan-1	80	82.7	81.4	83.5	82.1	0011
		Near BB Plant flux building ID	00	02.1	01.1	00.0	02.1	
		fan-2	83.2	83.9	82.6	82.4	83.6	
		Near BB Plant crushing &	00.2	00.0	02.0	02.1	00.0	
		screening building	80.2	79.8	80	81.5	80.5	
	BB Plant	Near BB Plant coke screening						
		building	79.7	79.3	80.1	79.2	81.4	
		Near BB Plant compressor						
		house 1 & 2	82.8	SD	SD	SD	SD	
26		BB Plant Office	59.5	59.7	59.4	59.3	58.8	
		Near CSB-1 I D Fan	81.7	SD	83	82.5	SD	83.5
		Near CSB-2   D Fan	SD	85.1	84.1	85.1	SD	84.9
		Near BB plant site office	78.5	80.3	79.3	78.6	77.9	80.2
		Near P.C.S building	80	81.5	78.4	80.9	SD	81.1
		Near T.C.S building	79.6	81.7	80	81.6	SD	82.3
27	RMPP	Near S.C.S building	79.8	82	79.9	81.4	SD	80.7
		Control Room Office	58.7	56	58.4	58.1	60.7	58.5
		Near Pumphouse Area	80.4	80.5	83.4	81.2	80.6	81.1
		Near O.P.S building	81.8	81.4	82.6	81.5	80.1	80.6
		Near O.S.C building	82.5	82.4	82	81.7	79.6	80.4
		Near O.T.C building	83	82.6	81.5	82.3	83.5	83.6
		Near Entrance Point	84.1	82.1	83.8	84.2	84.5	83.5
	110 MW Compressor	Near Compressor	90.2	92.3	90.7	91.5	92.3	92.8
	House AEL	Inside Operator office	79.7	80.3	75.1	80	75.9	80.3
28		Near Entrance Point	85.1	84.4	84.5	85.8	85.2	85.1
	150 MW Ash	Near Compressor	91.7	90.4	91	92	90.3	93.6
	Conveying Compressor House AEL	•	-					
	House ALL	Inside Operator office	81.4	80.6	76.3	79.9	76.5	81.4
	165 MW Comprossor	Near Entrance Point	81.7	82.5	79.3	81.5	85.1	80.5
29	165 MW Compressor House AEL	Near Compressor	92	90.3	92	91.7	91.9	92.8
	110430 7122	Inside Operator office	78.6	77.5	69.2	80.2	80.1	80.4
		CFBC Boiler-1						
		Near ID Fan-1	SD	SD	SD	SD	SD	SD
		Near ID Fan-2	SD	SD	SD	SD	SD	SD
		Near S A Fan	SD	SD	SD	SD	SD	SD
					-		-	
		Near P.A. Fan	SD	SD	SD	SD	SD	SD
		Near Boiler -1 Area	SD	SD	SD	SD	SD	SD
		CFBC- Boiler-2		1	1	1	1	
		Near ID Fan-1	SD	85.4	85.9	SD	SD	85.9
		Near ID Fan-2	SD	85.8	86	SD	SD	85.7
30	300 MW Power Plant AEL	Near S A Fan	SD	91	95.5	SD	SD	91.3
		Near P.A. Fan	SD	91.1	96	SD	SD	91.5
		Near Boiler -2 Area	SD	84.5	84.9	SD	SD	85.8
		CFBC- Boiler-3	50	04.5	04.3	50	50	0.00
		Near ID Fan-1	85.8	84.9	86.8	85.1	SD	85.2
		Near ID Fan-2	86.1	85.1	86.2	85.4	SD	85.9
		Near S A Fan	90.7	90.4	94.5	94.1	SD	91.8
		Near P.A. Fan	90.9	91.6	94.3	94.7	SD	91.2
		Near Boiler -3 Area	85.6	85.1	84.8	84.1	SD	85
		CFBC- Boiler-4						
	1	Near ID Fan-1	85.4	SD	84.1	84.4	SD	85.1

	1	Near ID Fan-2	86	SD	83.6	84	SD	85.4
		Near S A Fan	90.5	SD	94.3	93.7	SD	92
		Near P.A. Fan	91	SD	93.7	94.2	SD	91.3
		Near Boiler -4	85.2	SD	83.9	84.6	SD	85.8
		CFBC- Boiler-5						
		Near ID Fan-1	78.2	80	83.1	80.4	80.3	SD
		Near ID Fan-2	79.3	80.3	82.6	80.5	80.5	SD
		Near S A Fan	92.1	91.7	87.1	91.5	91.7	SD
		Near P.A. Fan	91.3	91.5	88.8	91.1	91.5	SD
		Near Boiler -5	85.4	85.8	84.7	85.1	85.1	SD
		CFBC- Boiler-6						
	185 MW Power	Near ID Fan-1	80	80.8	SD	80.1	81.6	SD
	Plant AEL	Near ID Fan-2	80.2	81.6	SD	80.4	80.7	SD
		Near S A Fan	91.5	91	SD	90.5	91.6	SD
		Near P.A. Fan	90.8	91.6	SD	91.4	91.4	SD
		Near Boiler -6	86	85.4	SD	85.3	83.9	SD
		Near Silo Area	84.8	84.3	84.5	83.5	83.7	82.5
		Near 150 MW TG	91.1	90.4	89.8	90.1	90	90.1
		Near 165 MW TG	91.5	90.2	90.6	90	89.6	90.5
		Control Room Office	59.3	61.5	61.8	61.8	59.3	60.8
		Hammer Building Area	84.3	83.6	80	81.5	80.2	81.1
	Coal Washary	Screening Building	80	80.6	79.5	81	81.9	80.4
21	cour reasinary	Power Plant Feeding Silo	83.5	82.4	82.7	83.6	82.8	84.2
31		Lab & Office Area	58.1	59.1	58.9	58.5	59.3	58.9
		Yard No-1 to 4	78.1	78.4	78.5	78.7	80	80.1
		Yard No-5 to 6	79.3	79.9	79.3	79.8	80.2	80.3
		Near 3 EP-2 RMHS-III	CO 4	<u> </u>	<u> </u>	00.4	70 5	04.0
		Electrical Building	68.4	60.3	60	80.1	72.5	81.6
		RMHS Office	59.1	58.4	58.2	59.4	58.8	58.7
		Wagon Tippler -1	SD	81.5	SD	82.1	SD	SD
	RMHS	Wagon Tippler -4	80	81.7	80.4	SD	SD	82
		Wagon Tippler -3	80.1	82.1	SD	81.6	SD	SD
		Wagon Tippler -2	79.6	81	SD	SD	SD	SD
		Tunnel area	81.2	83.3	82.3	83.1	SD	83.4
		RMHS-2 offline crusher Screen	OF 1	04.0	00.0	0.2	۲D	02.2
		area	85.1	84.8	80.8	82	SD	83.3
32		RMHS-2 offline crusher area	81.2	81.5	84.5	84.8	SD	84.8
		Entrance of air compressor house gate 1	82.1	81.4	82.1	81.5	81.5	82.6
		Entrance of air compressor			0	01.0	01.0	02.0
		gate 2	83.7	82.5	81.8	81.3	81.6	82.3
		Inside store cum rest house	80	78.7	71.5	79.5	80	80.6
	CCH 2	Inside compressor house	91.7	93.7	92.4	90.2	91.8	96.1
		Near air compressor	93.5	96.1	95.2	93.5	92.3	96.9
		Inside office area	76.9	59.4	59.8	59.3	58.5	60.3
_		Inside compressor operator						
33		cabin	80.3	79.3	78.5	78	80.4	80.7
	BFPP2 ash	Entrance of air compressor		_	_			
	conveying	house	84.3	83.1	83.4	83.3	83.2	83.6
24	compressor house	Inside compressor house	87.1	85.1	85	85.1	85.7	85.3
34		Near air compressor	88.6	87.3	86.2	86.5	86.8	86.1

35		Crusher Tata office						
	(container)		58	57	58.1	58.6	58	58.7
		Entrance of Weigh Bridge	70.2	81.5	79.2	82	80.2	80.6
		Scraped Yard	81	80.6	81.2	83.2	82.1	82
		New Sarpa MRP-II						
		(Operator Cabin)	59.3	58.3	59.7	59.3	58	SD
		New MRP Screen-II-New						
		MRP	81.1	81.1	78.8	80.2	80.4	SD
		New MRP Screen-I-New						
	IBMD	MRP	81.2	80.4	79.2	80.4	81.2	SD
		New MRP-Loading Point						
		Area	83.5	82.7	81.9	81.6	82.2	SD
		Office & Operator Cabin						
		(Old MRP)	59.7	59.2	60.1	58.1	58.8	58.4
		Old MRP Screen-I&II-New						
		MRP	80.6	80.5	80.8	81.5	81.5	80.8
		Old MRP Screen-III-New						
		MRP	80.4	80.7	79.9	80.1	81	80.5
		Old MRP-Loading Point	82.5	81	81.3	81.5	82.4	81.7

Address of Laboratory : Building No. P- 48, Udayan Industrial Estate, 3, Pagladanga Road, Kolkata 700015 West Bengal Tel. : +91 7044036120 Email: udayanlab@mitrask.com

#### Name & Address of Customer :

TATA STEEL LTD.

NH-55, NARENDRAPUR, MERAMANDLI, DHENKANAL ODISHA India Pin 759129

TC-6950

#### **TEST REPORT**

Report No. : Date : Sample No. : Date of receipt of sample: Date(s) of performance: Location of performance of Reference No. & Date : **Discipline:** 

MSKPL/ED/2024-25/8N6A9S 22/05/2024 MSKNB/ED/2024-25/05/TG432G 20/05/2024 20/05/2024 - 22/05/2024 Permanent Facility 3000151489/A06, Date - 01/04/2023

We hereby certify that the following sample Drawn by us has been analyzed with the following results:

1. Group	Atmospheric Pollution
2. Description of sample	
3. Unique Identification of sample(if any)	Ambient Air NA
4. Date of sampling	17/05/2024
5. Place of sampling	
6. Environmental conditions during sampling & Transport	1) Temperature :25-36 deg C 2) Barometric Pressure: 754 mm of Hz 2) Bain fall :
7. Sampling Plan & Method used	No & Cold Chain Maintained IS:5182(P-2,6,10,23, 24)
8. Identification of the personnel performing sampling by MSK	Ananda Sahoo
9. Field Equipments Used	MSK/BBSR/FIELD/FDS-5, MSK/BBSR/FIELD/RDS-05

#### Report No. : MSKPL/ED/2024-25/8N6A9S

**RESULT** 

Sample No. : MSKNB/ED/2024-25/05/TG432G

Chemical

hemio	al	Sections.			
SI No.	Parameter	UOM	Method	Limit	Result
1	Carbon monoxide (as CO)	mg/m3	IS 5182 (Part 10) (NDIR)	2 (8 Hours)	
2	Fine Particulate Matter (PM2.5)	micro gm/m3	IS 5182 (Part 24)	60 (24 Hours)	0.47
3	Oxides of Nitrogen as (NO2)	micro gm/m3	IS 5182 (Part 6)	80 (24 Hours)	38.3
4	PM10(Particulate Matter<10 µm)/Respirable Suspended Particulate Matter Cyclonic technique	micro gm/m3	IS 5182 (Part 23)	100 (24 Hours)	33.9
5	Sulphur Dioxide as (SO2)	micro gm/m3	IS 5182 (Part 2)	80 (24 Hours)	6.6

Limit as per CPCB notification, New Delhi, 18th November 2009, for Ambient air quality

Statement of Conformity NA

--- END -----

Reviewed By:

Signature Name

Designation : Technical In charge Authorized Signator Signature Name Designation Lab In charge

The results relate only to the item(s) tested.

10

Mr. Pradib Bad

This Test Report shall not be reproduced except in full, without the permission of Mitra S.K. Private Limited.

This rest report shall not be reproduced except in full, without the permission of Mitra S.K. Private Limited. The reserved part of sample(s) for chemical analysis (Non - perishable sample(s) Food, Water) shall be retained for 15 days from the date of issue of the Test Report. Perishable sample(s) shall be retained 2 days from the date of issue of the Test Report. The reserved part of sample(s) for chemical analysis (Soil, Solid & Liquid Waste) shall be retained for 15 days as per CPCB guideline & (Air) 1 month from the date of issue of the Test Report. The reserved part of sample(s) for Microbiological analysis (Non - perishable sample(s) Food, Sealed Water, Sealed food) shall be retained for 15 days from the date of issue of the Test Report.

Shrachi Centre (5th Floor), 74B, A.J.C. Bose Road, Kolkata - 700016, West Bengal, India. Head Office: Tel. : 91 33 40143000 / 22650007 Fax : 91 33 22650008 Email : info@mitrask.com Website : www.mitrask.com





Scan for Portal

ULR: TC-695024000009350F

Address of Laboratory :

Building No. P- 48, Udayan Industrial Estate. 3, Pagladanga Road, Kolkata 700015 West Bengal Tel. : +91 7044036120 Email: udayanlab@mitrask.com

#### Name & Address of Customer :

TATA STEEL LTD.

NH-55, NARENDRAPUR, MERAMANDLI, DHENKANAL ODISHA India Pin 759129



#### **TEST REPORT**

Report No. : Date : Sample No. : Date of receipt of sample: Date(s) of performance: Location of performance of Reference No. & Date : **Discipline:** 

MSKPL/ED/2024-25/2F6A9E 22/05/2024 MSKNB/ED/2024-25/05/RR434U 20/05/2024 20/05/2024 - 22/05/2024 Permanent Facility 3000151489/A06, Date - 01/04/2023 Chemical

Scan for Portal

ULR: TC-695024000009349F

We hereby certify that the following sample Drawn by us has been analyzed with the following results:

1. Group	Atmospheric Pollution
2. Description of sample	Ambient Air
3. Unique Identification of sample(if any)	NA
4. Date of sampling	17/05/2024
5. Place of sampling	Kochilamara
6. Environmental conditions during sampling & Transport	1) Temperature :25-36 deg C 2) Barometric Pressure: 754 mm of Hg 3) Pain fell
7. Sampling Plan & Method used	No & Cold Chain Maintained IS:5182(P-2,6,10,23, 24)
8. Identification of the personnel performing sampling by MSK	Ananda Sahoo
9. Field Equipments Used	MSK/BBSR/FIELD/FDS-9, MSK/BBSR/FIELD/RDS-09

#### Report No. : MSKPL/ED/2024-25/2F6A9E

Sample No. : MSKNB/ED/2024-25/05/RR434U

RES	111	T
I VILO	VI	na B

SI No.	Parameter	UOM	Method	Limit	Result
1	Carbon monoxide (as CO)	mg/m3	IS 5182 (Part 10) (NDIR)	2 (8 Hours)	0.41
2	Fine Particulate Matter (PM2.5)	micro gm/m3	IS 5182 (Part 24)	60 (24 Hours)	34.1
3	Oxides of Nitrogen as (NO2)	micro gm/m3	IS 5182 (Part 6)	80 (24 Hours)	
4	PM10(Particulate Matter<10 μm)/Respirable Suspended Particulate Matter Cyclonic technique	micro gm/m3	IS 5182 (Part 23)	100 (24 Hours)	<u>35.4</u> 77.0
5	Sulphur Dioxide as (SO2)	micro gm/m3	IS 5182 (Part 2)	80 (24 Hours)	BDL(DL:6.0)

Limit as per CPCB notification, New Delhi, 18th November 2009, for Ambient air quality

Statement of Conformity NA

-- END -----

Reviewed By:

Signature Name Мг

Designation Technical In charge

Authorized Signatory Signature Name umvadeep N Designation Lab In charge

Pradio Bad

The results relate only to the item(s) tested. This Test Report shall not be reproduced except in full, without the permission of Mitra S.K. Private Limited.

The reserved part of sample(s) for chemical analysis (Non - perishable sample(s) Food, Water) shall be retained for 15 days from the date of issue of the Test Report. Perishable sample(s) shall be retained 2 days from the date of issue of the Test Report. The reserved part of sample(s) for chemical analysis (Soil, Solid & Liquid Waste) shall be retained for 15 days as per CPCB guideline & (Air) 1 month from the date of issue of the Test Report. The reserved part of sample(s) for Microbiological analysis (Non - perishable sample(s) Food, Sealed Water, Sealed food) shall be retained for 15 days from the date of issue of the Test Report.

Shrachi Centre (5th Floor), 74B, A.J.C. Bose Road, Kolkata - 700016, West Bengal, India. Head Office: Tel. : 91 33 40143000 / 22650007 Fax : 91 33 22650008 Email : info@mitrask.com Website : www.mitrask.com





Address of Laboratory : Building No. P- 48, Udayan Industrial Estate, 3, Pagladanga Road, Kolkata 700015 West Bengal Tel. : +91 7044036120 Email: udayanlab@mitrask.com

#### Name & Address of Customer :

TATA STEEL LTD.

NH-55, NARENDRAPUR, MERAMANDLI, DHENKANAL ODISHA India Pin 759129

TC-6950

### TEST REPORT

Report No. : Date : Sample No. : Date of receipt of sample: Date(s) of performance: Location of performance of Reference No. & Date : **Discipline:** 

MSKPL/ED/2024-25/SM6A9E 22/05/2024 MSKNB/ED/2024-25/05/KV435J 20/05/2024 20/05/2024 - 22/05/2024 Permanent Facility 3000151489/A06, Date - 01/04/2023

We hereby certify that the following sample Drawn by us has been analyzed with the following results:

1. Group	Atmospheric Pollution
2. Description of sample	Ambient Air
3. Unique Identification of sample(if any)	NA
4. Date of sampling	17/05/2024
5. Place of sampling	Khaliberana
6. Environmental conditions during sampling & Transport	1) Temperature :25-36 deg C 2) Barometric Pressure: 754 mm of Hg 3) Rain fall : No & Cold Chain Maintained
7. Sampling Plan & Method used	IS:5182(P-2,6,10,23, 24)
8. Identification of the personnel performing sampling by MSK	Ananda Sahoo
9. Field Equipments Used	MSK/BBSR/FIELD/FDS-11, MSK/BBSR/FIELD/RDS-11

#### Report No. : MSKPL/ED/2024-25/SM6A9E

Sample No. : MSKNB/ED/2024-25/05/KV435J

Chemical

#### RESULT

Chemical SI No. Parameter UOM Method Limit Result 1 Carbon monoxide (as CO) mg/m3 IS 5182 (Part 10) (NDIR) 2 (8 Hours) 0.57 2 Fine Particulate Matter (PM2.5) micro gm/m3 IS 5182 (Part 24) 60 (24 Hours) 47.3 Oxides of Nitrogen as (NO2) 3 micro gm/m3 IS 5182 (Part 6) 80 (24 Hours) 32.9 PM10(Particulate Matter<10 4 µm)/Respirable Suspended Particulate micro gm/m3 IS 5182 (Part 23) 100 (24 Hours) 84.7 Matter Cyclonic technique 5 Sulphur Dioxide as (SO2) micro gm/m3 IS 5182 (Part 2) 80 (24 Hours) 7.1

-- END ------

Opinion :

Statement of Conformity NA

Limit as per CPCB notification, New Delhi, 18th November 2009, for Ambient air quality

Reviewed By:

Signature Name

Designation Technical In charge Authorized Signator Signature

Name Designation Lab In charge

The results relate only to the item(s) tested

This Test Report shall not be reproduced except in full, without the permission of Mitra S.K. Private Limited. The reserved part of sample(s) for chemical analysis (Non - perishable sample(s) Food, Water) shall be retained for 15 days from the date of issue of the Test Report. Perishable sample(s) shall be retained 2 days from the date of issue of the Test Report. The reserved part of sample(s) for chemical analysis (Soil, Solid & Liquid Waste) shall be retained for 15 days as per CPCB guideline & (Air) 1 month from the date of issue of the Test Report. The reserved part of sample(s) for Microbiological analysis (Non - perishable sample(s) Food, Sealed Water, Sealed food) shall be retained for 15 days from the date of issue of the Test Report.

Shrachi Centre (5th Floor), 74B, A.J.C. Bose Road, Kolkata - 700016, West Bengal, India. Tel. : 91 33 40143000 / 22650007 Fax : 91 33 22650008 Head Office: Email : info@mitrask.com Website : www.mitrask.com





Scan for Portal

ULR: TC-695024000009348F

Address of Laboratory : Building No. P- 48, Udayan Industrial Estate, 3, Pagladanga Road, Kolkata 700015 West Bengal Tel. : +91 7044036120 Email: udayanlab@mitrask.com

#### Name & Address of Customer :

TATA STEEL LTD.

NH-55, NARENDRAPUR, MERAMANDLI, DHENKANAL ODISHA India Pin 759129

TC-6950

#### **TEST REPORT**

Report No. : Date : Sample No. : Date of receipt of sample: Date(s) of performance: Location of performance of Reference No. & Date : **Discipline:** 

MSKPL/ED/2024-25/Q06A9G 22/05/2024 MSKNB/ED/2024-25/05/KS430D 20/05/2024 20/05/2024 - 22/05/2024 Permanent Facility 3000151489/A06, Date - 01/04/2023 Chemical

We hereby certify that the following sample Drawn by us has been analyzed with the following results:

1. Group	Atmospheric Pollution
2. Description of sample	Ambient Air
3. Unique Identification of sample(if any)	NA
4. Date of sampling	17/05/2024
5. Place of sampling	Mangalour
6. Environmental conditions during sampling & Transport	1) Temperature :25-36 deg C 2) Barometric Pressure: 754 mm of Hg 3) Bain fall :
7. Sampling Plan & Method used	No & Cold Chain Maintained IS:5182(P-2,6,10,23, 24)
8. Identification of the personnel performing sampling by MSK	Ananda Sahoo
9. Field Equipments Used	MSK/BBSR/FIELD/FDS-3, MSK/BBSR/FIELD/RDS-03

#### Report No. : MSKPL/ED/2024-25/Q06A9G

Sample No. : MSKNB/ED/2024-25/05/KS430D

#### RESULT

Chemical SI No. Parameter UOM Method Limit Result 1 Carbon monoxide (as CO) mg/m3 IS 5182 (Part 10) (NDIR) 2 (8 Hours) 0.48 Fine Particulate Matter (PM2.5) 2 micro gm/m3 IS 5182 (Part 24) 60 (24 Hours) 38.2 3 Oxides of Nitrogen as (NO2) micro gm/m3 IS 5182 (Part 6) 80 (24 Hours) 30.6 PM10(Particulate Matter<10 4 µm)/Respirable Suspended Particulate micro gm/m3 IS 5182 (Part 23) 100 (24 Hours) 74.4 Matter Cyclonic technique 5 Sulphur Dioxide as (SO2) micro gm/m3 IS 5182 (Part 2) 80 (24 Hours) 6.7

Limit as per CPCB notification, New Delhi, 18th November 2009, for Ambient air quality

Statement of Conformity NA

- END ------

Reviewed By:

Opinion :

Signature Name

Designation : Technical In charge

Authorized Signator

Signature Name Designation Lab In charge

The results relate only to the item(s) tested. This Test Report shall not be reproduced except in full, without the permission of Mitra S.K. Private Limited.

The reserved part of sample(s) for chemical analysis (Non - perishable sample(s) Food, Water) shall be retained for 15 days from the date of issue of the Test Report. Perishable sample(s) shall be retained 2 days The reserved part of sample(s) for chemical analysis (Soil, Solid & Liquid Waste) shall be retained for 15 days as per CPCB guideline & (Air) 1 month from the date of issue of the Test Report. The reserved part of sample(s) for Microbiological analysis (Non - perishable sample(s) Food, Sealed Water, Sealed food) shall be retained for 15 days from the date of issue of the Test Report.

Shrachi Centre (5th Floor), 74B, A.J.C. Bose Road, Kolkata - 700016, West Bengal, India. Tel. : 91 33 40143000 / 22650007 Fax : 91 33 22650008 Email : info@mitrask.com Website : www.mitrask.com Head Office:





ULR: TC-695024000009347F

Address of Laboratory :

Building No. P- 48, Udayan Industrial Estate, 3, Pagladanga Road, Kolkata 700015 West Bengal Tel. : +91 7044036120 Email: udayanlab@mitrask.com

#### Name & Address of Customer :

TATA STEEL LTD.

NH-55, NARENDRAPUR, MERAMANDLI, DHENKANAL ODISHA India Pin 759129

TC-6950

#### TEST REPORT

Report No. : Date : Sample No. : Date of receipt of sample: Date(s) of performance: Location of performance of Reference No. & Date : **Discipline:** 

MSKPL/ED/2024-25/KG6A90 22/05/2024 MSKNB/ED/2024-25/05/BA431U 20/05/2024 20/05/2024 - 22/05/2024 Permanent Facility 3000151489/A06, Date - 01/04/2023 Chemical

We hereby certify that the following sample Drawn by us has been analyzed with the following results:

1. Group	Atmospheric Pollution
2. Description of sample	Ambient Air
3. Unique Identification of sample(if any)	NA
4. Date of sampling	17/05/2024
5. Place of sampling	Narandrapur
6. Environmental conditions during sampling & Transport	1) Temperature :25-36 deg C 2) Barometric Pressure: 754 mm of Hg 3) Pain fall
7. Sampling Plan & Method used	No & Cold Chain Maintained IS:5182(P-2,6,10,23, 24)
8. Identification of the personnel performing sampling by MSK	Ananda Sahoo
9. Field Equipments Used	MSK/BBSR/FIELD/FDS-4, MSK/BBSR/FIELD/RDS-04

#### Report No. : MSKPL/ED/2024-25/KG6A90

Sample No. : MSKNB/ED/2024-25/05/BA431U

#### RESULT

Chemical SI No. Parameter UOM Method Limit Result 1 Carbon monoxide (as CO) mg/m3 IS 5182 (Part 10) (NDIR) 2 (8 Hours) 0.42 2 Fine Particulate Matter (PM2.5) micro gm/m3 IS 5182 (Part 24) 60 (24 Hours) 43.3 3 Oxides of Nitrogen as (NO2) micro gm/m3 IS 5182 (Part 6) 80 (24 Hours) 41.1 PM10(Particulate Matter<10 4 µm)/Respirable Suspended Particulate micro gm/m3 IS 5182 (Part 23) 100 (24 Hours) 90.5 Matter Cyclonic technique Sulphur Dioxide as (SO2) 5 micro gm/m3 IS 5182 (Part 2) 80 (24 Hours) 7.0

**Opinion**:

Limit as per CPCB notification, New Delhi, 18th November 2009, for Ambient air quality

Statement of Conformity NA

-- END -----

Reviewed By:

Signature

Name Technical In charge

Designation

Authorized Signator Signature

Name

Designation Lab In charge

The results relate only to the item(s) tested.

This Test Report shall not be reproduced except in full, without the permission of Mitra S.K. Private Limited.

The reserved part of sample(s) for chemical analysis (Non - perishable sample(s) Food, Water) shall be retained for 15 days from the date of issue of the Test Report. Perishable sample(s) shall be retained 2 days The reserved part of sample(s) for Microbiological analysis (Non - perishable sample(s) Food, value) and for 15 days as per CPCB guideline & (Air) 1 month from the date of issue of the Test Report. The reserved part of sample(s) for Microbiological analysis (Non - perishable sample(s) Food, Sealed Water, Sealed food) shall be retained for 15 days from the date of issue of the Test Report.

Shrachi Centre (5th Floor), 74B, A.J.C. Bose Road, Kolkata - 700016, West Bengal, India. Tel. : 91 33 40143000 / 22650007 Fax : 91 33 22650008 Email : info@mitrask.com Website : www.mitrask.com Head Office:







Scan for Portal

ULR: TC-695024000009346F

Address of Laboratory : Building No. P- 48, Udayan Industrial Estate, 3, Pagladanga Road, Kolkata 700015 West Bengal Tel. : +91 7044036120 Email: udayanlab@mitrask.com

#### Name & Address of Customer :

TATA STEEL LTD.

NH-55, NARENDRAPUR, MERAMANDLI, DHENKANAL ODISHA India Pin 759129

TC-6950

**TEST REPORT** 

Report No. : Date : Sample No. : Date of receipt of sample: Date(s) of performance: Location of performance of Reference No. & Date : **Discipline:** 

MSKPL/ED/2024-25/5R6A9B 22/05/2024 MSKNB/ED/2024-25/05/AK42FA 20/05/2024 20/05/2024 - 22/05/2024 Permanent Facility 3000151489/A06, Date - 01/04/2023 Chemical

We hereby certify that the following sample Drawn by us has been analyzed with the following results:

1. Group	Atmospheric Pollution
2. Description of sample	Ambient Air
3. Unique Identification of sample(if any)	NA
4. Date of sampling	17/05/2024
5. Place of sampling	Nalachandrapur (Nalatangra)
6. Environmental conditions during sampling & Transport	1) Temperature :25-36 deg C 2) Barometric Pressure: 754 mm of Hg 3) Rain fall
7. Sampling Plan & Method used	No & Cold Chain Maintained IS:5182(P-2,6,10,23, 24)
8. Identification of the personnel performing sampling by MSK	Ananda Sahoo
9. Field Equipments Used	MSK/BBSR/FIELD/FDS-12, MSK/BBSR/FIELD/RDS-12

#### Report No. : MSKPL/ED/2024-25/5R6A9B

DECINT

Sample No. : MSKNB/ED/2024-25/05/AK42FA

hemic	al		RESOLT		
SI No.	Parameter	UOM	Method	Limit	Result
1	Carbon monoxide (as CO)	mg/m3	IS 5182 (Part 10) (NDIR)	2 (8 Hours)	0.51
2	Fine Particulate Matter (PM2.5)	micro gm/m3	IS 5182 (Part 24)	60 (24 Hours)	50.2
3	Oxides of Nitrogen as (NO2)	micro gm/m3	IS 5182 (Part 6)	80 (24 Hours)	
4	PM10(Particulate Matter<10 μm)/Respirable Suspended Particulate Matter Cyclonic technique	micro gm/m3	IS 5182 (Part 23)	100 (24 Hours)	<u> </u>
5	Sulphur Dioxide as (SO2)	micro gm/m3	IS 5182 (Part 2)	80 (24 Hours)	7.9

**Opinion**:

Limit as per CPCB notification, New Delhi, 18th November 2009, for Ambient air quality

Statement of Conformity NA

-- END -----

Reviewed By:

Signature Name

Designation Technical In charge Authorized Signatory

Signature Name Dr. Soumvadeep Designation Lab In charge

The results relate only to the item(s) tested.

This Test Report shall not be reproduced except in full, without the permission of Mitra S.K. Private Limited. The reserved part of sample(s) for chemical analysis (Non - perishable sample(s) Food, Water) shall be retained for 15 days from the date of issue of the Test Report. Perishable sample(s) shall be retained 2 days from the date of issue of the Test Report.

from the date of issue of the Test Report. The reserved part of sample(s) for chemical analysis (Soil, Solid & Liquid Waste) shall be retained for 15 days as per CPCB guideline & (Air) 1 month from the date of issue of the Test Report. The reserved part of sample(s) for Microbiological analysis (Non - perishable sample(s) Food, Sealed Water, Sealed food) shall be retained for 15 days from the date of issue of the Test Report.

Shrachi Centre (5th Floor), 74B, A.J.C. Bose Road, Kolkata - 700016, West Bengal, India. Tel. : 91 33 40143000 / 22650007 Fax : 91 33 22650008 Head Office: Email : info@mitrask.com Website : www.mitrask.com





Scan for Portal

ULR: TC-695024000009345F

Address of Laboratory :

Building No. P- 48, Udayan Industrial Estate. 3, Pagladanga Road, Kolkata 700015 West Bengal Tel. : +91 7044036120 Email: udayanlab@mitrask.com

#### Name & Address of Customer :

TATA STEEL LTD.

NH-55, NARENDRAPUR, MERAMANDLI, DHENKANAL ODISHA India Pin 759129



#### **TEST REPORT**

Date of receipt of sample:

Location of performance of

Date(s) of performance:

Reference No. & Date :

Report No. :

Sample No. :

**Discipline:** 

Date :

MSKPL/ED/2024-25/TN6A9Q 22/05/2024 MSKNB/ED/2024-25/05/4K4338 20/05/2024

20/05/2024 - 22/05/2024 Permanent Facility 3000151489/A06, Date - 01/04/2023 Chemical

We hereby certify that the following sample Drawn by us has been analyzed with the following results:

1. Group	Atmospheric Pollution
2. Description of sample	Ambient Air
3. Unique Identification of sample(if any)	NA
4. Date of sampling	17/05/2024
5. Place of sampling	Galpada
6. Environmental conditions during sampling & Transport	1) Temperature :25-36 deg C 2) Barometric Pressure: 754 mm of Hg 3) Rain fall : No & Cold Chain Maintained
7. Sampling Plan & Method used	IS:5182(P-2,6,10,23, 24)
8. Identification of the personnel performing sampling by MSK	Ananda Sahoo
9. Field Equipments Used	MSK/BBSR/FIELD/FDS-10, MSK/BBSR/FIELD/RDS-10

#### Report No. : MSKPL/ED/2024-25/TN6A9Q

Sample No. : MSKNB/ED/2024-25/05/4K4338

#### RESULT

hemio	cal				
SI No.	Parameter	UOM	Method	Limit	Result
1	Carbon monoxide (as CO)	mg/m3	IS 5182 (Part 10) (NDIR)	2 (8 Hours)	0.36
2	Fine Particulate Matter (PM2.5)	micro gm/m3	IS 5182 (Part 24)	60 (24 Hours)	40.5
3	Oxides of Nitrogen as (NO2)	micro gm/m3	IS 5182 (Part 6)	80 (24 Hours)	39.6
4	PM10(Particulate Matter<10 μm)/Respirable Suspended Particulate Matter Cyclonic technique	micro gm/m3	IS 5182 (Part 23)	100 (24 Hours)	71.6
5	Sulphur Dioxide as (SO2)	micro gm/m3	IS 5182 (Part 2)	80 (24 Hours)	6.8

Limit as per CPCB notification, New Delhi, 18th November 2009, for Ambient air quality

Statement of Conformity NA

-- END ------

Authorized Signato Signature Name Designation Lab In charge

Technical In charge

The results relate only to the item(s) tested. This Test Report shall not be reproduced except in full, without the permission of Mitra S.K. Private Limited. The reserved part of sample(s) for chemical analysis (Non - perishable sample(s) Food, Water) shall be retained for 15 days from the date of issue of the Test Report. Perishable sample(s) shall be retained 2 days The reserved part of sample(s) for the Test Report. The reserved part of sample(s) for the Test Report. Perishable sample(s) shall be retained 2 days The reserved part of sample(s) for the Test Report.

The reserved part of sample(s) for chemical analysis (Soil, Solid & Liquid Waste) shall be retained for 15 days as per CPCB guideline & (Air) 1 month from the date of issue of the Test Report. The reserved part of sample(s) for Microbiological analysis (Non - perishable sample(s) Food, Sealed Water, Sealed food) shall be retained for 15 days from the date of issue of the Test Report. Shrachi Centre (5th Floor), 74B, A.J.C. Bose Road, Kolkata - 700016, West Bengal, India.

Head Office:

Reviewed By:

Signature

Designation

Name

Tel. : 91 33 40143000 / 22650007 Fax : 91 33 22650008 Email : info@mitrask.com Website : www.mitrask.com





Scan for Portal

ULR: TC-695024000009344F

Address of Laboratory : Building No. P- 48, Udayan Industrial Estate, 3, Pagladanga Road, Kolkata 700015 West Bengal Tel. : +91 7044036120 Email: udayanlab@mitrask.com

#### Name & Address of Customer :

TATA STEEL LTD.

NH-55, NARENDRAPUR, MERAMANDLI, DHENKANAL ODISHA India Pin 759129

TC-6950

#### TEST REPORT

Report No. : Date : Sample No. : Date of receipt of sample: Date(s) of performance: Location of performance of Reference No. & Date : **Discipline:** 

MSKPL/ED/2024-25/7T6A9P 22/05/2024 MSKNB/ED/2024-25/05/1842EN 20/05/2024 20/05/2024 - 22/05/2024 Permanent Facility 3000151489/A06, Date - 01/04/2023 Chemical

Scan for Portal

ULR: TC-695024000009343F

We hereby certify that the following sample Drawn by us has been analyzed with the following results:

1. Group	Atmospheric Pollution
2. Description of sample	Ambient Air
3. Unique Identification of sample(if any)	NA
4. Date of sampling	17/05/2024
5. Place of sampling	Motanga
6. Environmental conditions during sampling & Transport	1) Temperature :25-36 deg C 2) Barometric Pressure: 754 mm of Hg 3) Rain fall : No & Cold Chain Maintained
7. Sampling Plan & Method used	IS:5182(P-2,6,10,23, 24)
8. Identification of the personnel performing sampling by MSK	Ananda Sahoo
9. Field Equipments Used	MSK/BBSR/FIELD/FDS-6, MSK/BBSR/FIELD/RDS-06

#### Report No. : MSKPL/ED/2024-25/7T6A9P

RESULT

Chemical SI No. Parameter UOM Method Limit Result 1 Carbon monoxide (as CO) IS 5182 (Part 10) (NDIR) mg/m3 2 (8 Hours) 0.49 2 Fine Particulate Matter (PM2.5) micro am/m3 IS 5182 (Part 24) 60 (24 Hours) 44.6 3 Oxides of Nitrogen as (NO2) micro gm/m3 IS 5182 (Part 6) 80 (24 Hours) 35.2 PM10(Particulate Matter<10 4 um)/Respirable Suspended Particulate micro gm/m3 IS 5182 (Part 23) 100 (24 Hours) 78.3 Matter Cyclonic technique 5 Sulphur Dioxide as (SO2) micro gm/m3 IS 5182 (Part 2) 80 (24 Hours) BDL(DL:6.0)

**Opinion**:

Limit as per CPCB notification, New Delhi, 18th November 2009, for Ambient air quality

Statement of Conformity NA

- FND

Reviewed By:

Signature 0 Name adio Bag Mr P Technical In charge Designation :

Authorized Signatory:

Signature Name Designation Lab In charge

The results relate only to the item(s) tested. This Test Report shall not be reproduced except in full, without the permission of Mitra S.K. Private Limited.

The reserved part of sample(s) for chemical analysis (Non - perishable sample(s) Food, Water) shall be retained for 15 days from the date of issue of the Test Report. Perishable sample(s) shall be retained 2 days from the date of issue of the Test Report.

The reserved part of sample(s) for Microbiological analysis (Soil, Solid & Liquid Waste) shall be retained for 15 days as per CPCB guideline & (Air) 1 month from the date of issue of the Test Report. The reserved part of sample(s) for Microbiological analysis (Non - perishable sample(s) Food, Sealed Water, Sealed food) shall be retained for 15 days from the date of issue of the Test Report.

Shrachi Centre (5th Floor), 74B, A.J.C. Bose Road, Kolkata - 700016, West Bengal, India. Tel. : 91 33 40143000 / 22650007 Fax : 91 33 22650008 Head Office: Email : info@mitrask.com Website : www.mitrask.com

ep Mukha





Sample No.: MSKNB/ED/2024-25/05/1842EN

Address of Laboratory :

Building No. P- 48, Udayan Industrial Estate, 3. Pagladanga Road, Kolkata 700015 West Bengal Tel. : +91 7044036120 Email: udayanlab@mitrask.com

#### Name & Address of Customer :

TATA STEEL LTD.

NH-55, NARENDRAPUR, MERAMANDLI, DHENKANAL **ODISHA India Pin 759129** 

# TC-6950

**TEST REPORT** 



Scan for Portal

Doc MSK/GEN/19/07

TESTING . INSPECTION

ULR: TC-695024000009342F

**Report No. :** Date : Sample No. : Date of receipt of sample: Date(s) of performance: Location of performance of Reference No. & Date : **Discipline:** 

MSKPL/ED/2024-25/6S6A9E 22/05/2024 MSKNB/ED/2024-25/05/PR42EK 20/05/2024 20/05/2024 - 22/05/2024 Permanent Facility 3000151489/A06, Date - 01/04/2023 Chemical

MSKNB/ED/2024-25/05/PR42EK

We hereby certify that the following sample Drawn by us has been analyzed with the following results:

1. Group	Atmospheric Pollution		
2. Description of sample	Noise		
3. Unique Identification of sample(if any)	NA		
4. Date of sampling	17/05/2024		
5. Place of sampling	Motanga		
6. Environmental conditions during sampling & Transport	NA		
7. Sampling Plan & Method used	IS 9989:1988		
8. Identification of the personnel performing sampling by MSK	Ananda Sahoo		
9. Field Equipments Used	MSK/BBSR/FIELD/SLM-01		

Report No. : MSKPL/ED/2024-25/6S6A9E

Chemical SI No. Parameter UOM Method Result 51.4 Leq dB(A) day IS 9989 1 dB(A) 2 Leq dB(A) night dB(A) IS 9989 45.7 NA

RESULT

Sample No. :

**Opinion**:

Statement of Conformity NA

- END -----

Reviewed By: Signature Name Pradio Bad Mr

Authorized Signatory: Sign

Nan

Des

ature	8	000	
е	ŧ	Dr. Sodmyadeep Mukhopadhyay	
gnation	:	Lab In charge	

The results relate only to the item(s) tested.

Designation : Technical In charge

2

This Test Report shall not be reproduced except in full, without the permission of Mitra S.K. Private Limited. The reserved part of sample(s) for chemical analysis (Non - perishable sample(s) Food, Water) shall be retained for 15 days from the date of issue of the Test Report. Perishable sample(s) shall be retained 2 days from the date of issue of the Test Report. The reserved part of sample(s) for chemical analysis (Soil, Solid & Liquid Waste) shall be retained for 15 days as per CPCB guideline & (Air) 1 month from the date of issue of the Test Report.

The reserved part of sample(s) for Microbiological analysis (Non - perishable sample(s) Food, Sealed Water, Sealed food) shall be retained for 15 days from the date of issue of the Test Report. Shrachi Centre (5th Floor), 74B, A.J.C. Bose Road, Kolkata - 700016, West Bengal, India. Tel. : 91 33 40143000 / 22650007 Fax : 91 33 22650008 Head Office:

Email : info@mitrask.com Website : www.mitrask.com

Address of Laboratory :

Building No. P- 48, Udayan Industrial Estate, 3, Pagladanga Road, Kolkata 700015 West Bengal Tel.: +91 7044036120 Email: udayanlab@mitrask.com

#### Name & Address of Customer :

TATA STEEL LTD.

NH-55, NARENDRAPUR, MERAMANDLI, DHENKANAL **ODISHA India Pin 759129** 

TEST REPORT

**Report No. :** Date : Sample No. : Date of receipt of sample: Date(s) of performance: Location of performance of Reference No. & Date : **Discipline:** 

MSKPL/ED/2024-25/AJ6A9C 22/05/2024 MSKNB/ED/2024-25/05/MU42EE 20/05/2024 20/05/2024 - 22/05/2024 Permanent Facility 3000151489/A06, Date - 01/04/2023 Chemical

MSKNB/ED/2024-25/05/MU42EE

Scan for Portal

ULR: TC-695024000009341F

We hereby certify that the following sample Drawn by us has been analyzed with the following results:

1. Group	Atmospheric Pollution		
2. Description of sample	Noise		
3. Unique Identification of sample(if any)	NA		
4. Date of sampling	16/05/2024		
5. Place of sampling	Ganthigadia		
6. Environmental conditions during sampling & Transport	NA		
7. Sampling Plan & Method used	IS 9989:1988		
8. Identification of the personnel performing sampling by MSK	Ananda Sahoo		
9. Field Equipments Used	MSK/BBSR/FIELD/SLM-01		

#### MSKPL/ED/2024-25/AJ6A9C Report No. :

NA

Chemical						
SI No.	Parameter	UOM	Method	Result		
1	Leq dB(A) day	dB(A)	IS 9989	49.6		
2 .	Leq dB(A) night	dB(A)	IS 9989	46.4		

RESULT

**Opinion**:

Statement of Conformity NA

- END -----

Reviewed By:	
Signature	ŝ

Name Pradip Bag Mr Designation : Technical In charge

0

Authorized Signatory:

Signature	ž	000	
Name		Dr. Soumyedeep Mukhopa	adilyay
Designation		Lab In charge	

The results relate only to the item(s) tested.

This Test Report shall not be reproduced except in full, without the permission of Mitra S.K. Private Limited. The reserved part of sample(s) for chemical analysis (Non - perishable sample(s) Food, Water) shall be retained for 15 days from the date of issue of the Test Report. Perishable sample(s) shall be retained 2 days from the date of issue of the Test Report.

The reserved part of sample(s) for Chemical analysis (Soil, Solid & Liquid Waste) shall be retained for 15 days as per CPCB guideline & (Air) 1 month from the date of issue of the Test Report. The reserved part of sample(s) for Microbiological analysis (Non - perishable sample(s) Food, Sealed Water, Sealed food) shall be retained for 15 days from the date of issue of the Test Report. Shrachi Centre (5th Floor), 74B, A.J.C. Bose Road, Kolkata - 700016, West Bengal, India. Tel. : 91 33 40143000 / 22650007 Fax : 91 33 22650008 Head Office:

Email : info@mitrask.com Website : www.mitrask.com





Sample No. :

Building No.D5, Unit No- 230, Bhumi World Industrial Park, Mumbai, Nashik Highway, Pimplas Village, Bhiwandi, Near Kalyan Bhiwandi Bypass, Tal - Bhiwandi Dist. Thane- 421302. Tel. : 0252 2672352. Email: mumbailab@mitrask.com Web : www.mitrask.com

#### MSK TESTING INSPECTION

#### **TEST REPORT**

Name & Address of the Customer: TATA STEEL LTD. NH-55, NARENDRAPUR, MERAMANDLI DHENKANAL, Odisha-759129 India

Report No. Date Sample No. Date of receipt of sample Date(s) of performance Location of performance of Ref. No. & Date Discipline

: MSKGL/ED/2024-25/002239 : 10.07.2024 : MSKGL/ED/2024-25/06/00689 : 13.06.2024 : 13.06.2024 - 18.06.2024 : Permanent Facility : 3000148695/A06 : Chemical

We hereby certify that the following sample drawn by us from the customer has been analyzed with the following results: ANALYSIS RESULT

1. Group	Atmospheric Pollution
2. Description of sample	Noise
3. Unique Identification of sample(if any)	NA
4. Date of sampling	12/06/2024
5. Place of sampling	Caaqms-1(Colony)
6. Environmental conditions during sampling & Transport	NA
7. Sampling Plan & Method used	IS 9989:1981
8. Identification of the personnel performing sampling by MSK	Ananda Sahoo
9. Field Equipments Used	MSK/BBSR/FIELD/SLM-03

#### Report No. : MSKGL/ED/2024-25/002239

Sample No. : MSKGL/ED/2024-25/06/00689

#### RESULT

Chemi	Chemical							
SI No.	Parameter	UOM	Method	Result	Zone	Limit as per CPCB at Day (06.00-22.00)	Limit as per CPCB at Night (22.00-06.00)	
1	Leq dB(A) day	dB(A)	IS 9989	68.1	Industrial	75		
2	Leq dB(A) night	dB(A)	IS 9989	62.0	Industrial	22	70	

**Opinion** : NA

Statement of Conformity : NA

End

**Reviewed By:** 

Signature

Designation.

Name

Avanta icuma Rosti

: Mr. Ananta Kumar Rath. : Operational Manager

Authorized Signatory For Mitra S.K. Private Limited

Signature Name Designation

Avanta kuma Rostn : Mr. Ananta Kumar Rath.

: Operational Manager

- The results relate only to the item(s) tested.
- This Test Report shall not be reproduced except in full, without the permission of Mitra S.K. Private Limited.
- . The reserved part of sample(s) shall be retained for 10 days & 1 years (Air) from the date of issue of the Test Report.

Head Office: Shrachi Centre (5th floor), 74B, A.J.C. Bose Road, Kolkata - 700 016. West Bengal, India. Tel. : 91 33 40143000 / 22650006 / 22650007 Fax : 91 33 22650008 Email : info@mitrask.com. Website: www.mitrask.com

Page 1of 1

Building No.D5, Unit No- 230, Bhumi World Industrial Park. Mumbai, Nashik Highway, Pimplas Village, Bhiwandi, Near Kalyan Bhiwandi Bypass, Tal - Bhiwandi Dist. Thane- 421302. Tel. : 0252 2672352. Email: mumbailab@mitrask.com Web : www.mitrask.com

## TESTING . INSPECTION

#### **TEST REPORT**

Name & Address of the Customer: TATA STEEL LTD. NH-55, NARENDRAPUR, MERAMANDLI DHENKANAL, Odisha-759129 India

Report No. Date Sample No. Date of receipt of sample Date(s) of performance Location of performance of Ref. No. & Date Discipline

: MSKGL/ED/2024-25/002240 : 10.07.2024 : MSKGL/ED/2024-25/06/00949 : 14.06.2024 : 14.06.2024 - 19.06.2024 : Permanent Facility : 3000148695/A06 : Chemical

We hereby certify that the following sample drawn by us from the customer has been analyzed with the following results: ANALYSIS RESULT

1. Group	Atmospheric Pollution
2. Description of sample	Noise
3. Unique Identification of sample(if any)	NA
4. Date of sampling	13/06/2024
5. Place of sampling	Caaqms-2(AEL)
6. Environmental conditions during sampling & Transport	NA
7. Sampling Plan & Method used	IS 9989:1981
8. Identification of the personnel performing sampling by MSK	Ananda Sahoo
9. Field Equipments Used	MSK/BBSR/FIELD/SLM-03

Report No. : MSKGL/ED/2024-25/002240

Sample No. : MSKGL/ED/2024-25/06/00949

#### RESULT

Chemical								
SI No.	Parameter	UOM	Method	Result	Zone	Limit as per CPCB at Day (06.00-22.00)	Limit as per CPCB at Night (22.00-06.00)	
1	Leq dB(A) day	dB(A)	IS 9989	70.0	Industrial	75		
2	Leq dB(A) night	dB(A)	IS 9989	64.2	Industrial		70	

**Opinion** : NA

Statement of Conformity : NA

End

**Reviewed By:** 

Signature Name Designation.

Ananta kum Rath

: Mr. Ananta Kumar Rath : Operational Manager

Authorized Signatory For Mitra S.K. Private Limited Ananta Kuma Rath Signature Name : Mr. Ananta Kumar Rath

Designation

: Operational Manager

- The results relate only to the item(s) tested.
- This Test Report shall not be reproduced except in full, without the permission of Mitra S.K. Private Limited,
- The reserved part of sample(s) shall be retained for 10 days & 1 years (Air) from the date of issue of the Test Report.

Head Office: Shrachi Centre (5th floor), 74B, A.J.C. Bose Road, Kolkata - 700 016. West Bengal, India. Tel. : 91 33 40143000 / 22650006 / 22650007 Fax : 91 33 22650008 Email : info@mitrask.com. Website: www.mitrask.com

Page 1of 1

Building No.D5, Unit No- 230, Bhumi World Industrial Park, Mumbai, Nashik Highway, Pimplas Village, Bhiwandi, Near Kalyan Bhiwandi Bypass,Tal - Bhiwandi Dist. Thane- 421302. Tel. : 0252 2672352. Email: <u>mumbailab@mitrask.com</u> Web : www.mitrask.com

## 

#### **TEST REPORT**

Name & Address of the Customer: TATA STEEL LTD. NH-55, NARENDRAPUR,MERAMANDLI DHENKANAL,Odisha-759129 India Report No. Date Sample No. Date of receipt of sample Date(s) of performance Location of performance of Ref. No. & Date Discipline : MSKGL/ED/2024-25/002241 : 10.07.2024 : MSKGL/ED/2024-25/06/00960 : 18.06.2024 : 18.06.2024 - 22.06.2024 : Permanent Facility : 3000148695/A06 : Chemical

We hereby certify that the following sample drawn by us from the customer has been analyzed with the following results: <u>ANALYSIS RESULT</u>

1. Group	Atmospheric Pollution
2. Description of sample	Noise
3. Unique Identification of sample(if any)	NA
4. Date of sampling	17/06/2024
5. Place of sampling	Caaqms-3(CRM)
6. Environmental conditions during sampling & Transport	NA
7. Sampling Plan & Method used	IS 9989:1981
8. Identification of the personnel performing sampling by MSK	Ananda Sahoo
9. Field Equipments Used	MSK/BBSR/FIELD/SLM-03

Report No. : MSKGL/ED/2024-25/002241

Sample No. : MSKGL/ED/2024-25/06/00960

#### RESULT

Chemical								
SI No.	Parameter	UOM	Method	Result	Zone	Limit as per CPCB at Day (06.00-22.00)	Limit as per CPCB at Night (22.00-06.00)	
1	Leq dB(A) day	dB(A)	IS 9989	66.7	Industrial	75		
2	Leq dB(A) night	dB(A)	IS 9989	63.6	Industrial		70	

**Opinion** : NA

Statement of Conformity : NA

End

**Reviewed By:** 

Signature

Designation.

Name

Avanta kuma pots

: Mr. Ananta Kumar Rath : Operational Manager Authorized Signatory For Mitra S.K. Private Limited

Signature Name Designation

Ananto Kuma Roth : Mr. Ananta Kumar Rath

: Operational Manager

- The results relate only to the item(s) tested.
- This Test Report shall not be reproduced except in full, without the permission of Mitra S.K. Private Limited.
- The reserved part of sample(s) shall be retained for 10 days & 1 years (Air) from the date of issue of the Test Report.

Head Office: Shrachi Centre (5th floor), 74B, A.J.C. Bose Road, Kolkata - 700 016. West Bengal, India. Tel. : 91 33 40143000 / 22650006 / 22650007 Fax : 91 33 22650008 Email : info@mitrask.com. Website: www.mitrask.com

Building No.D5, Unit No- 230, Bhumi World Industrial Park, Mumbai, Nashik Highway, Pimplas Village, Bhiwandi, Near Kalyan Bhiwandi Bypass,Tal - Bhiwandi Dist. Thane- 421302. Tel. : 0252 2672352. Email: <u>mumbailab@mitrask.com</u> Web : www.mitrask.com

#### 

#### **TEST REPORT**

Name & Address of the Customer: TATA STEEL LTD. NH-55, NARENDRAPUR, MERAMANDLI DHENKANAL, Odisha-759129 India Report No. Date Sample No. Date of receipt of sample Date(s) of performance Location of performance of Ref. No. & Date Discipline : MSKGL/ED/2024-25/002242 : 10.07.2024 : MSKGL/ED/2024-25/06/00962 : 19.06.2024 : 19.06.2024 - 23.06.2024 : Permanent Facility : 3000148695/A06 : Chemical

We hereby certify that the following sample drawn by us from the customer has been analyzed with the following results: <u>ANALYSIS RESULT</u>

1. Group	Atmospheric Pollution
2. Description of sample	Noise
3. Unique Identification of sample(if any)	NA
4. Date of sampling	18/06/2024
5. Place of sampling	Caaqms-5(Coke Oven-2)
6. Environmental conditions during sampling & Transport	NA
7. Sampling Plan & Method used	IS 9989:1981
8. Identification of the personnel performing sampling by MSK	Ananda Sahoo
9. Field Equipments Used	MSK/BBSR/FIELD/SLM-03

#### Report No. : MSKGL/ED/2024-25/002242

Sample No. : MSKGL/ED/2024-25/06/00962

#### RESULT

Chemical								
SI No.	Parameter	UOM	Method	Result	Zone	Limit as per CPCB at Day (06.00-22.00)	Limit as per CPCB at Night (22.00-06.00)	
1	Leq dB(A) day	dB(A)	IS 9989	69.2	Industrial	75		
2	Leq dB(A) night	dB(A)	IS 9989	62.9	Industrial		70	

**Opinion** : NA

Statement of Conformity : NA

End

Reviewed By:

Signature Name Designation.

Avanta kuma Rath : Mr. Ananta Kumar Rath

: Operational Manager

Authorized Signatory For Mitra S.K. Private Limited

Signature Name Designation

Ananto icom porty : Mr. Ahanta Kumar Rath : Operational Manager

- The results relate only to the item(s) tested.
- This Test Report shall not be reproduced except in full, without the permission of Mitra S.K. Private Limited.
- The reserved part of sample(s) shall be retained for 10 days & 1 years (Air) from the date of issue of the Test Report.

Head Office: Shrachi Centre (5th floor), 74B, A.J.C. Bose Road, Kolkata - 700 016. West Bengal, India. Tel. : 91 33 40143000 / 22650006 / 22650007 Fax : 91 33 22650008 Email : info@mitrask.com. Website: www.mitrask.com

Page 1of 1

Building No.D5, Unit No- 230, Bhumi World Industrial Park, Mumbai, Nashik Highway, Pimplas Village, Bhiwandi, Near Kalyan Bhiwandi Bypass,Tal - Bhiwandi Dist. Thane- 421302. Tel. : 0252 2672352. Email: <u>mumbailab@mitrask.com</u> Web : www.mitrask.com

#### TEST REPORT

Name & Address of the Customer: TATA STEEL LTD. NH-55, NARENDRAPUR,MERAMANDLI DHENKANAL,Odisha-759129 India Report No. Date Sample No. Date of receipt of sample Date(s) of performance Location of performance of Ref. No. & Date Discipline : MSKGL/ED/2024-25/002243 : 10.07.2024 : MSKGL/ED/2024-25/06/00964 : 25.06.2024 : 25.06.2024 – 28.06.2024 : Permanent Facility : 3000148695/A06 : Chemical

We hereby certify that the following sample drawn by us from the customer has been analyzed with the following results: <u>ANALYSIS RESULT</u>

1. Group	Atmospheric Pollution
2. Description of sample	Noise
3. Unique Identification of sample(if any)	NA
4. Date of sampling	24/06/2024
5. Place of sampling	Caaqms-4(HSM Water Complex)
6. Environmental conditions during sampling & Transport	NA
7. Sampling Plan & Method used	IS 9989:1981
8. Identification of the personnel performing sampling by MSK	Ananda Sahoo
9. Field Equipments Used	MSK/BBSR/FIELD/SLM-03

#### Report No. : MSKGL/ED/2024-25/002243

Sample No. : MSKGL/ED/2024-25/06/00964

#### RESULT

Chemical								
SI No.	Parameter	UOM	Method	Result	Zone	Limit as per CPCB at Day (06.00-22.00)	Limit as per CPCB at Night (22.00-06.00)	
1	Leq dB(A) day	dB(A)	IS 9989	67.7	Industrial	75		
2	Leq dB(A) night	dB(A)	IS 9989	64.3	Industrial		70	

**Opinion** : NA

Statement of Conformity : NA

End

**Reviewed By:** 

Signature Name Designation. : Avanta comer forth : Mr. Ananta Kumar Rath : Operational Manager Authorized Signatory For Mitra S.K. Private Limited

Signature Name Designation

Anante Kuman Rosth : Mr. Ananta Kumar Rath

: Operational Manager

- The results relate only to the item(s) tested.
- This Test Report shall not be reproduced except in full, without the permission of Mitra S.K. Private Limited.
- The reserved part of sample(s) shall be retained for 10 days & 1 years (Air) from the date of issue of the Test Report.

Head Office: Shrachi Centre (5th floor), 74B, A.J.C. Bose Road, Kolkata - 700 016. West Bengal, India. Tel. : 91 33 40143000 / 22650006 / 22650007 Fax : 91 33 22650008 Email : info@mitrask.com. Website: www.mitrask.com

Page 1 of 1

Doc No MSK/GEN/19/01

TESTING INSPECTION

MSK

Building No.D5, Unit No- 230, Bhumi World Industrial Park, Mumbai, Nashik Highway, Pimplas Village, Bhiwandi, Near Kalyan Bhiwandi Bypass, Tal - Bhiwandi Dist. Thane- 421302. Tel. : 0252 2672352. Email: <u>mumbailab@mitrask.com</u> Web : www.mitrask.com



#### **TEST REPORT**

Name & Address of the Customer: TATA STEEL LTD. NH-55, NARENDRAPUR,MERAMANDLI DHENKANAL,Odisha-759129 India Report No. Date Sample No. Date of receipt of sample Date(s) of performance Location of performance of Ref. No. & Date Discipline : MSKGL/ED/2024-25/002244 : 10.07.2024 : MSKGL/ED/2024-25/06/00966 : 26.06.2024 : 26.06.2024 - 30.06.2024 : Permanent Facility : 3000148695/A06 : Chemical

We hereby certify that the following sample drawn by us from the customer has been analyzed with the following results: <u>ANALYSIS RESULT</u>

1. Group	Atmospheric Pollution	
2. Description of sample	Noise	
3. Unique Identification of sample(if any)	NA	
4. Date of sampling	25/06/2024	
5. Place of sampling	Caaqms-6(Wagon Tippler)	
6. Environmental conditions during sampling & Transport	NA	-
7. Sampling Plan & Method used	IS 9989:1981	
8. Identification of the personnel performing sampling by MSK	Ananda Sahoo	
9. Field Equipments Used	MSK/BBSR/FIELD/SLM-03	1.1

Report No. : MSKGL/ED/2024-25/002244

Sample No. : MSKGL/ED/2024-25/06/00966

#### RESULT

Chemical								
SI No.	Parameter	UOM	Method	Result	Zone	Limit as per CPCB at Day (06.00-22.00)	Limit as per CPCB at Night (22.00-06.00)	
1	Leq dB(A) day	dB(A)	IS 9989	66.2	Industrial	75		
2	Leq dB(A) night	dB(A)	IS 9989	62.4	Industrial		70	

**Opinion** : NA

Statement of Conformity : NA

End

**Reviewed By:** 

Signature

Designation.

Name

Ananta kiema pots

: Mr. Ananta Kumar Rath : Operational Manager Authorized Signatory For Mitra S.K. Private Limited Signature : An Name : Mr. Anar

Avanta Kumo- Rath : Mr. Ananta Kumar Rath

Designation : Operational Manager

- The results relate only to the item(s) tested.
- This Test Report shall not be reproduced except in full, without the permission of Mitra S.K. Private Limited.
- The reserved part of sample(s) shall be retained for 10 days & 1 years (Air) from the date of issue of the Test Report.

Head Office: Shrachi Centre (5th floor), 74B, A.J.C. Bose Road, Kolkata - 700 016. West Bengal, India. Tel. : 91 33 40143000 / 22650006 / 22650007 Fax : 91 33 22650008 Email : info@mitrask.com. Website: www.mitrask.com

Page 1of 1

Building No.D5, Unit No- 230, Bhumi World Industrial Park, Mumbai, Nashik Highway, Pimplas Village, Bhiwandi, Near Kalyan Bhiwandi Bypass, Tal - Bhiwandi Dist. Thane- 421302. Tel. : 0252 2672352. Email: mumbailab@mitrask.com Web : www.mitrask.com

#### MSK TESTING . INSPECTION

#### **TEST REPORT**

Name & Address of the Customer: TATA STEEL LTD. NH-55, NARENDRAPUR, MERAMANDLI DHENKANAL, Odisha-759129 India

Report No. Date Sample No. Date of receipt of sample Date(s) of performance Location of performance of Ref. No. & Date Discipline

: MSKGL/ED/2024-25/002245 : 10.07.2024 : MSKGL/ED/2024-25/06/00968 : 27.06.2024 : 27.06.2024 - 02.07.2024 : Permanent Facility : 3000148695/A06 : Chemical

We hereby certify that the following sample drawn by us from the customer has been analyzed with the following results: ANALYSIS RESULT

1. Group	Atmospheric Pollution
2. Description of sample	Noise
3. Unique Identification of sample(if any)	NA
4. Date of sampling	26/06/2024
5. Place of sampling	Caaqms-7(Material Gate)
6. Environmental conditions during sampling & Transport	NA
7. Sampling Plan & Method used	IS 9989:1981
8. Identification of the personnel performing sampling by MSK 9. Field Equipments Used	Ananda Sahoo
2. Field Equipments Used	MSK/BBSR/FIELD/SLM-03

Report No. : MSKGL/ED/2024-25/002245

Sample No.: MSKGL/ED/2024-25/06/00968

#### RESULT

Chemical								
SI No.	Parameter	UOM	Method	Result	Zone	Limit as per CPCB at Day (06.00-22.00)	Limit as per CPCB at Night (22.00-06.00)	
1	Leq dB(A) day	dB(A)	IS 9989	69.5	Industrial	75	(22.00-00.00)	
2	Leq dB(A) night	dB(A)	IS 9989	65.8	Industrial		70	

**Opinion** : NA

Statement of Conformity : NA

End

**Reviewed By:** 

Signature Name Designation.

: Ananta Kum Rath : Mr. Ananta Kumar Rath : Operational Manager

Authorized Signatory For Mitra S.K. Private Limited

Signature Name Designation

Ananta kunon Rath : Mr. Ananta Kumar Rath : Operational Manager

The results relate only to the item(s) tested. .

- This Test Report shall not be reproduced except in full, without the permission of Mitra S.K. Private Limited.
- The reserved part of sample(s) shall be retained for 10 days & 1 years (Air) from the date of issue of the Test Report.

Head Office: Shrachi Centre (5th floor), 74B, A.J.C. Bose Road, Kolkata - 700 016. West Bengal, India. Tel. : 91 33 40143000 / 22650006 / 22650007 Fax : 91 33 22650008 Email : info@mitrask.com. Website: www.mitrask.com

Page 1of 1

Address of Laboratory :

Building No. P- 48, Udayan Industrial Estate, 3, Pagladanga Road, Kolkata 700015 West Bengal Tel. : +91 7044036120 Email: udayanlab@mitrask.com



#### TEST REPORT

#### Name & Address of Customer :

TATA STEEL LTD.

NH-55, NARENDRAPUR, MERAMANDLI, DHENKANAL ODISHA India Pin 759129

#### Report No. : Date : Sample No. : Date of receipt of sample: Date(s) of performance: Location of performance of Reference No. & Date : Discipline:

MSKPL/ED/2024-25/NH5181 22/05/2024 MSKNB/ED/2024-25/05/RX3F1U 16/05/2024 16/05/2024 - 21/05/2024 Permanent Facility 3000148695/A06, Date - 15/12/2022 Chemical

Scan for Portal

ULR: TC-695024000008863F

certify that the following sample Drawn by us has been analyzed with the following results:

Ve hereby certify that the following sample brann by certify that the following sample brann by	Atmospheric Pollution
1. Group	Noise
2. Description of sample	NA
3. Unique Identification of sample(if any)	13/05/2024
4. Date of sampling	Caagms-1(Colony)
5. Place of sampling	NA
6. Environmental conditions during sampling & Transport	IS 9989:1988
7. Sampling Plan & Method used	Chinmaya Biswal
8. Identification of the personnel performing sampling by MSK	MSK/BBSR/FIELD/SLM-03
9. Field Equipments Used	more been and a second s

Report No.: MSKPL/ED/2024-25/NH5181

NA

Sample No.: MSKNB/ED/2024-25/05/RX3F1U

#### RESULT

Chemical							Limit as per CPCB at Nigh
SI No.	Parameter	UOM	Method	Result	Zone	Limit as per CPCB at Day (06.00-22.00)	(22.00-06.00)
		10(1)	IS 9989	69.4	Industrial	75	• 1
1	Leq dB(A) day	dB(A)					70
2	Leq dB(A) night	dB(A)	IS 9989	63.4	Industrial		

**Opinion**:

NA Statement of Conformity

---- END ------

Reviewed By Signature Name

Designation

Authorized Signatory Signature Name Technical In charge Designation

E

utive Chemist

The results results results results results reproduced except in full, without the permission of Mitra S.K. Private Limited. This Test Report shall not be reproduced except in full, without the permission of Mitra S.K. Private Limited. The reserved part of sample(s) for chemical analysis (Non - perishable sample(s) Food, Water's shall be retained for 15 days from the date of issue of the Test Report. Perishable sample(s) shall be retained 2 days from the date of issue of the Test Report.

The reserved part of sample(s) for chemical analysis (Soil, Solid & Liquid Waste) shall be retained for 15 days as per CPCB guideline & (Air) 1 month from the date of issue of the Test Report. The reserved part of sample(s) for Microbiological analysis (Non - perishable sample(s) Food, Sealed Water, Sealed food) shall be retained for 15 days from the date of issue of the Test Report.

Shrachi Centre (5th Floor), 74B, A.J.C. Bose Road, Kolkuta - 700016, West Bengal, India. Tel. : 91 33 40143000 / 22550007 Fax : 91 33 22650008 Head Office: Email : info@mitrask.com Website : www.mitrask.com





Address of Laboratory :

Building No. P- 48, Udayan Industrial Estate, 3, Pagladanga Road, Kolkata 700015 West Bengal Tel.: +91 7044036120 Email: udayanlab@mitrask.com



### TEST REPORT

#### Name & Address of Customer :

TATA STEEL LTD.

NH-55, NARENDRAPUR, MERAMANDLI, DHENKANAL ODISHA India Pin 759129

Report No. : Date : Sample No. : Date of receipt of sample: Date(s) of performance: Location of performance of Reference No. & Date : Discipline:

MSKPL/ED/2024-25/U3519Y 22/05/2024 MSKNB/ED/2024-25/05/KF3F1Y 17/05/2024 17/05/2024 - 21/05/2024 Permanent Facility 3000151489/A06, Date - 01/04/2023 Chemical

Scan for Portal

ULR: TC-695024000008866F

certify that the following sample Drawn by us has been analyzed with the following results:

Ve hereby certify that the following sample brann by come	Atmospheric Pollution
1. Group	Noise
2. Description of sample	NA
3. Unique Identification of sample(if any)	15/05/2024
4. Date of sampling	Sarapa
5. Place of sampling	NA
6. Environmental conditions during sampling & Transport	IS 9989:1988
7. Sampling Plan & Method used	Ananda Sahoo
8. Identification of the personnel performing sampling by MSK	MSK/BBSR/FIELD/SLM-01
9. Field Equipments Used	more bore received at

9. Field Equipm

Report No. : MSKPL/ED/2024-25/U3519Y

NA

Sample No.: MSKNB/ED/2024-25/05/KF3F1Y

#### RESULT

Chemical							Limit as per CPCB at Nigh
SI No.	Parameter	UOM	Method	Result	Zone	Limit as per CPCB at Day (06.00-22.00)	(22.00-06.00)
		10(4)	IS 9989	49.2	Industrial	75	•
1	Leq dB(A) day	dB(A)					70
2	Leq dB(A) night	dB(A)	IS 9989	46.7	Industrial		1

**Opinion**:

NA Statement of Conformity

---- END ------

Reviewed By. Signature

Mr. Bay Name

Authorized Signatory Signature adip Bag Name Mr Technical In charge Designation :

Designation : Executive Chemist

The results relate only to the item(s) tested. This Test Report shall not be reproduced except in full, without the permission of Mitra S.K. Private Limited. The reserved part of sample(s) for chemical analysis (Non - perishable sample(s) Food, Water) shall be retained for 15 days from the date of issue of the Test Report. Perishable sample(s) shall be retained 2 days from the date of issue of the Test Report. The reserved part of sample(s) for chemical analysis (Solit, Solid & Liquid Waste) shall be retained for 15 days as per CPCB guideline & (Air) 1 month from the date of issue of the Test Report. The reserved part of sample(s) for dhemical analysis (Solit, Solid & Liquid Waste) shall be retained for 15 days as per CPCB guideline & (Air) 1 month from the date of issue of the Test Report. The reserved part of sample(s) for Microbiological analysis (Non - perishable sample(s) Food, Sealed Water, Sealed food) shall be retained for 15 days from the date of issue of the Test Report.

Shrachi Centre (5th Floor), 74B, A.J.C. Bose Road, Kolkata - 700016, West Bengal, India. Tel. : 91 33 40143000 / 22650007 Fax : 91 33 22650008 Email : info@mitrask.com Website : www.mitrask.com Head Office:



Address of Laboratory :

Building No. P- 48, Udayan Industrial Estate, 3, Pagladanga Road, Kolkata 700015 West Bengal Tel. : +91 7044036120 Email: udayanlab@mitrask.com



## TEST REPORT

#### Name & Address of Customer :

TATA STEEL LTD

NH-55, NARENDRAPUR, MERAMANDLI, DHENKANAL ODISHA India Pin 759129

#### Report No. : Date : Sample No. : Date of receipt of sample: Date(s) of performance: Location of performance of Reference No. & Date : Discipline:

MSKPL/ED/2024-25/LM518Z 22/05/2024 MSKNB/ED/2024-25/05/R43F15 16/05/2024 16/05/2024 - 21/05/2024 Permanent Facility 3000151489/A06, Date - 01/04/2023 Chemical

certify that the following sample Drawn by us has been analyzed with the following results:

Ve hereby certify that the following sample brawn by do not been by	Atmospheric Pollution
1. Group	Noise
2. Description of sample	NA
3. Unique Identification of sample(if any)	14/05/2024
4. Date of sampling	Sibapur
5. Place of sampling	
6. Environmental conditions during sampling & Transport	NA
7 Sampling Plan & Method used	IS 9989:1988
8. Identification of the personnel performing sampling by MSK	Ananda Sahoo MSK/BBSR/FIELD/SLM-01
9 Field Equipments Used	MSK/BBSR/FIELD/SEMIOT

9. Field Equipments Used

Report No. : MSKPL/ED/2024-25/LM518Z

NA

Sample No. : MSKNB/ED/2024-25/05/R43F15

#### RESULT

Chemical							Limit as per CPCB at Night
SI No.	Parameter	UOM	Method	Result	Zone	Limit as per CPCB at Day (06.00-22.00)	(22.00-06.00)
		10(4)	IS 9989	48.4	Industrial	75	-
1	Leq dB(A) day	dB(A)					70
2	Leq dB(A) night	dB(A)	IS 9989	46.9	Industrial	-	

Opinion :

Statement of Conformity NA

----- END ------

Signature Name Designation Executive Chemist

Reviewed By

Authorized Signatory Signature 10 Mr. Pradip Beg Name Technical In charge Designation

The results relate only to the item(s) tested. This Test Report shall not be reproduced except in full, without the permission of Mitra S.K. Private Limited. This reserved part of sample(s) for chemical analysis (Non - perishable sample(s) Food, Water) shall be retained for 15 days from the date of issue of the Test Report. Perishable sample(s) shall be retained 2 days from the date of issue of the Test Report. The reserved part of sample(s) for chemical analysis (Solil, Solid & Liquid Waste) shall be retained for 15 days as per CPCB guideline & (Air) 1 month from the date of issue of the Test Report. The reserved part of sample(s) for Microbiological analysis (Non - perishable sample(s) Food, Sealed Water, Sealed food) shall be retained for 15 days from the date of issue of the Test Report. The reserved part of sample(s) for Microbiological analysis (Non - perishable sample(s) Food, Sealed Water, Sealed food) shall be retained for 15 days from the date of issue of the Test Report. Page 1 of 1

Strachi Centre (5th Floor), 748, A.J.C. Bose Road, Kolkata - 700016, West Bengal, India. Tel.: 91 33 40143000 / 22650007 Fax: 91 33 22650008 Email: info@mitrask.com Website: www.mitrask.com Head Office:





Scan for Portal

ULR: TC-695024000008865F

Address of Laboratory :

Building No. P- 48, Udayan Industrial Estate, 3, Pagladanga Road, Kolkata 700015 West Bengal Tel. : +91 7044036120 Email: udayanlab@mitrask.com



#### TEST REPORT

#### Name & Address of Customer :

TATA STEEL LTD.

NH-55, NARENDRAPUR, MERAMANDLI, DHENKANAL ODISHA India Pin 759129

#### Report No. : Date : Sample No. : Date of receipt of sample: Date(s) of performance: Location of performance of Reference No. & Date : **Discipline:**

MSKPL/ED/2024-25/DN5181 22/05/2024 MSKNB/ED/2024-25/05/253F1F 16/05/2024 16/05/2024 - 21/05/2024 Permanent Facility 3000151489/A06, Date - 01/04/2023 Chemical

that the following sample Drawn by us has been analyzed with the following results:

We hereby certify that the following sample Drawn by us has been any	Atmospheric Pollution
1. Group	Noise
2. Description of sample	NA
3. Unique Identification of sample(if any)	13/05/2024
4. Date of sampling	Kochilamara
5. Place of sampling	NA
6. Environmental conditions during sampling & Transport	IS 9989:1988
7. Sampling Plan & Method used	Ananda Sahoo
8. Identification of the personnel performing sampling by MSK	MSK/BBSR/FIELD/SLM-01
9 Field Equipments Used	Moroborn inconcern

9. Field Equipmi

Report No. : MSKPL/ED/2024-25/DN5181

NA

Sample No. : MSKNB/ED/2024-25/05/253F1F

#### RESULT

Chemical					T		Limit as per CPCB at Nigh
SI No.	Parameter	UOM	Method	Result	Zone	Limit as per CPCB at Day (06.00-22.00)	(22.00-06.00)
			IS 9989	48.9	Industrial	75	
1	Leq dB(A) day	dB(A)	12 3303				70
2	Leg dB(A) night	dB(A)	IS 9989	45.9	Industrial	· ·	1

Opinion	:

Statement of Conformity NA

---- END ------

Reviewed By Signature Name

Designation

Authorized Signatory Signature tio Bag Name Technical In charge Designation

Ex

ative Chemist

The results relate only to the item(s) tested. This Test Report shall not be reproduced except in full, without the permission of Mitra S.K. Private Limited. The reserved part of sample(s) for chemical analysis (Non - perishable sample(s) Food, Water) shall be retained for 15 days from the date of issue of the Test Report. Perishable sample(s) shall be retained 2 days from the date of issue of the Test Report. The reserved part of sample(s) for chemical analysis (Soil, Solid & Liquid Waste) shall be retained for 15 days as per CPCB guideline & (Air) 1 month from the date of issue of the Test Report. The reserved part of sample(s) for chemical analysis (Soil, Solid & Liquid Waste) shall be retained for 15 days as per CPCB guideline & (Air) 1 month from the date of issue of the Test Report. The reserved part of sample(s) for Microbiological analysis (Non - perishable sample(s) Food, Sealed Water, Sealed food) shall be retained for 15 days from the date of issue of the Test Report.

Shrachi Centre (5th Floor), 74B, A J C. Bose Road, Kolkata - 700016, West Bengal, India. Tel. : 91 33 40143000 / 22650007 Fax : 91 33 22650008 Email : info@mitrask.com Website : www.mitrask.com Head Office:







Scan for Portal

ULR: TC-695024000008864F