



TSM-CPP/MoEF&CC/TS-01/2025-03/189
May 20, 2025

The Member Secretary

State Level Environmental Impact Assessment Authority,
5RF-2/1, Unit-IX
Bhubaneswar-751022

Subject: Submission of half yearly EC compliance reports for setting up of 2x150 MW coal based TPP at M/s. Tata Steel Limited-TSM-CPP(formerly known as Angul Energy Limited), Odisha for the period from October' 2024 to March' 2025.

Reference: EC vide letter No. SEIAA/35; dated: 12.12.2009.

Dear Sir,

With reference to the captioned subject and cited reference, we are herewith submitting six monthly compliance reports for the conditions stipulated in the Environmental Clearance for setting up of 2x150 MW coal based thermal power plant at Tata Steel Limited-TSM-CPP(formerly known as Angul Energy Limited), Odisha for the period from October' 2024 to March' 2025 along with monitoring reports for your kind perusal.

The soft copies of the aforesaid compliance report are also being sent through mail to roez.bsr-mef@nic.in & seiaaodisha@gmail.com for your kind information and necessary record please. Also copy of EC compliance is being uploaded on MoEF&CC web site on portal <http://environmentalclearance.nic.in>.

Hope, the above are in line with the statutory requirements.

Thanking you

Yours faithfully,

For TSM-CPP


Rajesh Kumar Agarwal
(Factory Manager, TSM-CPP)

Encl: As above

- Copy to:**
1. The Deputy Director General of Forests (C), MoEF&CC, Integrated Regional Office, Chandrasekharpur, Bhubaneswar – 751023.
 2. The Zonal Officer, Central Pollution Control Board, Southern Conclave Block, 502, 5th & 6th Floors, 1582 Rajdanga Main Road, Kolkata – 700107.
 3. The Member Secretary, SPCB, Parivesh Bhawan, A/118, Nilakantha Nagar, Unit-VIII, Odisha, Bhubaneswar-751012
 4. The Regional Officer, State Pollution Control Board, Angul, Odisha.

TATA STEEL LIMITED

Ganthigadia Nuahata Banarpal Angul 759 128 Odisha India Tel 91 6762 352000

Registered Office Bombay House 24 Homi Mody Street Fort Mumbai 400 001 India Tel 91 22 6665 7371 Fax 91 22 6665 7724

Corporate Identification Number L27100MH1907PLC00260 website www.tatasteel.com



HALF YEARLY COMPLIANCE REPORT

(Period from October' 2024 to March' 2025)

Compliance Status of Environment Clearance for setting up of 2x150 MW coal based thermal power plant at Tata Steel Limited – TSM-CPP (formerly known as Angul Energy Limited), Ganthigadia District Angul, Odisha vide SEIAA letter No. SEIAA/35, Dated. 15.12.2009

SL	STIPULATED CONDITIONS	COMPLIANCE STATUS
01	The applicant (project proponent) will take necessary measures for prevention, control and mitigation of Air Pollution, Water Pollution, Noise Pollution and Land Pollution including solid waste management as mentioned in Form-I, final EIA reports and Environment Management Plan (EMP) in compliance with the prescribed statutory norms and standards.	Adequate pollution control measures such as ESPs, pneumatic ash conveying system, vent filters, mechanical road sweeping machines, wheel washing facilities, dust suppression system, Sewage Treatment Plant, enclosures & silencers, Dry collection & disposal system for waste, fly ash management were taken for the prevention and mitigation of air pollution, water pollution, noise pollution and land pollution including solid waste management.
02	The applicant will take necessary steps for socio-economic development of the people of the area Primary Socio Economic Survey of the core area on need based assessment for providing employment, education, health care, drinking water, sanitation, road and communication facilities etc. A detailed report is to be submitted to the proposal to SEIAA on 1 st June & 1 st December of each calendar year.	Various socio-economic development programs are being undertaken in nearby villages based on a need assessment survey. These programs encompass the provision of educational facilities, such as the Green School Project in collaboration with TERI, as well as road construction and repair. Additionally, initiatives include the provision of safe drinking water, sanitation facilities, sports, and healthcare services. These efforts represent a combination of social engineering and infrastructure projects aimed at improving the overall quality of life in the communities served.
03	The applicant will comply with the points concerned and issues raised by the people during public hearing on 4 th February, 2009 in accordance with the commitments made.	Issues raised during the public hearing were mainly related to drinking water, wastewater management, employment and peripheral development, which had already been completed.
04	The applicant will take statutory clearance / approval / permissions from the concerned authorities in respect of the project as and when required.	Statutory approvals from concerned authorities were obtained and are being renewed from time to time.
05	For post environmental clearance monitoring, the applicant will submit half yearly compliance report in respect of the stipulated terms and conditions of this Environmental Clearance to the State Environmental Impact Assessment Authority (SEIAA), Orissa on 1 st June and 1 st December of each calendar year.	Half-yearly environmental compliance report is being submitted to SEIAA, MOEF&CC, CPCB and SPCB, Odisha at stipulated intervals. The last half yearly compliance report was submitted vide letter no. TSM-CPP/SEIAA/TS-01/2024-05/168 dated 27.11.2024

HALF YEARLY COMPLIANCE REPORT

(Period from October' 2024 to March' 2025)

Compliance Status of Environment Clearance for setting up of 2x150 MW coal based thermal power plant at Tata Steel Limited – TSM-CPP (formerly known as Angul Energy Limited), Ganthigadia District Angul, Odisha vide SEIAA letter No. SEIAA/35, Dated. 15.12.2009

06	High efficiency Electrostatic Precipitators (ESP's) shall be installed to ensure that particulate emission does not exceed 50 mg / Nm ³ .	Electrostatic Precipitators (ESPs) with 99.97% efficiency have been installed to meet the emission level below 50 mg/Nm ³ .
07	The proponent shall treat the flue gas through Flue Gas De-sulphurization (FGD), if SO ₂ emission levels exceed the prescribed norm.	CFBC (Circulating Fluidized Bed Combustion) coal-fired boiler has been installed, and to control SO ₂ emissions, lime is being fed along with the coal. Adequate space has been provided for the installation of a lime injection system, and a lime sizing plant is currently under construction to supply sized lime for the effective reduction of SO ₂ emissions.
08	Adequate dust extraction system such as cyclones / bag filters and water spray system in dusty areas such as in coal handling and ash handling points, transfer areas and other vulnerable dusty areas shall be provided.	<ul style="list-style-type: none"> Dust extraction systems and dust suppression measures are actively implemented at ash silos and coal handling areas. A Wheel washing system is in operation to prevent fugitive dust emissions during the movement of fly ash vehicles.
09	Fly ash shall be collected in dry form and storage facility (silos) shall be provided. 100% fly ash utilization shall be ensured as per fly ash notification of MoEF, Govt. of India. Unutilized fly ash and bottom ash shall be stored in the ash pond separately through high concentration slurry disposal method. Mercury levels along with other heavy metals (Pb, Cr, As etc.) should be monitored in the fly ash bottom ash, leachate and effluents emanating from the ash pond.	<ul style="list-style-type: none"> Ash is being collected in dry form in the ash silo. Four silos with a capacity of 1,000 MT each and two intermediate silos with a capacity of 250 MT each have been installed. Ash utilization is being ensured. Leachate characteristics of ash are carried out at regular intervals. The report is enclosed as Annexure -I. Annual implementation report w.r.t. fly ash generation and utilization report is being submitted periodically. The last report was submitted vide letter no. TSM-CPP/SPCB/TS-06/2025-01/186.
10	The ash pond should be constructed with impervious lining and ash pond embankment should be stone pitched.	<ul style="list-style-type: none"> Fly ash has been stored in ash silo and is being supplied to actual user through covered trucks/bulker/rake to avoid any fugitive emission due to transportation. An interim ash pond is currently in operation to Store and manage ash in case of emergencies to ensure proper handling until final disposal can be arranged.
11	The treated effluents conforming to the prescribed standards shall be re-circulated and reused within the plant. There shall be no discharge outside the plant boundary.	<ul style="list-style-type: none"> Wastewater is being treated in the Effluent Treatment Plant and recycled & reused for dust suppression and irrigation of green areas.

HALF YEARLY COMPLIANCE REPORT

(Period from October' 2024 to March' 2025)

Compliance Status of Environment Clearance for setting up of 2x150 MW coal based thermal power plant at Tata Steel Limited – TSM-CPP (formerly known as Angul Energy Limited), Ganthagadia District Angul, Odisha vide SEIAA letter No. SEIAA/35, Dated. 15.12.2009

	Arrangements shall be made so that effluents and storm water do not get mixed.	<ul style="list-style-type: none"> • Rainwater collected from the plant area is being channelized through drains into a series of storage ponds for harvesting.
12	A sewage treatment plant shall be provided and the treated sewage shall be used for raising greenbelt / plantation	A sewage treatment plant with a capacity of 3000 KLD is currently in operation to treat domestic sewage. The treated water serves two primary purposes: it is reused for irrigation of green areas and for low-end applications within the plant.
13	Rainwater harvesting should be adopted. Central Groundwater Authority Board shall be consulted for finalization of appropriate rainwater harvesting technology within a period of three months from the date of clearance and details shall be furnished to the SEIAA, Orissa.	Earthen ponds have been created to manage surface runoff. However, a detailed scientific study has been conducted to explore more effective methods for managing surface runoff and rainwater harvesting. A Site-specific rainwater harvesting structures are being constructed in a phased manner.
14	Adequate safety measures shall be provided in the plant area to check/minimize spontaneous fires in coal yard, especially during summer season. Details of these measures to be taken along with location plant layout shall be submitted to the SEIAA, Orissa.	<ul style="list-style-type: none"> • Fire hydrants have been installed in coal yards as well as in the coal sheds, to control spontaneous fires. • Gun sprinklers have been installed in the yards to maintain surface moisture. • Coal piles are being leveled by scraping and compacted by rolling. • Coal silos/bins are operated on a "First In, First Out" (FIFO) principle to prevent spontaneous combustion. • Fire tenders are on standby 24/7 to handle any fire emergencies.
15	Storage facilities for auxiliary liquid fuel such as LDO and/HFO shall be made in the plant area where risk is minimum. On site and off site Disaster Management Plans shall be prepared to meet any eventuality in case of an accident taking place. Mock drills shall be conducted regularly and based on the same, modifications required, if any shall be incorporated in the Disaster Management Plan (DMP). Sulphur content in the liquid fuel will not exceed 0.5%.	<ul style="list-style-type: none"> • LDO/HSD is being stored in the plant area where the risk is minimum. There is a dyke around the storage tanks. • On-site emergency plan was prepared and approved. • Regular mock drills are being conducted. • Presently domestic coal being used having sulphur content less than 0.5 %.
16	Regular monitoring of ground water in and around the ash pond area shall be carried out, records maintained and half yearly reports shall be furnished to the SEIAA, Orissa.	Monitoring of ground water in the peripheral villages is carried out every quarter. The results are submitted to the SEIAA/IRO MoEF&CC in every six months along with the half yearly compliance report. The summarized data for

HALF YEARLY COMPLIANCE REPORT

(Period from October' 2024 to March' 2025)

Compliance Status of Environment Clearance for setting up of 2x150 MW coal based thermal power plant at Tata Steel Limited – TSM-CPP (formerly known as Angul Energy Limited), Ganthigadia District Angul, Odisha vide SEIAA letter No. SEIAA/35, Dated. 15.12.2009

		the period from Oct'24 to Mar'25 is enclosed as Annexure II.
17	A green belt of adequate width and density preferably with local species along the periphery of the plant & alongside roads etc shall be raised so as to provide protection against particulates and noise. It must be ensured that at least 33 % of the total land area shall be under permanent green cover. The project proponent shall ensure proper maintenance of green belt throughout the year & for this purpose they may engage professionals in this field for creation and maintenance of the green belt. An action plan for this purpose shall be prepared accordingly and submitted to the SEIAA, Orissa.	<ul style="list-style-type: none"> • , Greenery has developed in and around the plant premises using mainly native plant species. • Green belt development is under progress in and around the plant complex by planting indigenous species as per CPCB guidelines. 33 % of total plant area has been covered under green belt. • Proper maintenance of green coverage is ensured throughout the year.
18	First aid and sanitation arrangements shall be made for the drivers and other contract workers during construction phase.	Adequate first aid and sanitation arrangements are ensured for employees and workers. This ensures a safe and healthy environment for all personnel involved in the project.
19	Noise levels emanating from turbines and air compressors shall be limited to 75 dB (A). For people working in the high noise area, requisite personal protective equipment's like ear plugs/earmuffs etc. shall be provided. Workers engaged in noisy areas such as turbine area, air compressors etc. shall be periodically examined to maintain audiometric record and for treatment for any hearing loss including shifting to non - noisy / less noisy areas.	<ul style="list-style-type: none"> • Enclosures and silencers have been provided for the primary and secondary air fans of boilers. • Necessary personal protective equipment (PPE) is being supplied to workers in noisy areas, and periodic examinations are conducted for those engaged in noise-prone environments. • Noise monitoring is carried out regularly in the work zone areas. • The summary of noise monitoring report is enclosed as Annexure-III.
20	Regular monitoring of ground level concentration of SO ₂ , NO _x , SPM, RSPM and mercury shall be carried out in the impact zone and records to be maintained. If at any stage these levels are found to exceed the prescribed limits, necessary control measures shall be taken immediately. The location of the monitoring stations and frequency of monitoring shall be decided in consultation with SPCB, Orissa.	Ambient air quality monitoring stations have been established in nearby villages in consultation with the SPCB, Odisha, to measure the monthly ground-level concentrations of PM ₁₀ , SO ₂ , and NO _x . A summary of the Ambient Air Quality Report for the period from October 2024 to March 2025 is attached as Annexure-IV.

HALF YEARLY COMPLIANCE REPORT

(Period from October' 2024 to March' 2025)

Compliance Status of Environment Clearance for setting up of 2x150 MW coal based thermal power plant at Tata Steel Limited – TSM-CPP (formerly known as Angul Energy Limited), Ganthigadia District Angul, Odisha vide SEIAA letter No. SEIAA/35, Dated. 15.12.2009

21	Provision shall be made for housing of construction laborers within the site with all necessary infrastructure and facilities such as fuel for cooking, mobile toilets, mobile STP, safe drinking water, medical health care, crèche etc. The housing may be in the form of temporary structures to be removed after the completion of the project.	Adequate arrangements for housing construction workers were made during the construction phase of the plant. These same facilities are being continued during the operational phase for both employees and workers.
22	A separate environment management cell with qualified staff shall be set up for implementation of the stipulated environmental safeguards. A report is to be submitted to SEIAA, Orissa.	The Environment Management Department has been established with qualified and experienced officers to implement the stipulated environmental safeguards and control pollution. Necessary details have already been submitted to the State Environment Impact Assessment Authority (SEIAA), Odisha.
23	Half yearly report of the status of implementation of the stipulated conditions and environmental safeguards shall be submitted to the appropriate authorities.	Half yearly environmental compliance report is being submitted to SEIAA, MOEF&CC, CPCB and SPCB, Odisha. Last compliance report was submitted vide letter no. TSM-CPP/SEIAA/TS-01/2024-05/168 dated 27.11.2024
24	Separate funds shall be allocated for implementation of pollution control measures along with item-wise break-up. These cost shall be included as part of the project cost. The funds earmarked for the environment protection measures shall not be diverted for other purposes and year-wise expenditure should be reported.	The funds earmarked for pollution control measures are not diverted for any other activity. The details of expenditure made to control pollution are being submitted as part of the annual Environment Statement. The last Environment Statement was submitted in Form – V vide letter no. TSM-CPP/SPCB/TS-03/2024-13/160 dated 27.09.2024.
25	The above-mentioned stipulated conditions shall be complied in time bound manner. Failure to comply with any of the conditions mentioned above may result in withdrawal of this clearance and attract action under the provisions of environment protection (EP) Act, 1986.	Compliance with the stipulated conditions is diligently pursued within a specified timeframe through a process of continual improvement.



Visiontek Consultancy Services Pvt. Ltd.

(Committed For Better Environment)

ISO 9001:2015, ISO 14001:2015, ISO 45001:2018 (OH&S), ISO/IEC 17025:2017 Certified

Ref. no: Envlab/24-25/TR-12306

Date: 18.11.2024

ASH ANALYSIS REPORT

1. Name of the Indus : M/s TATA Steel Limited Meramandali, Dhenkanal
2. Sampling Location : S-1: Fly Ash collected from BFPP-1
: S-2: Bed Ash collected from BFPP-1
: S-3: Fly ash collected from AEL-165
: S-4: Bed ash collected from ASL-165
3. Date of Sampling : 11.11.2024
4. Date of Analysis : 12.11.2024 to 18.11.2024
5. Sample Collected by : VCSPL Representative

Sl. No.	Name of the Parameters	Unit	Govt. of India, MoEF & CC Schedule-II based on leachable concentration limits (TCLP) or Soluble Threshold limit Concentration (STLC), Class A2016	Analysis Results			
				S-1	S-2	S-3	S-4
01	Arsenic as As	mg/l	5.0 mg/l	0.004	0.002	0.003	0.002
02	Barium as Ba	mg/l	100.0 mg/l	BDL	BDL	BDL	BDL
03	Cadmium as cd	mg/l	1.0 mg/l	BDL	BDL	BDL	BDL
04	Chromium as Cr	mg/l	5.0 mg/l	BDL	BDL	BDL	BDL
05	Lead as Pb	mg/l	5.0 mg/l	BDL	BDL	BDL	BDL
06	Mercury as Hg	mg/l	0.2 mg/l	BDL	BDL	BDL	BDL
07	Selenium as Se	mg/l	1.0 mg/l	0.003	0.003	0.003	0.003
08	Iron as Fe	mg/l	--	0.81	0.41	0.69	0.36
09	Nickel as Ni	mg/l	20.0 mg/l	0.22	0.16	0.24	0.17
10	Zinc as Zn	mg/l	250.0 mg/l	0.48	0.35	0.49	0.33
11	Manganese as Mn	mg/l	10.0 mg/l	0.41	0.28	0.50	0.32
12	Cobalt as Co	mg/l	80.0 mg/l	BDL	BDL	BDL	BDL
13	Copper as Cu	mg/l	25.0 mg/l	0.37	0.28	0.39	0.26
14	Vanadium as V	mg/l	24.0 mg/l	BDL	BDL	BDL	BDL
15	Aluminium as Al	mg/l	--	4.7	4.3	5.3	4.8
16	Fluoride as F	mg/l	180.0 mg/l	1.79	1.31	1.89	1.36

Reviewed By: 


Approved By: 


Annexure-II

Ground Water Quality Analysis Report of surrounding villages

February 2025

	Location		Kharagprasad	Charadagadia	Sibpur	Kochilamada	Galapada	Motonga	Narendrapur	Khaliberena	Kharagprasad
S.N.	Parameters	unit	GW-01	GW-02	GW-03	GW-04	GW-05	GW-06	GW-07	GW-08	GW-9
1	pH	-	8.12	8.04	7.55	8.08	8.01	7.69	8.21	8.03	8.01
2	Odour	-	Agreeable	Agreeable	Agreeable	Agreeable	Agreeable	Agreeable	Agreeable	Agreeable	Agreeable
3	Colour	mg/l	BDL(DL:2.0)	BDL(DL:2.0)	BDL(DL:2.0)	BDL(DL:2.0)	BDL(DL:2.0)	BDL(DL:2.0)	BDL(DL:2.0)	BDL(DL:2.0)	BDL(DL:2.0)
4	Turbidity	N.T. U	BDL(DL:1.0)	BDL(DL:1.0)	BDL(DL:1.0)	BDL(DL:1.0)	BDL(DL:1.0)	BDL(DL:1.0)	BDL(DL:1.0)	BDL(DL:1.0)	BDL(DL:1.0)
5	Total Dissolved Solids (as TDS)	mg/l	848	841	888	860	876	946	792	780	758
6	Aluminium as Al	mg/l	BDL(DL:0.05)	BDL(DL:0.05)	BDL(DL:0.05)	BDL(DL:0.05)	BDL(DL:0.05)	BDL(DL:0.05)	BDL(DL:0.05)	BDL(DL:0.05)	BDL(DL:0.05)
7	Anionic Surface-Active Agents as (MBAS)	mg/l	BDL(DL:0.05)	BDL(DL:0.05)	BDL(DL:0.05)	BDL(DL:0.05)	BDL(DL:0.05)	BDL(DL:0.05)	BDL(DL:0.05)	BDL(DL:0.05)	BDL(DL:0.05)
8	Boron as B	mg/l	BDL(DL:0.5)	BDL(DL:0.5)	BDL(DL:0.5)	BDL(DL:0.5)	BDL(DL:0.5)	BDL(DL:0.5)	BDL(DL:0.5)	BDL(DL:0.5)	BDL(DL:0.5)
9	Calcium as Ca	mg/l	114	108	114	130	100	130	123	106	139
10	Chloride as Cl	mg/l	57	37	24	93	143	56	89	143	96
11	Copper as Cu	mg/l	BDL(DL:0.05)	BDL(DL:0.05)	BDL(DL:0.05)	BDL(DL:0.05)	BDL(DL:0.05)	BDL(DL:0.05)	BDL(DL:0.05)	BDL(DL:0.05)	BDL(DL:0.05)
12	Fluoride as F	mg/l	1.7	1.9	2.6	3.1	3.8	4.2	1.3	1.4	1.9
13	Residual Free Chlorine	mg/l	BDL(DL:0.1)	BDL(DL:0.1)	BDL(DL:0.1)	BDL(DL:0.1)	BDL(DL:0.1)	BDL(DL:0.1)	BDL(DL:0.1)	BDL(DL:0.1)	BDL(DL:0.1)
14	Iron as Fe	mg/l	BDL(DL:0.5)	BDL(DL:0.5)	BDL(DL:0.5)	BDL(DL:0.5)	BDL(DL:0.05)	BDL(DL:0.5)	BDL(DL:0.5)	BDL(DL:0.5)	BDL(DL:0.5)
15	Magnesium as Mg	mg/l	28	29	25	25	29	40	29	22	14
16	Manganese as Mn	mg/l	BDL(DL:0.05)	BDL(DL:0.05)	BDL(DL:0.05)	BDL(DL:0.05)	BDL(DL:0.05)	BDL(DL:0.05)	BDL(DL:0.05)	BDL(DL:0.05)	BDL(DL:0.05)
17	Mineral Oil	mg/l	BDL(DL:1.0)	BDL(DL:1.0)	BDL(DL:1.0)	BDL(DL:1.0)	BDL(DL:1.0)	BDL(DL:1.0)	BDL(DL:1.0)	BDL(DL:1.0)	BDL(DL:1.0)
18	Nitrate as NO3	mg/l	BDL(DL:0.2)	2.4	3.2	17.4	7.3	5.6	33.2	19	27.6

	Location		Kharagprasad	Charadagadia	Sibpur	Kochilamada	Galapada	Motonga	Narendrapur	Khaliberena	Kharagprasad
S.N.	Parameters	unit	GW-01	GW-02	GW-03	GW-04	GW-05	GW-06	GW-07	GW-08	GW-9
19	Phenolic Compounds as C ₆ H ₅ OH	mg/l	BDL (DL:0.001)	BDL (DL:0.001)	BDL (DL:0.001)	BDL (DL:0.001)	BDL (DL:0.001)	BDL (DL:0.001)	BDL (DL:0.001)	BDL (DL:0.001)	BDL (DL:0.001)
20	Selenium as Se	mg/l	BDL (DL:0.005)	BDL (DL:0.005)	BDL (DL:0.005)	BDL (DL:0.005)	BDL (DL:0.005)	BDL (DL:0.005)	BDL (DL:0.005)	BDL (DL:0.005)	BDL (DL:0.005)
21	Sulphate as SO ₄	mg/l	87	133	89	121	143	112	158	143	126
22	Total Alkalinity as CaCO ₃	mg/l	435	431	420	416	451	500	467	420	482
23	Total Hardness as CaCO ₃	mg/l	402	392	388	428	370	492	430	356	406
24	Zinc as Zn	mg/l	BDL(DL:0.05)	BDL(DL:0.05)	BDL(DL:0.05)	BDL(DL:0.05)	BDL(DL:0.05)	1.06	BDL(DL:0.05)	BDL(DL:0.05)	BDL(DL:0.05)
25	Cadmium as Cd	mg/l	BDL(DL:0.05)	BDL(DL:0.05)	BDL(DL:0.05)	BDL(DL:0.05)	BDL(DL:0.05)	BDL(DL:0.05)	BDL(DL:0.05)	BDL(DL:0.05)	BDL(DL:0.05)
26	Cyanide as CN	mg/l	BDL(DL:0.1)	BDL(DL:0.1)	BDL(DL:0.1)	BDL(DL:0.1)	BDL(DL:0.1)	BDL(DL:0.1)	BDL(DL:0.1)	BDL(DL:0.1)	BDL(DL:0.1)
27	Lead as Pb	mg/l	BDL(DL:0.05)	BDL(DL:0.05)	BDL(DL:0.05)	BDL(DL:0.05)	BDL(DL:0.05)	BDL(DL:0.05)	BDL(DL:0.05)	BDL(DL:0.05)	BDL(DL:0.05)
28	Mercury as Hg	mg/l	BDL (DL:0.001)	BDL (DL:0.001)	BDL (DL:0.001)	BDL (DL:0.001)	BDL (DL:0.001)	BDL (DL:0.001)	BDL (DL:0.001)	BDL (DL:0.001)	BDL (DL:0.001)
29	Nickel (as Ni)	mg/l	BDL(DL:0.05)	BDL(DL:0.05)	BDL(DL:0.05)	BDL(DL:0.05)	BDL(DL:0.05)	BDL(DL:0.05)	BDL(DL:0.05)	BDL(DL:0.05)	BDL(DL:0.05)
30	Total Arsenic (as As)	mg/l	BDL (DL:0.005)	BDL (DL:0.005)	BDL (DL:0.005)	BDL (DL:0.005)	BDL (DL:0.005)	BDL (DL:0.005)	BDL (DL:0.005)	BDL (DL:0.005)	BDL (DL:0.005)
31	E. coli	/100ml	Not Detected	Detected	Not Detected	Not Detected	Not Detected	Detected	Not Detected	Not Detected	Not Detected

Note: BDL: Below Detectable Limit; DL: Detectable Limit, U/S: Upstream D/S: Downstream

Source: Monitoring/ Analysis report of S.K. Mitra Private Limited and Environment Laboratory of TSM.

Annexure-III

Environment Laboratory
TATA Steel Meramandali, Odisha

Ref.No.EMD/LAB/2024/0002

S. No.	Name of the unit	Location	Oct-24	Nov-24	Dec-24	Jan-25	Feb-25	Mar-25
			Leq					
2	110 MW Compressor House TSM-CPP	Near Entrance Point	84.1	84.5	83.2	83.6	83.7	81.7
		Near Compressor	93	91.5	91.6	91.4	90.6	87.5
		Inside Operator office	77.9	71.6	74.8	76	75	73.3
	150 MW Ash Conveying Compressor House TSM-CPP	Near Entrance Point	85.2	84.9	85.1	83.1	85.6	84.7
		Near Compressor	93.4	94.1	92.1	86.8	90	90.3
		Inside Operator office	79.2	78.3	80	80	75.6	79.8
3	165 MW Compressor House TSM-CPP	Near Entrance Point	81.6	83	80.5	82.5	80	81.4
		Near Compressor	92.4	92.7	90.1	90.8	88.2	89.7
		Inside Operator office	79	77.6	78.5	70.8	73.2	70.6
4	300 MW Power Plant TSM-CPP	CFBC Boiler-1						
		Near ID Fan-1	SD	SD	SD	SD	SD	SD
		Near ID Fan-2	SD	SD	SD	SD	SD	SD
		Near S A Fan	SD	SD	SD	SD	SD	SD
		Near P.A. Fan	SD	SD	SD	SD	SD	SD
		Near Boiler -1 Area	SD	SD	SD	SD	SD	SD
		CFBC- Boiler-2						
		Near ID Fan-1	85.7	85.4	85.8	SD	85.9	85.8
		Near ID Fan-2	86.2	85.9	86	SD	85.7	85.7
		Near S A Fan	91.8	91.2	92.2	SD	91.5	90.2
		Near P.A. Fan	92.1	91.9	92.6	SD	91.6	90.4
		Near Boiler -2 Area	84.5	84.6	84.8	SD	84.8	84.8
		CFBC- Boiler-3						
		Near ID Fan-1	86.1	85.7	85.6	85.5	85.1	85.1
		Near ID Fan-2	87	86.5	86.7	86.1	85.4	85.5
		Near S A Fan	92.4	92.6	92.7	91.2	91.7	91
		Near P.A. Fan	92.7	91	93.2	91.8	91.8	90.8
		Near Boiler -3 Area	85.1	85.4	85.3	85.4	85.2	85.4
		CFBC- Boiler-4						
		Near ID Fan-1	SD	SD	85.1	85.8	84.8	84.8
		Near ID Fan-2	SD	SD	85.5	85.4	85.4	85.4
		Near S A Fan	SD	SD	91.2	91.3	90	91.2
		Near P.A. Fan	SD	SD	92.2	91.1	90.3	91.5

Annexure-III

Environment Laboratory
TATA Steel Meramandali, Odisha

S. No.	Name of the unit	Location	Oct-24	Nov-24	Dec-24	Jan-25	Feb-25	Mar-25
			Leq					
		Near Boiler -4	SD	SD	85.2	84.7	85	84.9
		CFBC- Boiler-5						
		Near ID Fan-1	SD	SD	SD	SD	SD	SD
		Near ID Fan-2	SD	SD	SD	SD	SD	SD
		Near S A Fan	SD	SD	SD	SD	SD	SD
		Near P.A. Fan	SD	SD	SD	SD	SD	SD
		Near Boiler -5	SD	SD	SD	SD	SD	SD
		CFBC- Boiler-6						
5	185 MW Power Plant TSM-CPP	Near ID Fan-1	81.1	81.1	80.2	80.5	80	80.5
		Near ID Fan-2	81.3	80.8	80.5	80.8	80.3	81.2
		Near S A Fan	91.1	90.2	91.2	91.4	92	92.1
		Near P.A. Fan	91.4	91.1	91.5	92	91.8	91.5
		Near Boiler -6	84.8	84.8	85.1	84.8	85.3	85
		Near Silo Area	83.5	82.8	83.5	82.4	82.3	82.7
		Near 150 MW TG	89.2	89.2	89.2	89.2	89.1	89.3
		Near 165 MW TG	90.4	89.4	88.4	88.9	88.4	88.8
		Control Room Office	62.4	61.2	64	68.3	62.5	70.4

**SUMMARY OF AMBIENT AIR QUALITY
MONTHLY AVERAGE VALUES**

Month	Locations of Monitoring	Monthly Average				
		Unit in $\mu\text{g}/\text{m}^3$				Unit in mg/m^3
	Pollutant	PM ₁₀	PM _{2.5}	SO ₂	NO _x	CO
	Standard	100	60	80	80	2
Oct'24	CAAQMS-1	114.61	22.72	17.51	24.66	0.66
	CAAQMS-2	115.40	41.32	23.12	11.31	0.73
	CAAQMS-3	105.46	41.13	6.39	18.68	0.73
	CAAQMS-4	67.27	33.57	8.10	25.70	0.25
	CAAQMS-5	92.97	34.30	8.32	20.93	0.96
	CAAQMS-6	106.28	34.50	14.75	18.66	1.00
	CAAQMS-7	93.08	47.40	50.66	15.56	0.74
Nov'24	CAAQMS-1	144.77	41.61	15.28	24.96	0.70
	CAAQMS-2	156.66	70.39	23.08	9.64	0.71
	CAAQMS-3	135.67	66.24	6.46	18.04	0.79
	CAAQMS-4	112.29	72.17	5.49	29.34	0.21
	CAAQMS-5	147.43	64.61	8.11	19.90	0.52
	CAAQMS-6	176.41	55.09	14.58	18.78	0.84
	CAAQMS-7	216.03	95.54	24.14	18.51	1.10
Dec'24	CAAQMS-1	160.55	46.26	15.12	24.75	0.73
	CAAQMS-2	216.80	94.39	23.07	9.61	0.92
	CAAQMS-3	163.75	76.05	5.65	19.37	1.27
	CAAQMS-4	126.61	84.24	5.24	33.54	0.61
	CAAQMS-5	148.71	66.81	9.14	26.89	0.53
	CAAQMS-6	149.22	53.69	14.59	24.62	0.52
	CAAQMS-7	186.13	91.94	10.11	20.38	1.15
Jan'25	CAAQMS-1	184.69	52.22	18.52	17.25	0.41
	CAAQMS-2	243.09	113.05	23.08	5.47	0.72
	CAAQMS-3	191.31	96.96	5.42	17.68	1.14
	CAAQMS-4	113.65	71.37	5.95	31.58	0.47
	CAAQMS-5	150.84	57.52	14.81	10.84	0.62
	CAAQMS-6	174.27	46.45	15.26	18.28	0.43
	CAAQMS-7	246.13	126.09	10.54	14.65	1.15

Month	Locations of Monitoring	Monthly Average				
		Unit in $\mu\text{g}/\text{m}^3$				Unit in mg/m^3
	Pollutant	PM ₁₀	PM _{2.5}	SO ₂	NO _x	CO
	Standard	100	60	80	80	2
Feb'25	CAAQMS-1	180.65	55.67	22.90	9.66	0.82
	CAAQMS-2	220.07	101.39	23.17	9.72	0.43
	CAAQMS-3	193.09	77.35	9.42	16.17	1.20
	CAAQMS-4	132.01	59.52	5.69	24.10	0.69
	CAAQMS-5	140.82	52.02	18.79	13.42	0.90
	CAAQMS-6	154.70	44.05	15.46	15.72	0.49
	CAAQMS-7	206.59	102.64	8.13	18.40	0.99
March'25	CAAQMS-1	167.68	67.94	39.69	6.23	0.71
	CAAQMS-2	233.49	94.75	23.15	4.61	0.76
	CAAQMS-3	175.38	67.95	10.18	19.16	1.26
	CAAQMS-4	117.66	51.89	6.70	23.87	0.59
	CAAQMS-5	150.84	57.52	14.81	10.84	0.62
	CAAQMS-6	134.42	63.79	19.60	14.77	0.52
	CAAQMS-7	187.26	86.61	14.75	18.41	0.97

All values are in $\mu\text{g}/\text{m}^3$ except CO values are in mg/m^3 . All Values are derived from 24 hourly average data except CO values which are derived from 8 hourly average data.

CAAQMS 1: Near Township; CAAQMS 2: Near Utility Department; CAAQMS 3: Near CRM; CAAQMS 4: Near Water Complex; CAAQMS 5: Near Coke Oven 2; CAAQMS 6: Near Wagon Tippler; CAAQMS 7: Near Material Gate, UM: Under Maintenance.